EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	80.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	103.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	74.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	12.94	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	3	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	227	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	227	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	3	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations VCB New	2	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	5	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	183	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	183	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	142.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	158.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	2	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations VCB New	2	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	149.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	205	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	90.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	205	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	75.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	89.0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations VCB New	2	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	2	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	18061	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	9L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	20352	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	10L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	17565	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	12L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7110	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6825.60	kw
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	63.33	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	17565	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	165	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	17565	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Operation Checked?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	All Connections OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.5750	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	5520.00	kw
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	38	°F
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/27/2023 15:18	Distribution	Paris 12kV Substation Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	9 Month Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	9 Month Operations VCB New	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Unknown Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Switching Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AL	190	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AF	190	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Maintenance Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps A Ø	95.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps C Ø	67.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps B Ø	60.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	239	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	239	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations VCB New	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	138.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	177.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	144.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	309.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	302.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	295.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	170	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	170	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations VCB New	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	67.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1072	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1072	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	60.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	95.0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations VCB New	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	0	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	3124	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	3124	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	8L	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	7R	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	577	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	10886.40	kw
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	55	°C
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	30	°C
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	35	°C
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.6048	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.7	VDC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
12/27/2023 15:03	Distribution	Detroit Harvester Substation Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	233	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	233	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	73.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	67.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	75.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations VCB New	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps B Ø	40.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps A Ø	41.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	9 Month Operations VCB New	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	9 Month Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AL	216	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AF	216	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations B Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations A Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations This Read Vac	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Unknown Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps C Ø	38.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations C Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations Ground	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Maintenance Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AL	200	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AF	200	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Maintenance Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations Ground	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations C Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations This Read Vac	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Switching Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Unknown Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations B Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations A Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps C Ø	43.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps B Ø	35.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps A Ø	35.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	9 Month Operations VCB New	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	9 Month Operations	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations VCB New	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	2	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	200.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	190.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	215.0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	365	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	365	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	95286	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53115	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	118556	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	705.84	kw
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5882	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	15878	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	15878	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	7L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	3L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	14L	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	714	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	.8800	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	40	°C
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	60	°C
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	4224.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/26/2023 14:02	Distribution	Carlisle Substation Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	142	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	142	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	20	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	20	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	20	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	3.16	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	3.16	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	3.16	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	52	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	52	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	13.62	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	15.89	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	9.08	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	132	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	132	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	2.27	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	2	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	179	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	179	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	100	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	100	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	100	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations VCB New	3	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	3	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	182747	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	182747	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	213	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3201.6	kw
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.4002	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50	VDC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 13:55	Distribution	Maysville West Substation Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	.14	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	.27	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	57	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	50	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	47	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	190	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	.14	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations VCB New	4	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	4	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	190	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	189	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	189	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	55	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	83	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	83	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	.55	%
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations VCB New	3	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	3	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	70469	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	68397	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	74348	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3254.4	kw
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	25	°C
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.678	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/21/2023 13:38	Distribution	Millersburg Substation Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	10.19	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	1	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations VCB New	1	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	2	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	51.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	50.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	1	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	197	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	60.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	197	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	33.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	194	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	194	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	3	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations VCB New	3	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	66.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	36.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	1	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	182	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	182	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations VCB New	1	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	51.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	52.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	52.0	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	288449	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	288454	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	969	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.5706	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	5477.76	kw
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Present	34	°C
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments	Small oil seeping from LTC drain. Tightened drain plug and cleaned affected area.	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments	added oil to LTC	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 12:34	Distribution	Appalachia Substation Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/21/2023 11:45	Distribution	West Point Substation Inspection	LTCC000179	LTCControl	WP-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	374	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	173135	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	173135	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.4	VDC
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.6	AMPS
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 11:45	Distribution	West Point Substation Inspection	BAT001699	Battery	WP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/21/2023 11:45	Distribution	West Point Substation Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 11:45	Distribution	West Point Substation Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/21/2023 11:45	Distribution	West Point Substation Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Unknown Operations	1	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Switching Operations	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations This Read Vac	1	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AL	254	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AF	254	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Maintenance Operations	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations Ground	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations C Ø	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations B Ø	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations A Ø	0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps C Phase V	9.55	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps B Phase V	9.55	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps A Phase V	9.55	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps C Ø	74.0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps B Ø	74.0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps A Ø	60.0	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations VCB New	4	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations	5	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	General Comments		
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 11:45	Distribution	West Point Substation Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	General Comments	ok	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LTCC000210	LTCControl	MU-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	218443	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	218443	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	303	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 11:40	Distribution	Muldraugh Substation Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	7.12	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	177	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	177	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	11.4	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	14.25	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations VCB New	4	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	4	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	568	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	568	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	60	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	60	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	60	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	2	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	2	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	4.28	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	4.28	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	9.98	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	100	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	430	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	430	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	166	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	221	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	118	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	1.43	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	2.85	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations VCB New	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	2	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	124	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	124	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	88859	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	88859	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	6L	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	204	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.4038	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	3230.4	kw
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50	VDC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:13	Distribution	Maysville Mid Substation Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	180	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	251	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	305	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	214	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	214	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	207	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	207	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	59	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	52	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	61	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	67	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	57	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	53	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	203	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	203	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.43	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2580	kw
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	102	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	84455	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	84455	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49	VDC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 8:08	Distribution	Maysville East Substation Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	215	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	215	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	109	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	102	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	118	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	.62	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	.62	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	.62	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations VCB New	8	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	8	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	3	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations VCB New	3	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	1.56	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	44	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	58	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	90	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	415	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	415	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	277	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	277	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	118	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	108	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	111	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations VCB New	2	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	2	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57653	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	58574	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122	volts
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54301	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6774	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6503.04	kw
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	30	°F
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
12/21/2023 7:57	Distribution	Augusta Substation Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-06-14 00:00:00.000000000	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 7:57	Distribution	Augusta Substation Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	29	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	40	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	35	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	5.29	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	14.73	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	9.44	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations VCB New	13	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	13	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	316	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	316	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations VCB New	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	470	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	498	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	473	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	192	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	192	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	3	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	259	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	259	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	3	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	12.94	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	90	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	89	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	57	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations VCB New	1	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	4	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	2.27	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	2.27	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations VCB New	3	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	56	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	56	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	56	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	237	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	237	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	9	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	234	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	234	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	9	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	45.6	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	342	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	340	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	339	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	1.51	%
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations VCB New	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	9	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	26100	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	26100	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	3L	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	2L	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	369	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	12L	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	15206.4	kw
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	30	°C
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	30	°C
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	1.056	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	50	°C
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	30	°C
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1900	psi
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:50	Distribution	Carntown Substation Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	39.96	kw
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1332	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	41	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	10	°C
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:33	Distribution	Bens Branch Substation Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	1	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	1	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	206	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	206	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	75.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	92.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	71.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations VCB New	4	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	5	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AL	222	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AF	222	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Maintenance Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations C Ø	2	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations A Ø	2	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Unknown Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Switching Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations This Read Vac	4	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps C Ø	114.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps B Ø	133.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps A Ø	103.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations VCB New	13	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations	17	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	267	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	267	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	205.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	150.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	145.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations VCB New	5	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	5	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations VCB New	1	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps A Ø	68.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps B Ø	60.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps C Ø	61.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations	1	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Unknown Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Switching Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AL	175	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AF	175	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Maintenance Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations A Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations B Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations C Ø	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations Ground	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Maintenance Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AF	204	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AL	204	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations This Read Vac	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Switching Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Unknown Operations	0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations	4	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations VCB New	4	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps A Ø	148.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps B Ø	112.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps C Ø	173.0	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.7	VDC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	80550	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	80545	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	806	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	All Connections OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	6733.44	kw
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.7014	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	1072	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	7L	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	3R	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	3L	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	24821	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	24815	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.8730	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	40	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	60	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	6285.60	kw
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	27086	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	27090	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	11L	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	1058	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	1.1420	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	39	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	55	°C
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	8222.40	kw
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments		
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2023 7:34	Distribution	Big Stone Gap Substation Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	14	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	52	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	51	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	46	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	8	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	11	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6915	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8428	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6897	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.9	VDC
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	73369	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71584	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	70313	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0170	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1627.20	kw
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	296	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	296	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	3	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations VCB New	3	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	168.0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	120.0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	108.0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 12:31	Distribution	Pennington Gap Substation Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.6	VDC
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	20	°F
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	561	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	92148	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	92144	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	All Connections OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Operation Checked?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	32	°C
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	41	°C
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	8674.56	kw
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.9036	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	63.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	78.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	78.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	432	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	432	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations This Read Vac	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations VCB New	27	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	27	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations VCB New	17	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	18	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	264.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	1	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	552	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	552	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	1	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	4.81	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	312.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	216.0	
12/20/2023 12:31	Distribution	Poor Valley Substation Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	179	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	179	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	48	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	81	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	93	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations VCB New	2	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	2	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	2	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations VCB New	2	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	.66	%
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	134	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	118	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	140	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	187	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	187	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-12-05 00:00:00.000000000	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	9 Months Operations OCB New	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	427	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	427	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	25	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	25	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.203	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	5774.4	kw
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments	needs Winding temp checked	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	460	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	6R	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	17681	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	17681	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132	VDC
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132	VDC
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/20/2023 9:54	Distribution	Flemingsburg Substation Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	19	°F
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	10.000	millivolts
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	728	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	3R	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	1R	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	25848	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	25846	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	9311.76	kw
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	59	°C
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	48	°C
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	1.2933	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations This Read Vac	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Switching Operations	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps B Ø	150.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations C Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations B Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations A Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps C Ø	224.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AL	174	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps A Ø	272.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	9 Month Operations VCB New	6	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	9 Month Operations	6	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations Ground	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AF	174	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Maintenance Operations	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps B Ø	186.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps A Ø	121.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	9 Month Operations VCB New	14	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps C Ø	218.0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	9 Month Operations	14	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations A Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations B Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations C Ø	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Maintenance Operations	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AF	163	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations Ground	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Unknown Operations	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Switching Operations	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations This Read Vac	0	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AL	163	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	General Comments		
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 9:52	Distribution	Hamblin Substation Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.5	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 11:36	Distribution	Sardis Substation Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	1.42	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	.95	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	1.42	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations VCB New	4	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	8	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	4	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	64	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	64	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	4	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	6	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations VCB New	4	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	3.09	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	3.33	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	2.14	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	2	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	2.14	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	1.42	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations VCB New	4	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	7	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	60	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	3	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	1017	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	1017	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	3	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1100	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	1	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1100	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	9	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	1	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Readings	9 Months Operations OCB New	8	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-12-04 00:00:00.000000000	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments	replaced beckwith control	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124	VAC
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments	counter not working	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	401	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	401	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	2L	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	4291.2	kw
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.894	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments	Muddy from flooding	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/20/2023 7:27	Distribution	Wedonia Substation Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments	Rock and dirt against fence	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	170	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	170	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	51.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	61.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	70.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	39.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	31.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	31.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	152	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	152	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	214	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	13	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations VCB New	13	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	25.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	30.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	214	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	40.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	172	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	172	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	58.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	45.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	53.0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	347	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	207220	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	207220	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	4930.56	kw
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.5136	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 13:53	Distribution	Elizabethtown 5 Substation Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	74	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	85	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	271	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	291	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	10195	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	10R	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	128254	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	125498	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2069.28	kw
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8622	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 12:56	Distribution	Bonnieville Substation Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	9	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	20.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	21.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	22.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	45	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	45	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	242	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	242	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	20.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	21.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	22.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	31	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.1152	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	12	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	34	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	9	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2073.60	kw
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	11	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	362.88	kw
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4536	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	27	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AF	197	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AL	197	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A Ø	85.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B Ø	84.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C Ø	82.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	192	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	192	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	1R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	94.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	90.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	90.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	111	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	111	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	73.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	72.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	133	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	133	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	75.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	88.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	90.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	85	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	85	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	94.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	106	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	106	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	90.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	88.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	87.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	195	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	195	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	566.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	558.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	560.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	76	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	76	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	62	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	62	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	56	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	56	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	153	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	153	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	161	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	161	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	54	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	54	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	63	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	63	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	54	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	54	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	109	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	109	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	80	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	80	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	123.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	118.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	127.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	151	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	151	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	213	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	213	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	48	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	10	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	173	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	173	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	149	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	149	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	70	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	70	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	162	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	162	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	12	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	38	°C
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	92	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	92	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:40	Distribution	Pocket Substation Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	223	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	233	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	84	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	84	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	91	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	91	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	559.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	553.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	547.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	4	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	4	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	46.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	104	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	104	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	46.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	44.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	94	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	94	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	102	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	102	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	136.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	140.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	140.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	117.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	102	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	102	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	114.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	116.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	106.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	104.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	106.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	154	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	133.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	124.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	132.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	196	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	196	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	126	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	126	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	130.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	131.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	134.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	150	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	150	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AL	70	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AF	70	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	130	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	130	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	176	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	176	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	76	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	76	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	180	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	180	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	182	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	182	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	179	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	179	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	107	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	107	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	49.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	436.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	433.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	200	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	200	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	47.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	44.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	43.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations VCB New	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	111.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	111.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	111.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	187	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	187	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	96	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	96	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps A Ø	53.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps B Ø	53.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	53.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	67.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	68.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	68.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	63.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	310	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	310	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	62.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	68.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations VCB New	8	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	8	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	190	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	190	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	189	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	189	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	68.05	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	68.05	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	68.05	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	225	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	225	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	156	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	156	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	105	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	105	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	70.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	83.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	93.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	209	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	209	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	70.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	72.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	75.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	103	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	103	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	117	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	117	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C Ø	66.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B Ø	66.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A Ø	69.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	77.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	77.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	82.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations VCB New	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	3	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	311	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	311	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	2	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	86.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	83.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	83.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	115	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	115	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	72.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	73.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	77.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Switching Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AL	188	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AF	188	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	101	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	101	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	83.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	85.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	87.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	69.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	69.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	72.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	127	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	127	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	77	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	77	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	165	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	165	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	438.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	443.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	173	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	447.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	173	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	1	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	98	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	98	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	53	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	53	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	62	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	62	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	48	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	48	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	66	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	66	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments	needs nitro	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	LTC Output Voltage Level	115.8	VAC
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	41250	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	41350	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	2L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	3R	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	525	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	50	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	49	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	LTC Output Voltage Level	115.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	32257	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	32257	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	1L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	657	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	51	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	23	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	52	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	23	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	52	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	23	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	920	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.9	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	LTC Output Voltage Level	115.4	VAC
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	387	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	28405	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	28405	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	66	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	66	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	66	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	61	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	LTC Output Voltage Level	115.6	VAC
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	30679	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	261	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	30679	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	381	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	381	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	2	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations VCB New	2	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	115.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	104.0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	108.0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	53	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	53	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	53	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	34	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	51	°C
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	79.0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	50.0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	72.0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations VCB New	3	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	3	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	287	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	287	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	610	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	30933	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	30933	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments	no nitrogen gauge	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments	no winding temp gauge	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	4836.00	kw
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	1.0075	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.7	VDC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Negative DC Ground	1.9	VDC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Positive DC Ground	51.4	VDC
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	60	°F
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
12/19/2023 12:20	Distribution	Waterside West Substation Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments	wooden fence is touching	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	33	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:40	Distribution	Munfordville Substation Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	21.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	0.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	14.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	182	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	182	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	360.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	360.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	360.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	287	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	287	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	273	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	273	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	730.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	762.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	740.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	213	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	213	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	480.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	480.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	320.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99947	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99947	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	276	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	276	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	438.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	418.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	420.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations VCB New	2	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	2	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	256	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	256	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	309.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	314.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	303.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	180.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	250.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	250.0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	99957	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	99957	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	795	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	41.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	42.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	45.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	1976	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	10L	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	14R	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	2R	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	147786	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	147790	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	67	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	8	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	72	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments	no nitrogen on LTC	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	65	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.8	volts
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4844	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	75	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.8814	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	70	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	65	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	75	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	15865.20	kw
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	660	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	9R	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	62009	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	62009	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21043	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	All Connections OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments	no temp gauge and does not have nitrogen	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8228	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	13910.40	kw
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.7728	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	70	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1069.20	kw
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	51	°C
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8910	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.9	VDC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.1	VDC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 10:57	Distribution	St Charles ODP Substation Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 11:02	Distribution	Horse Cave Industrial Substation Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000022	LTCControl	LN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	265175	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	265175	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	675	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.30	MegaWatts
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps A Ø	184.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps B Ø	194.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps C Ø	170.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations A Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations B Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	9 Month Operations VCB New	2	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	9 Month Operations	2	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AF	192	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AL	192	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations This Read Vac	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Switching Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Unknown Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations C Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations Ground	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps A Ø	69.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	9 Month Operations VCB New	3	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	9 Month Operations	3	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps B Ø	45.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps C Ø	54.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations A Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations B Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations C Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations Ground	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Maintenance Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AF	174	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AL	174	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations This Read Vac	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Switching Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Unknown Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Month Ops New	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	90.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	100.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	95.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	6	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	6	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	506	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	506	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	4	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	4	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	50.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	100.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	60.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	4	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Month Ops New	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	101.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	115.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	134.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	49	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	378	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	378	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Month Ops New	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	90.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	95.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	90.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Month Ops New	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	80.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	105.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	90.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	520	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	520	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	LTCC000282	LTCControl	LN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	185	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	185	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	64.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	47.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	37.0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.40	MegaVars
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	165.00	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.80	MegaWatts
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.45	MegaVars
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	1	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	186	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	186	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	132.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	133.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	139.0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	9895	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	265	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	9895	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	710	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	140392	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	140392	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments	no nitrogen or temperature gauge on LTC	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
12/19/2023 10:18	Distribution	Lynn Substation Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	771	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	3R	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	2L	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	40337	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	40337	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 10:18	Distribution	Lynn Substation Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.6740	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	6470.40	kw
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Max	60	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments	no LTC temperature gauge	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.5988	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	5748.48	kw
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.6	VDC
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments	SPR system has been removed	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/19/2023 10:16	Distribution	Horse Cave Substation Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LTCC000340	LTCControl	VE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	433864	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	433864	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	419	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	65	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	30	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	30	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	65	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	230.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments	no targets	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	3	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Month Ops New	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	3	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	70.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	479	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	479	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	70.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	3	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	70.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	10	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Month Ops New	10	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	474	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	474	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	20.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	20.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	20.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Month Ops New	5	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	5	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	80.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	80.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	80.0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	423	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	423	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 9:11	Distribution	Vermont Substation Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	1	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations VCB New	1	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	67.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	54.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	272	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	272	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	88.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	396	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	396	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	6	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations VCB New	6	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	221	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	221	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	145.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	208.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	298.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	1	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	217	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	217	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	1	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	85.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	137.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	125.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	1	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations This Read Vac	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AL	176	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AF	176	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations Ground	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations A Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps C Ø	92.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps B Ø	100.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps A Ø	94.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations VCB New	3	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations	3	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	197	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	197	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	142.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	115.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	140.0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations VCB New	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	0	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	All Connections OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	174	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	8L	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	3L	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	6L	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	76949	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	76949	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.6798	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Present	35	°C
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	35	°C
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	6526.08	kw
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	All Connections OK?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Operation Checked?	y	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	42878	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	42878	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	4L	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	8L	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	206	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.7602	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	40	°C
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	40	°C
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	7297.92	kw
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/19/2023 7:27	Distribution	Kenton Substation Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	214931	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	210616	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	83273	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9900	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1584.00	kw
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments	oil seep at DETC	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	53.0	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments	BFTC	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	64	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 15:14	Distribution	Exeter Substation Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	529.20	kw
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3230	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	304621	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments	bad counter anddrag hands	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79893	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	177848	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps A Ø	35.0	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Operations Counter	467	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps C Ø	49.0	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps B Ø	42.0	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments	yard light not working. W/O made to replace with LED	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 14:42	Distribution	Keokee Substation Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Operations Counter	80	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	General Comments	recloser open and disconnects are open	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments	grounds cut on gates going up the barbed wire on top of the gates.	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 14:14	Distribution	Calvin Substation Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	1	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	1	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	20.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	40.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	425	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	425	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	1	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	20.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	20.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	30.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	20.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	40.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	7	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	7	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	7	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	66.82	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	66.82	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	66.82	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	100.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	180.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	21	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	498	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	498	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	21	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	6	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	6	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	433	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	433	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	50.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments	A and B phase IOC	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	28.64	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	28.64	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	3	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	3	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	552	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	150.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	180.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	190.0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	552	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000180	LTCControl	WE-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	35922	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	35922	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	784	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Touched-Up	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	4.50	MegaWatts
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.30	MegaVars
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.80	MegaVars
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	LTCC000181	LTCControl	WE-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	253786	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	253786	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.25	MegaVars
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.30	MegaWatts
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
12/18/2023 12:24	Distribution	Western Substation Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/18/2023 12:24	Distribution	Western Substation Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 12:24	Distribution	Western Substation Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 12:24	Distribution	Western Substation Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:24	Distribution	Western Substation Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:24	Distribution	Western Substation Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:24	Distribution	Western Substation Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	121	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	121	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	1	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	1	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments	Open	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	3	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	2	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	426	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	426	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Month Ops New	3	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	3	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	242	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	242	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	536	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	536	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments	DNO	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	11	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Month Ops New	7	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	4	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	245	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	245	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments	A and B phase IOC, B phase TOC	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	2	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	2	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	300.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	300.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	86	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	86	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Month Ops New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	300.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Heater will not come on.	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	86971	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1257	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	86971	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	63	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	63	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	18	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	18	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments	50.65 voltage after 1 minute trip	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AL	251	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AF	251	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps C Ø	32.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps B Ø	31.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps A Ø	32.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	9 Month Operations VCB New	3	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	9 Month Operations	3	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	LTC Output Voltage Level	116.6	VAC
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000954	LTCControl	SW-B TRANS 1	LTC Control Insp	All Connections OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC As Found Counter	13567	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC As Left Counter	13567	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	657	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	74	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	73	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	74	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Max	64	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Present	23	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1389	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Found Counter	9095	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Left Counter	9095	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BCH001600	Charger	SW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.5	amps
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	9 Month Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Amps A Ø	110.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Amps B Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Amps C Ø	120.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Operations Counter AL	254	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Readings	Operations Counter AF	254	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Operations Counter AL	179	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Operations Counter AF	179	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Amps C Ø	40.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Amps B Ø	40.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Amps A Ø	50.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Readings	9 Month Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Operations Counter AL	177	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Operations Counter AF	177	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Amps C Ø	80.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Amps B Ø	100.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Amps A Ø	90.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Readings	9 Month Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Amps A Ø	80.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Amps B Ø	120.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Amps C Ø	110.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Operations Counter AF	258	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Operations Counter AL	258	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Operations Counter AF	225	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Operations Counter AL	225	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Switching Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Unknown Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Amps C Ø	290.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Amps B Ø	300.0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Amps A Ø	260.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations VCB New	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	74.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	229	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	229	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	45.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	55.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments	A,B, AND C PHASE IOC	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	156	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	156	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	3	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	118.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	125.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	159.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	3	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations VCB New	5	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	5	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	101.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	118.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	204.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	174	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	174	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	261.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	256.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	245.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	127	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	127	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments	dno	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	156	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	156	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	161	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	668.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	531.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	564.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	161	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	51247	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	51247	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	858	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	42	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	10	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	47	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	19	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	47	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	19	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	371	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	371	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	290.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	296.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	297.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	37	°F
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	87	psi
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	357	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	357	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	67.08	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	6	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	67.08	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	6	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	157.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	161.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	106.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	6	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	57	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	9 Month Operations GCB New	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	57	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	300.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	300.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	313.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	199	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	199	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	5	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations VCB New	5	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	53.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	54.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	50.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations VCB New	12	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	13	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	481	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	481	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	1	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	167.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	163.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	162.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	187	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	187	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	186.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	164.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	195.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	416	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	416	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations VCB New	3	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	3	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	1	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	81.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	98.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	8.15	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	1	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	271	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	271	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	1	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	73.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments	DNO	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	372	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	372	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	1	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	231	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	231	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	594.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	648.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	645.0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	525.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	545.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	518.0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	156	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	156	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	22	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	1.0900	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	22	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	15696.00	kw
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	1589	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	52864	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	52860	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	108401	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	108401	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1565	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	25	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	45	°C
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	All Connections OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.3	VDC
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.4	VDC
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.3	VDC
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments	signs need updating	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 11:52	Distribution	Black Branch Road Substation Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.4	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.4	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.0	VDC
12/18/2023 11:58	Distribution	Worthington Substation Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C Ø	73.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B Ø	47.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A Ø	71.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	245	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	245	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations	10	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations VCB New	8	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps A Ø	62.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps B Ø	71.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps C Ø	80.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Maintenance Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AF	188	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AL	188	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations This Read Vac	2	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Unknown Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Switching Operations	2	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations A Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps C Ø	158.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps B Ø	164.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps A Ø	123.0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations VCB New	2	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations	2	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations B Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations C Ø	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations Ground	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Switching Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations This Read Vac	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AL	187	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AF	187	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Maintenance Operations	0	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	General Comments	Reset Beckwith	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	All Connections OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	16826	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	300	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	4L	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	16826	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	1L	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.7968	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	50	°C
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	40	°C
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	7649.28	kw
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 11:32	Distribution	Sharon Substation Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments	signs need updating	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.6	VDC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	173.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	142.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	128.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	30	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	30	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	320.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	3	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations VCB New	3	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	316.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	337.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	287	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	287	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	112.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	92.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	86.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	322	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	322	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	6.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	1.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	1.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	917	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	917	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	2	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	69.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	43.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	71.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	6	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	6	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AF	152	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AL	152	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps C Ø	223.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps B Ø	230.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps A Ø	233.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	205	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	205	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	93.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	99.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	96.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	620.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	580.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	500.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	67	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	330.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	325.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	325.0	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	67	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	127638	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	2L	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	7R	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	7L	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	530	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	127634	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	40	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	70	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.7626	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	40	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	40	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	13726.80	kw
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	18199	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	18195	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	368	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	30	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	45	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.4452	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	8013.60	kw
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.3	amps
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments	SPR system is gone	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 10:58	Distribution	Elizabethtown 2 Substation Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	117.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	110.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	88.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	181	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	181	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	173	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	173	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	12.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	38.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	44.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	130.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	125.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	140.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	237	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	237	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	58.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	74.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	55.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	291	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	291	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations B Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations C Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations Ground	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Maintenance Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations Counter AF	158	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations A Ø	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps C Ø	310.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps B Ø	386.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps A Ø	337.0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations Counter AL	158	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations This Read Vac	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Switching Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Unknown Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	9 Month Operations VCB New	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	9 Month Operations	0	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	90296	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	90292	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	6L	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	301	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	All Connections OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	25	°C
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.5300	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	9540.00	kw
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.5	VDC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	°F
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.5	VDC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 10:10	Distribution	Rogersville City Substation Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002091	BreakerVacuum	SW-1184	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002092	BreakerVacuum	SW-1185	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002093	BreakerVacuum	SW-1186	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002094	BreakerVacuum	SW-1187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	General Comments		
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2023 12:17	Distribution	Stewart Substation Inspection	BK002090	BreakerVacuum	SW-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-04-12 00:00:00.000000	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/15/2023 13:56	Distribution	Bardstown Industrial Customer Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	362.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	358.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	356.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	216	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	216	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations VCB New	1	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	1	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	1017	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	6L	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	84470	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	84470	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	10017.00	kw
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.5565	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	45	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	40	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	1	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations VCB New	1	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	320.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	320.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	320.0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	174	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	174	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	172253	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	172253	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	571	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	30	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.4619	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	8314.20	kw
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 13:49	Distribution	Bardstown Industrial Substation Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	3	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations VCB New	3	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps A Ø	219.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps B Ø	227.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps C Ø	215.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations A Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations B Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations C Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations Ground	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Unknown Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Switching Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations This Read Vac	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AL	222	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AF	222	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Maintenance Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations	7	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations VCB New	7	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps A Ø	121.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps B Ø	134.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C Ø	135.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	203	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	203	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps C Ø	351.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps B Ø	363.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps A Ø	343.0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Unknown Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Switching Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations This Read Vac	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AL	151	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AF	151	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Maintenance Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations A Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations B Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations C Ø	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations Ground	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	All Connections OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Operations Since Last Insp	451	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Left Counter	13366	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Found Counter	13366	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	LTC Totalizer Reading	7416.00	kw
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Reading	.5150	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Present	20	°C
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	96	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	96	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Unknown Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Readings	9 Month Operations GCB New	0	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	48	°F
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure	68	psi
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.3	VDC
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.3	VDC
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.2	VDC
12/15/2023 13:05	Distribution	Barton Substation Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 13:05	Distribution	Barton Substation Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	185	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	185	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	259.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	247.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	248.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations VCB New	6	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	6	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	62.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	1	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	185	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	185	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	1	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	1	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	64.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	57.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	279.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	279.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	299.0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	62110	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	62110	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	9L	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	5L	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	660	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.7092	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	6808.32	kw
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	25	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	45	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	20	°C
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.8	VDC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments	positive posts are corroded, bolts are corroded too. cleaned best I could	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 10:32	Distribution	Elizabethtown 3 Substation Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	3L	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	8319	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	8319	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	583	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	120.6	VAC
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	LTC Totalizer Reading	168.00	kw
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Reading	.0420	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments	gauge still leaking	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1325	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1325	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	120.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	140.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Month Ops New	4	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	4	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	120.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	869	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	869	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	120.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	140.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	120.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	585	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	585	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:37	Distribution	Gates Rubber Substation Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	64.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	114.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	92.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	6	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Month Ops New	6	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	219	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	219	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	530	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	530	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	92.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	114.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	64.0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	94580	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	94580	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	457	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	20	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	388	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	94525	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	94525	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/15/2023 9:36	Distribution	Shepherdsville Substation Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	6299	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	6299	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	583	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	110.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	120.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	50.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	140.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	130.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	170.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Month Ops New	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations This Read Vac	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	169	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	1	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	169	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations VCB New	1	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	68.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	61.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	67.0	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 9:19	Distribution	Southern Baptist Seminary Substation Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations This Read Vac	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	162	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	162	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	38.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	37.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	40.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	96.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	78.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	97.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	180	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	180	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations VCB New	4	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	4	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	336.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	329.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	337.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	180	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	180	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	480.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	480.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	480.0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	226	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	226	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Operations Since Last Insp	513	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Max Tap Position	6L	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Left Counter	26173	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Found Counter	26173	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	11484.00	kw
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.6380	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	65	°C
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	65	°C
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 9:15	Distribution	Elizabethtown West Substation Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Unknown Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Switching Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations This Read Vac	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	9 Month Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps C Ø	130.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps B Ø	130.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps A Ø	130.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AL	178	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AF	178	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations A Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations B Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations C Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations Ground	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Maintenance Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Unknown Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Switching Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations This Read Vac	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AL	171	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AF	171	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Maintenance Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations Ground	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations B Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations A Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps C Ø	6.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps B Ø	9.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps A Ø	5.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	9 Month Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	9 Month Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Maintenance Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps A Ø	90.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps B Ø	85.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps C Ø	100.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations A Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations B Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations C Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations Ground	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Unknown Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Switching Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations This Read Vac	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations Counter AL	177	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations Counter AF	177	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	9 Month Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Unknown Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Switching Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps A Ø	255.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps B Ø	150.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps C Ø	175.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations A Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations B Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations C Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations Ground	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations This Read Vac	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AL	173	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AF	173	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Maintenance Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Unknown Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Switching Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations This Read Vac	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations Counter AL	193	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations Counter AF	193	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Maintenance Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations Ground	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations C Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations B Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations A Ø	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	9 Month Operations	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps A Ø	210.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps B Ø	75.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps C Ø	110.0	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15938	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	16L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	20800	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26536	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2864.64	kw
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8952	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	5L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	208	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	4R	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	4L	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	9001	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	9001	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.7488	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	20	°C
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	45	°C
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	7188.48	kw
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
12/15/2023 7:30	Distribution	Cynthiana Substation Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/19/2023 9:11	Distribution	Vermont Substation Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/19/2023 9:11	Distribution	Vermont Substation Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	221	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	221	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	51.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	59.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	42.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	1	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations VCB New	1	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	231	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	231	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	47.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	69.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	63.0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16660	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32860	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30623	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5030.40	kw
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5240	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	57	°F
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.5	VDC
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	16.0	VDC
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments	no fuses in sub	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 14:20	Distribution	Rineyville Substation Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	491	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	491	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	130.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	130.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	160.0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	498	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	498	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	352	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	352	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Readings	9 Months Operations OCB New	0	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-03-27 00:00:00.000000	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	14850	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	14850	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	374	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 13:10	Distribution	Butler Substation Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.8262	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3965.76	kw
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	70	°C
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/14/2023 13:10	Distribution	Butler Substation Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.0	VDC
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 13:10	Distribution	Butler Substation Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 13:10	Distribution	Butler Substation Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Unknown Operations	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Switching Operations	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations This Read Vac	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AL	180	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AF	180	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Maintenance Operations	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations Ground	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations C Ø	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations B Ø	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations A Ø	0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps C Ø	300.0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps B Ø	390.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps A Ø	310.0	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	9 Month Operations VCB New	2	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	9 Month Operations	2	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24912	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29811	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27271	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8096.00	kw
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.5300	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 13:05	Distribution	Falmouth Substation Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	291	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	291	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	120.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	100.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	100.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	247	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	247	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	60.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	10.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	10.0	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	332	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	80202	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	80202	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	50	°C
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	3369.60	kw
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.3510	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 12:59	Distribution	Cynthiana South Substation Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Maintenance Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AF	187	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AL	187	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Switching Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Unknown Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps C Ø	6.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps B Ø	8.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps A Ø	7.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	9 Month Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	180.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	120.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	100.0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations VCB New	1	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	1	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	279	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	279	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	135	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	3L	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	11L	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	24856	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	24856	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	3373.92	kw
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.4686	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 12:53	Distribution	Kawneer Substation Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps A Ø	35.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps B Ø	79.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Maintenance Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps C Ø	54.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AF	167	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AL	167	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Switching Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Unknown Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps C Phase V	5.46	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations B Ø	1	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations C Ø	1	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations This Read Vac	2	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AL	187	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AF	187	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Maintenance Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Switching Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Unknown Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	9 Month Operations	2	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps A Ø	77.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps B Ø	82.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps C Ø	71.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps B Phase V	5.46	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps C Ø	133.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps B Ø	111.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps A Ø	118.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Unknown Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Switching Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Maintenance Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AF	178	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AL	178	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations A Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps C Ø	256.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps B Ø	282.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps A Ø	222.0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations B Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Unknown Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Switching Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations This Read Vac	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations Counter AL	162	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations Counter AF	162	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations C Ø	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations Ground	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Maintenance Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	9 Month Operations	0	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	739	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	263674	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	263674	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	6534.00	kw
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.3630	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	°F
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 12:10	Distribution	Radcliff Substation Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409613	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409613	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	555	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	428539	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	428553	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	transformer still leaking from temp gauges. known problem with transformer	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	316	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	316	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	1	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations VCB New	1	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	130.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	90.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	100.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	304	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	304	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	15.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	10.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	10.0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations VCB New	3	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	3	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	237167	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	237167	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	200	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	200.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	572	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	572	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	200.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	200.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.9216	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	4423.68	kw
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	50.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	50.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	50.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	150.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	150.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	393	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	393	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	150.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	399	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	399	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	200.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	180.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	200.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.8	VDC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	43	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 10:54	Distribution	Radcliff South Substation Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	240.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	180.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	250.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	249	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	249	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2050	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2050	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations VCB New	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	170.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	160.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	130.0	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	All Connections OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000479	LTCControl	SE-TRANS 2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	229815	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	229815	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	428	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	All Connections OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	420	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	261089	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	261089	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	.9816	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	3141.12	kw
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	48	°C
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	1.00	MegaWatts
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.80	MegaWatts
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.6	VDC
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LTCC000478	LTCControl	SE-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:01	Distribution	Vine Grove Substation Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	402	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	325327	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	325327	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.00	MegaWatts
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Month Ops New	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Month Ops New	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18563	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18563	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Month Ops New	2	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	2	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	347	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	347	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	80.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	120.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	220.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	451	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	451	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Month Ops New	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	160.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	140.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	130.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	317	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	110.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	80.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	140.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	1	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Month Ops New	1	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	437	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	1	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Month Ops New	1	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	130.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	437	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	110.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	140.0	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	9 Month Operations	4	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	9 Month Operations VCB New	3	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations A Ø	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations B Ø	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations Counter AF	95	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations Counter AL	95	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations This Read Vac	2	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps A Ø	195.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps B Ø	194.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps C Ø	192.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations A Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations B Ø	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	General Comments	B PHASE TOC	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations Counter AF	98	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations Counter AL	98	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations This Read Vac	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations B Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations A Ø	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps C Ø	11.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps B Ø	11.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps A Ø	11.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	9 Month Operations VCB New	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	9 Month Operations	2	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations Counter AF	77	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations Counter AL	77	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations This Read Vac	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	9 Month Operations	9	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	9 Month Operations VCB New	7	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps A Ø	79.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps B Ø	76.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps C Ø	74.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.1	VDC
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
12/14/2023 8:08	Distribution	South Park Substation Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	785	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	785	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	13	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations VCB New	12	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	20.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	30.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	40.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	301.67	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	28	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	290.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	5	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	19	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	51	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	19	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	53	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	236517	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	236517	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	605	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Month Ops New	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	152	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	152	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	0.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	550.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	490.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments	A phase amp meter isn't working	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	24	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	127	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	127	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Month Ops New	20	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	4	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	4	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	70.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	100.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	90.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2488	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2488	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	150.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	150.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	180.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Month Ops New	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	456	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	185.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	205.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	160.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	9	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Month Ops New	8	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	456	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	241	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	241	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Month Ops New	1	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	10.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	80.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	40.0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	ok	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 8:08	Distribution	South Park Substation Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	399	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations VCB New	3	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	3	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	0.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	0.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	0.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	399	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations VCB New	2	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	2	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	201	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	201	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	12.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	20.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	5.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	2	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations VCB New	2	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	140.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	135.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	110.0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	306	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	306	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	21868	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	23381	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	26700	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1234.56	kw
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3858	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2023 7:09	Distribution	Winchester Substation Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2023 10:04	Distribution	Seventh Street Substation Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Month Ops New	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	4.27	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	4.27	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.2	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Month Ops New	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	10.67	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	9.61	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	1	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Month Ops New	1	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	7.47	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	16.01	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	17.08	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	4.27	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Month Ops New	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Month Ops New	0	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
12/14/2023 11:02	Distribution	Shawnee Substation Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	290.0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	280.0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	280.0	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	137894	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	137894	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	628	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	7L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	2L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	12L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	All Connections OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Current Tap Position	7L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Max Tap Position	2L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Min Tap Position	12L	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Bandwidth AL	123.0	VAC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Base Voltage AL	123.0	VAC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Counter AF	137894	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Counter AL	137894	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	6732.00	kw
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	45	°C
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	25	°C
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.3740	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	25	°C
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	50	°C
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.6	VDC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments	No SPCC spill kit	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-04-24 00:00:00.000000	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 16:13	Distribution	Bardstown City Substation Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 16:18	Distribution	Bardstown City Customer Substation Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2059	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	58.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	47.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	55	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	33002	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	33006	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	3L	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	381	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.6000	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	5760.00	kw
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 15:13	Distribution	Woodlawn Substation Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Unknown Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Switching Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AL	179	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AF	179	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations	2	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps A Ø	60.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps B Ø	35.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps C Ø	35.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations A Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations B Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations C Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations Ground	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Maintenance Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	55.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	75.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	50.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	364	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	364	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	2	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	382	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	382	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	205.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	235.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	230.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	234	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	234	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	330.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	330.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	285.0	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	All Connections OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	122785	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	122785	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	425	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	9087.84	kw
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.6311	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 13:03	Distribution	Parker Seal Substation Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	2	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	155.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	120.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	170.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	209	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	209	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	195	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	195	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	15.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	12.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	15.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations VCB New	6	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	6	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	69	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	69	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	320.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	320.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	350.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	234	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	234	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	205.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	210.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	165.0	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations VCB New	6	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	6	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	66811	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	66811	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	5L	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	2L	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	12L	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	703	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	All Connections OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	10632.96	kw
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Present	30	°C
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	70	°C
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	1.1076	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	50	°C
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 12:48	Distribution	Sylvania Substation Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	215	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	215	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	100.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	135.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	130.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations VCB New	4	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	4	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	3	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations VCB New	3	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	75.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	60.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	75.0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	347	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	347	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	348	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	16L	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	231911	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	231911	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.6558	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	2098.56	kw
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.9	VDC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/13/2023 12:41	Distribution	Winchester South Substation Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	9 Month Operations	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps A Ø	205.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps B Ø	195.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps C Ø	215.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Unknown Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Switching Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations Counter AL	142	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations Counter AF	142	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Maintenance Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Unknown Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Switching Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations Counter AL	263	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations Counter AF	263	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Maintenance Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	9 Month Operations	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps C Ø	30.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps B Ø	15.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps A Ø	30.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps B Ø	100.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps A Ø	155.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	9 Month Operations VCB New	6	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	9 Month Operations	6	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations Counter AL	427	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Unknown Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Switching Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps C Ø	155.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations Counter AF	427	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Maintenance Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps C Ø	35.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	50.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	35.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	171	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	171	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations VCB New	3	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	3	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps A Ø	420.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps B Ø	370.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps C Ø	425.0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Maintenance Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AF	204	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AL	204	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Switching Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Unknown Operations	0	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	582	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	20814	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	20814	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	14788.80	kw
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	1.0270	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	50	°C
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.3	VDC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 12:36	Distribution	Boone Avenue Substation Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	40.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	40.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	30.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	2	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	328	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	328	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	2	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	318	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	318	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	150.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	150.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	150.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	60.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	75.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	55.0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	284	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	284	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations VCB New	4	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	4	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	44982	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2523	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51452	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8770	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8419.20	kw
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 12:27	Distribution	Winchester Water Substation Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	General Comments	Can not check Bat Volt. 1 min	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Negative DC Ground	9.1	VDC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Positive DC Ground	8.5	VDC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	55.8	VDC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	7L	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	177	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	1L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	1L	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	1676	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	1667	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	82.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	89.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	84.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	9 Month Operations GCB New	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	111	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	111	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	824	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	824	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	36.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	34.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	33.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	9 Month Operations GCB New	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1469	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1469	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	9 Month Operations GCB New	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	396.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	400.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	398.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
12/15/2023 8:54	Distribution	Shively Substation Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	270	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	91984	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	91984	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments	ok	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	21	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	49	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	49	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	22	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	49	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	22	°C
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	49	°C
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	61	°C
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	248	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	6269	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	6269	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	62	°C
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	373	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	8L	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	4L	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	7483	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	7471	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	9 Month Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps A Ø	277.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps B Ø	273.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps C Ø	269.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations Counter AL	87	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations Counter AF	87	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations This Read Vac	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations Counter AL	81	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations Counter AF	81	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	9 Month Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps A Ø	0.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps B Ø	0.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations A Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations B Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps C Ø	0.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Follow-up Action Required?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	General Comments	PRIMARY RELAY IS NOT DISPLAYING ANYTHING ON SEL RELAY	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	9 Month Operations	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	9 Month Operations VCB New	1	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps A Ø	15.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps B Ø	16.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps C Ø	15.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations A Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations B Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations C Ø	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations Ground	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations Counter AF	74	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations Counter AL	74	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations This Read Vac	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	9 Month Operations GCB New	2	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	100.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	99.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	105.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	2	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	671	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	671	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	86.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	86.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	78.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	460	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	460	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	4	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	9 Month Operations GCB New	4	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	SF6 Pressure	0	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Ambient Temperature	37	°F
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	9 Month Operations GCB New	5	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	117.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	102.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	104.0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	5	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	782	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	782	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	SF6 Pressure	0	psi
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Ambient Temperature	37	°F
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Foundation Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Grounds in Place?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2023 8:54	Distribution	Shively Substation Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.4674	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	35	°C
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	4487.04	kw
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	190	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	190	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments	Bkr is offline	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	2	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	2	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	220	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	220	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	9.88	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	9.88	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	9.88	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	204.0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	192.0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	180.0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	2	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments	ok	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 10:56	Distribution	Green River Steel Substation Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Amps B Ø	180.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Amps C Ø	200.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Amps A Ø	190.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Operations Counter AL	133	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Operations Counter AF	133	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	General Comments	This is the correct VC. VC may count backwards or wrong count was entered last time.	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Operations Counter AL	134	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Operations Counter AF	134	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Amps C Ø	500.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Amps B Ø	450.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Readings	Amps A Ø	450.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Operations Counter AF	111	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Operations Counter AL	111	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Amps C Ø	30.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Amps B Ø	50.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Amps A Ø	40.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Amps C Ø	80.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Amps B Ø	80.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Amps A Ø	70.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Operations Counter AF	166	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Operations Counter AL	166	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Operations This Read Vac	6	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Operations Counter AL	232	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Operations Counter AF	232	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	9 Month Operations	6	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Amps A Ø	90.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Amps B Ø	70.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Amps C Ø	60.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Operations A Ø	2	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Operations B Ø	2	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Operations C Ø	2	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Readings	General Comments	A, B, and C phase IOC	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Amps A Ø	140.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Amps B Ø	125.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Amps C Ø	110.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Operations Counter AF	272	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Readings	Operations Counter AL	272	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations Counter AL	114	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations Counter AF	114	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	General Comments	DNO	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations Counter AL	115	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations Counter AF	115	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	General Comments	DNO	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	68	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Found Counter	8020	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Left Counter	8020	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	42	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	20	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Max	32	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Present	18	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	15	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	1	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	170	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	170	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	3	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	3	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps A Ø	55.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps B Ø	58.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps C Ø	63.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AF	114	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AL	114	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps C Ø	171.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps B Ø	144.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps A Ø	148.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AF	109	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AL	109	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	General Comments	DNO	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AF	176	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AL	176	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps A Ø	195.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps B Ø	197.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps C Ø	219.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AL	290	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AF	290	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	30649	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	30649	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	312	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	12	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	21	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	1	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	10	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	this is gone. remove from inspection	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	All Connections OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments	The road into the sub is full of pot holes	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002085	BreakerVacuum	PL-1270	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002086	BreakerVacuum	PL-1271	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002087	BreakerVacuum	PL-1272	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002088	BreakerVacuum	PL-1273	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002089	BreakerVacuum	PL-1274	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	General Comments		
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 9:46	Distribution	Pleasure Ridge Substation Inspection	BK002095	BreakerVacuum	PL-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	997	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	521113	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	421113	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	18863	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	18863	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1217	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	30.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	30.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	30.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	42	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	42	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	363	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Month Ops New	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	4	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	90.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	90.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	90.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	19.09	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	363	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	4	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	2	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	2	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99857	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99857	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	80.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	80.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	80.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99967	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99967	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	50.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	50.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	50.0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Month Ops New	0	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 23:55	Distribution	Pirtle Substation Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Operations Counter	404	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Unknown Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Switching Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations This Read Vac	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AL	189	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AF	189	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Maintenance Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	9 Month Operations	1	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps A Ø	220.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps B Ø	255.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps C Ø	230.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations A Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations C Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Unknown Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Switching Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations This Read Vac	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AL	176	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AF	176	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Maintenance Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations C Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations A Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps C Ø	55.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps B Ø	70.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps A Ø	70.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations	1	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations This Read Vac	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AL	180	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AF	180	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Maintenance Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations A Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps C Ø	185.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps B Ø	200.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps A Ø	185.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	148	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	148	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	465.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	515.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	480.0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Found Counter	64683	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Left Counter	64683	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Current Tap Position	4L	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Min Tap Position	10L	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Operations Since Last Insp	714	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Present	50	°C
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Max	75	°C
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Reading	.8754	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Present	50	°C
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Max	65	°C
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	LTC Totalizer Reading	15757.20	kw
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 15:06	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	4	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations VCB New	4	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	190.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	200.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	240.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	303	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	303	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	160	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	160	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	480.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	2	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	304	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	304	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	200.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	250.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	210.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps A Ø	70.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps B Ø	75.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps C Ø	80.0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Maintenance Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations Counter AF	195	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations Counter AL	195	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Switching Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Unknown Operations	0	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	9 Month Operations	2	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	652	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	89651	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	89651	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Max	70	°C
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	10872.00	kw
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.7550	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	70	°C
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	40	°C
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 14:57	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations Counter AF	241	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations Counter AL	241	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps C Ø	0.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps B Ø	0.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps A Ø	0.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	9 Month Operations	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations Counter AF	169	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations Counter AL	169	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps C Ø	140.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps B Ø	130.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps A Ø	135.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	9 Month Operations	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations Counter AL	165	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations Counter AF	165	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps B Ø	115.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps A Ø	115.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps C Ø	130.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	9 Month Operations	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AL	177	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AF	177	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	9 Month Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps C Ø	270.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps B Ø	245.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps A Ø	250.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	General Comments	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Ambient Temperature	42	°F
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Pressure	66	psi
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations Counter AF	178	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations Counter AL	178	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	9 Month Operations	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps A Ø	0.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps B Ø	0.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations Counter AF	175	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations Counter AL	175	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	9 Month Operations	3	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	9 Month Operations VCB New	3	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps A Ø	210.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps B Ø	220.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps C Ø	240.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations Counter AL	190	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations Counter AF	190	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	9 Month Operations	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps A Ø	360.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps B Ø	370.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps C Ø	410.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Switching Operations	1	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations This Read Vac	1	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations Counter AL	174	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations Counter AF	174	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps C Ø	685.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps B Ø	640.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps A Ø	640.0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	9 Month Operations	1	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Ambient Temperature	42	°F
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	General Comments	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Unknown Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Switching Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations This Read SF6	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AL	186	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AF	186	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Num Operations Last 9 Months	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Maintenance Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Fault Operations	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	9 Month Operations GCB New	0	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	LTC Totalizer Reading	15000.00	kw
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Present	25	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Max	60	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Reading	.6250	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Present	24	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Max	59	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Operations Since Last Insp	831	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Max Tap Position	6R	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Current Tap Position	1R	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Left Counter	14627	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Found Counter	14627	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	521	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	8R	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	1R	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	140960	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	140960	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	30	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	3669.12	kw
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	15	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	120.00	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	30	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	35	°C
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	.3822	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.5	VDC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 14:49	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	55.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	226	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	30.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	70.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	226	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	190.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	180.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	195.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	218	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	218	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	105.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	110.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	115.0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	252	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	252	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	20208	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	20208	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	800	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	8428.80	kw
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	.8780	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.2	VDC
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 14:31	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps A Ø	316.0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps B Ø	333.0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps C Ø	323.0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Unknown Operations	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations A Ø	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations B Ø	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	9 Month Operations	1	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Switching Operations	1	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations This Read Vac	1	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AL	199	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AF	199	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Maintenance Operations	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	General Comments	counter entered wrong last time	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations Ground	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations C Ø	0	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	681	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	16L	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	5382	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	5382	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.2105	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1263.00	kw
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 14:01	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	67.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	81.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	84.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	191	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	191	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	2	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	3.49	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	25.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	26.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	2	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	198	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	198	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	25.0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	2	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	422162	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	422170	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	1R	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	8R	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1539	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	290.00	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.9900	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	4752.00	kw
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	120.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	120.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	100.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	162	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	162	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	0	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 15:08	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	32	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	109597	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	109604	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	5R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	1103	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	43	°C
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	26	°C
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.4150	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	3984.00	kw
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.936	millivolts
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.1	VDC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	3	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	151.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	156.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	151.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	183	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	183	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	224	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	224	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	37.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	18.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	24.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 13:47	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	70.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	76.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	69.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	236	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	236	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	3	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A Ø	111.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B Ø	78.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C Ø	90.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	183	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	183	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	320.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	320.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	320.0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments	Counter stopped working during overhaul.	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	163	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	163	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	1	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	214185	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	214192	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	6R	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	614	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	32	°C
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	30	°C
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.7930	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Max	32	°C
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	11419.20	kw
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 13:21	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.7	VDC
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33405	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33437	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33197	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	22	°C
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5520	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1987.20	kw
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	6	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations VCB New	6	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	229	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	229	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	45.0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	25.0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	10.0	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments	Bus could use additional wildlife protection.	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments	ok	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	Small waskout left rear corner and back of station.	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 12:52	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	262	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	262	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	1.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	188	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	188	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments	OK	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	202	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	202	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.4	VDC
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments	C IOC	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B Ø	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	99.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	116.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	99.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	4	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	294	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	294	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	345	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	345	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C Ø	113.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B Ø	106.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A Ø	95.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	4	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	78128	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	209.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	228.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	194.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	2	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	199	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	199	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	152283	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Unknown Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Switching Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations This Read Vac	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AL	192	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AF	192	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Maintenance Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps C Ø	109.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps B Ø	108.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps A Ø	103.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	67687	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	67687	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	2R	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	490	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations	1	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps A Ø	29.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps B Ø	58.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps C Ø	39.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Maintenance Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AF	170	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AL	170	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations This Read Vac	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Switching Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Unknown Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	48	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	49	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	49	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	19	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	47	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	19	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	20	°C
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	136.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	156.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	128.0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	341	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	341	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	70324	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	70331	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	830	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	450	psi
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	8887.68	kw
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Max	59	°C
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.9258	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	404	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	83465	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	83465	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.532	millivolts
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.2	VDC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	31421	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	31421	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	619	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	44	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 12:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	114386	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1676.16	kw
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3492	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	65.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	100.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	95.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99961	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99961	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AL	181	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AF	181	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Maintenance Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Switching Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Unknown Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations	7	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations VCB New	7	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps A Ø	111.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps B Ø	127.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps C Ø	121.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments	1 trip check. Bkr is offline.	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	1	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	167	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	167	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	1	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	1	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	4	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	282	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	282	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	4	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	20.78	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	64.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	49.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	51.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	5	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	59.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	40.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	34.0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	304	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	304	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments	ok	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	3R	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	209919	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	209912	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1208	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Replace Next Maint	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments	Gasket is cracking and LTC tank is seaping	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	5552.64	kw
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	58	°C
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	24	°C
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.5784	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments	Bus needs wildlife protection.	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments	Fence fabric on right side of station is held together by aluminum tie wire. Needs to be repaired.	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments	Small washout is developing in front of gate.	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 12:21	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.974	millivolts
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.5	VDC
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 11:40	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	45	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.5	VDC
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	94094	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	89471	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71075	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	273.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	224.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	268.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	427	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	427	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	242	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	242	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	66.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	62.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	95.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	202	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	202	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	204.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	194.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	213.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	156	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	156	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	575.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	484.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	505.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	318488	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	318481	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	4R	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	9R	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	1669	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	46	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.8622	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	40	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	57	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	29	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	12415.68	kw
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6696	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	23	°C
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2142.72	kw
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments	Needs wildlife protection.	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	147	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	147	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	122.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	95.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	115.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	123	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	123	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	87.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	98.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	95.0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	2	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	346	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	346	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	1	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	5.99	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	109.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	35.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	75.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	435	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	435	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	22	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations VCB New	22	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	412.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	394.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	378.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments	C phase SandC insulator has broken skirt. broken skirt center phase of 303. Whole station could use wildlife protection upgrade.	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	262	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	262	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	480.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	410.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	478.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99988	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99988	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	0	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments	ok	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments	Yard light was tested and was found to be inoperable.	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 11:16	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	1613	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	10R	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	4R	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	145374	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	145364	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	All Connections OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/12/2023 11:28	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	65	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	12654.72	kw
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	65	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	35	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.3182	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	35	°C
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.1	amps
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	9 Month Operations	3	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps A Ø	58.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps B Ø	66.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps C Ø	60.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations Counter AF	48	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations Counter AL	48	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations This Read Vac	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations Counter AL	37	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations Counter AF	38	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	9 Month Operations	8	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps A Ø	83.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps B Ø	108.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps C Ø	76.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	General Comments	C IOC	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations C Ø	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps C Ø	171.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps B Ø	191.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps A Ø	120.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations Counter AF	18	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations Counter AL	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps A Ø	261.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps B Ø	353.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps C Ø	299.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations Counter AF	135	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations Counter AL	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations Counter AF	11	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations Counter AL	11	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps C Ø	99.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps B Ø	88.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps A Ø	63.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations Counter AL	28	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations Counter AF	28	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps C Ø	97.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps B Ø	86.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps A Ø	83.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	9 Month Operations	6	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Unknown Operations	2	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations This Read Vac	2	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations Counter AL	99980	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations Counter AF	99980	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps C Ø	184.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps B Ø	228.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps A Ø	209.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	9 Month Operations	7	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps A Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps B Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps C Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations Counter AL	16	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations Counter AF	16	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	13	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	13	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Unknown Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Switching Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations Counter AL	39	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	9 Month Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps A Ø	355.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps B Ø	403.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps C Ø	375.0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations Counter AF	39	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	1	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	139	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	139	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	19	°C
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments	Fence panel needs repair from vandalism.	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	134.6	VDC
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Negative DC Ground	70.1	VDC
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.0	VDC
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.0	VDC
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments	ok	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 10:06	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	19	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	46.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	116	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	116	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	23.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	39.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	11.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	11.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	11.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	59	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	19	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	62	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	62	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	63	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	464	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	19192	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	19192	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	3248	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	3248	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	518	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	38	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	24	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	100	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	10	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	10	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	100	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	199.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	207.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	218.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	10	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	106	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	106	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	10	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	10.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	169.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	161.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	204.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	101	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	101	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	8.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	36.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	8	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	73	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	73	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	38.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	38.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	24.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	8	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	7.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	16	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	535.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	439.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	447.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	15.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	15.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	15.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	15	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	15	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	106	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	106	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	5.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	5.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	5.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	9	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	117	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	117	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	5	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	5	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Unknown Operations	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations This Read Vac	11	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations Counter AL	32	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations Counter AF	32	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps B Phase V	122.98	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps C Phase V	122.98	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps A Phase V	122.98	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps C Ø	115.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps B Ø	117.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps A Ø	178.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	9 Month Operations	13	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	9 Month Operations	10	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps A Ø	113.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps B Ø	81.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps C Ø	121.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps A Phase V	78.26	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps B Phase V	78.26	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps C Phase V	78.26	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations Counter AF	143	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations Counter AL	143	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations This Read Vac	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Unknown Operations	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps B Phase V	33.54	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps C Ø	74.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps B Ø	63.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations Counter AF	21	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations Counter AL	21	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations This Read Vac	3	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps A Ø	73.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Unknown Operations	3	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	9 Month Operations	3	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Unknown Operations	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps C Phase V	78.26	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations This Read Vac	7	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations Counter AL	82	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations Counter AF	82	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps C Ø	36.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps B Ø	29.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps A Ø	39.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	9 Month Operations	8	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps B Phase V	78.26	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps A Phase V	78.26	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.3	VDC
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	9 Month Operations	8	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps A Ø	39.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps B Ø	63.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps C Ø	57.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps A Phase V	55.90	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps B Phase V	55.90	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps C Phase V	55.90	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations Counter AF	35	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations Counter AL	35	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations This Read Vac	5	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Unknown Operations	5	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72317	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	162.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	162.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	162.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations Counter AF	36	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations Counter AL	36	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations This Read Vac	6	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Switching Operations	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Unknown Operations	6	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps C Ø	402.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps B Ø	341.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps A Ø	431.0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	9 Month Operations	7	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments	Upper arm stops resetting at R2	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	317272	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128836	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1910.88	kw
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7962	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments	Oil level gauge cover is broken.	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	156	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	156	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	8	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations VCB New	8	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	115.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	125.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	140.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	154	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	120.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	154	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	95.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	130.0	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments	ok	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 8:55	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 11:35	Distribution	Middletown Substation Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 11:35	Distribution	Middletown Substation Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Fault Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	9 Month Operations GCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Num Operations Last 9 Months	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations Counter AF	92	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations Counter AL	92	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations This Read SF6	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Ambient Temperature	36	°F
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Pressure	66	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	General Comments	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	All Connections OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC As Found Counter	3877	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC As Left Counter	3877	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Current Tap Position	2R	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Max Tap Position	6R	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Min Tap Position	7L	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Operations Since Last Insp	750	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X3 Winding Temp Max	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X2 Winding Temp Max	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	LTC Totalizer Reading	7680.00	kw
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Oil Temp Max	20	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Oil Temp Present	20	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X1 Winding Temp Max	21	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Winding Temp Present	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Totalizer Meter Reading	.3200	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Winding Temp Max	21	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps C Ø	285.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps B Ø	245.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Switching Operations	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations This Read Vac	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations Counter AL	196	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations Counter AF	196	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps A Ø	310.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	9 Month Operations VCB New	4	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	9 Month Operations	5	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations Counter AL	169	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations Counter AF	169	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	9 Month Operations	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps C Ø	145.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps A Ø	140.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps B Ø	140.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations Counter AF	274	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	9 Month Operations	4	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	9 Month Operations VCB New	4	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps A Ø	60.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps B Ø	55.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations Counter AL	274	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps C Ø	90.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations Counter AL	167	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps C Ø	90.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations Counter AF	167	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps B Ø	55.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps A Ø	100.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	9 Month Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps B Ø	0.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps C Ø	0.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps A Ø	0.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Switching Operations	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations This Read Vac	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations Counter AL	171	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations Counter AF	171	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	9 Month Operations	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations Counter AL	202	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations Counter AF	202	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	9 Month Operations	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps A Ø	35.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps B Ø	40.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps C Ø	30.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps A Ø	5.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps B Ø	3.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	9 Month Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps C Ø	20.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations Counter AL	212	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations Counter AF	212	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps C Ø	50.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations Counter AF	167	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations Counter AL	167	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps B Ø	55.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps A Ø	100.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	9 Month Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps A Ø	130.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps B Ø	150.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps C Ø	105.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations B Ø	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations C Ø	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	9 Month Operations	5	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations Counter AF	191	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations Counter AL	191	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations This Read Vac	4	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Unknown Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Switching Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations Counter AL	213	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations Counter AF	213	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps C Ø	270.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps B Ø	305.0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps A Ø	290.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	9 Month Operations	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	All Connections OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	LTC Operation Checked?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Operations Since Last Insp	700	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Max Tap Position	9R	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC As Left Counter	4878	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC As Found Counter	4878	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Totalizer Meter Reading	.3900	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Oil Temp Present	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Oil Temp Max	0	°C
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	LTC Totalizer Reading	9360.00	kw
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	General Comments	C50 NOT WORKING	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	9 Month Operations GCB New	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Fault Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Switching Operations	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations This Read SF6	1	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations Counter AL	143	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Maintenance Operations	0	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Num Operations Last 9 Months	2	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations Counter AF	143	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Pressure	66	psi
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	General Comments	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Ambient Temperature	36	°F
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.6	amps
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.8	VDC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	36	°F
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 7:55	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.700	millivolts
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.300	millivolts
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC As Left Counter	1733	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Current Tap Position	7L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Min Tap Position	15L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC As Found Counter	1733	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	General Comments	counter entered wrong last check (JB corrected counters on last check and LTC overhaul mxorder)	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	General Comments	Under Construction Not in Sevice	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC As Found Counter	1733	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC As Left Counter	1733	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Max Tap Position	16R	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Min Tap Position	16L	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X3 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X3 Winding Temp Max	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X2 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X3 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X3 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X1 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X3 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X3 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X2 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X2 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X1 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X1 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	100	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	General Comments	Not in Service. Being built.	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X1 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X2 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X2 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X2 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X1 Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X1 Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Winding Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Winding Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations Counter AF	318	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations Counter AL	318	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations Counter AF	294	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations Counter AL	294	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations Counter AL	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations Counter AF	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	General Comments	Under Constuction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations Counter AF	252	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations Counter AL	252	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations Counter AF	256	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations Counter AL	256	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations Counter AL	285	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations Counter AL	250	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations Counter AF	250	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations Counter AL	241	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations Counter AF	241	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations Counter AF	275	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations Counter AL	275	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations Counter AL	244	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations Counter AF	244	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations Counter AL	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations Counter AF	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations Counter AF	278	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations Counter AL	278	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations Counter AF	255	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations Counter AL	255	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations Counter AF	285	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations Counter AL	500	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations Counter AF	500	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations Counter AF	292	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations Counter AL	292	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations Counter AF	502	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations Counter AF	486	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations Counter AL	486	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	9 Month Operations	-1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations Counter AL	482	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations Counter AF	482	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations Counter AL	502	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations Counter AF	298	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations Counter AL	298	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations Counter AL	491	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations Counter AF	491	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations Counter AL	303	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations Counter AF	303	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	General Comments	Under Construction.	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations Counter AL	286	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations Counter AF	286	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations Counter AF	250	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations Counter AL	250	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations Counter AF	232	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations Counter AL	232	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations Counter AL	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations Counter AL	240	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations Counter AF	240	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations Counter AF	242	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations Counter AL	271	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations Counter AF	271	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Maintenance Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations Counter AF	293	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations Counter AL	293	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	9 Month Operations	-1	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	General Comments	Under Construction Not in Service.	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations VCB New	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	9 Month Operations VCB New	7	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations VCB New	4	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	9 Month Operations VCB New	3	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations VCB New	3	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations VCB New	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	9 Month Operations VCB New	6	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	9 Month Operations VCB New	5	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations VCB New	2	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	1	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	15	°C
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	Nitro cyl neede refielld.	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	1	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	16.84	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	15.31	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	4.59	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	4.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	3.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	108	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	108	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	208.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	203.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	10.72	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	18.37	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	131	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	1312	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	18.37	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations VCB New	4	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	4	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	203.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	5	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations VCB New	5	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	18.37	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	27.56	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	13.78	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	15.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	15.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	15.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	151	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	151	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	190	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	190	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	225.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	229.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	2	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	.15	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	226.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	.15	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	209	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	209	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	.3	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	.3	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	.3	%
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	1	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments	ok	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	35	°C
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121535	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121535	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	7	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	6	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	7	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	2	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	35	°C
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptible	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 5:51	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Tank Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Grounds in Place?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Foundation Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Bushing Condition	Good	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/13/2023 12:52	Distribution	Nachand Substation Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AL	183	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AF	183	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps C Ø	115.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps B Ø	130.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps A Ø	110.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations	5	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations VCB New	5	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	410.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	340.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	330.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	214	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	214	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	269	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	269	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	7.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	7.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	10.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	1	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	2	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	290.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	300.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	310.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	316	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	316	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	202	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	95.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	202	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	70.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	60.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	2	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	233	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	233	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	295.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	260.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	265.0	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations VCB New	4	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	4	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	84756	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	84756	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	1R	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	8R	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	1265	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	10638.00	kw
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	45	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.5910	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	65	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	30	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	209537	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	209537	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	1R	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	12R	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	1025	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8920.80	kw
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.2390	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 15:17	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	6	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations VCB New	6	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	110.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	75.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	100.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	256	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	256	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Unknown Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	9 Month Operations	5	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	9 Month Operations VCB New	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Switching Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AL	176	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps A Ø	175.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps B Ø	200.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps C Ø	180.0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Maintenance Operations	0	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AF	176	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Min Tap Position	9R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10105	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11580	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11342	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5965.92	kw
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	15	°C
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8286	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 15:03	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	274	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	274	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	29.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	25.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	25.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	1	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Maintenance Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AF	204	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AL	204	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Switching Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps C Ø	155.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps B Ø	150.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps A Ø	157.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Unknown Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	9 Month Operations VCB New	5	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	9 Month Operations	5	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Maintenance Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AF	172	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AL	172	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps C Ø	190.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps B Ø	190.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps A Ø	190.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	9 Month Operations	1	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Switching Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Unknown Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps A Ø	5.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps B Ø	1.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Unknown Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Switching Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AL	185	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AF	185	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Maintenance Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps C Ø	4.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	172	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	172	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	389.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	355.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	359.0	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations VCB New	3	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	3	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	2648	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	7R	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	43948	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	43948	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	9558.00	kw
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.5310	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	55	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	30	°C
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	35	°F
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 14:52	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.4	VDC
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42449	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37889	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35594	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0548	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	41	°C
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments	temp gauge needs new lense	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10126.08	kw
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	206	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	206	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	2	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	162.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	197.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	173.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	1	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	117.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	113.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	98.0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations VCB New	3	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	4	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments	1 - CG	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	211	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	211	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	1	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 14:03	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	261	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	17	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations VCB New	17	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	261	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps A Ø	274.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps B Ø	199.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps C Ø	214.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Maintenance Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AF	204	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AL	204	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Switching Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Unknown Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations	1	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	2	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	78.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	94.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	196	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	196	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	1	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	1	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	84.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1168	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	107783	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	107773	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	8976.00	kw
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	21	°C
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	.9350	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	50	°C
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	179.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	169.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	161.0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	262	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	262	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	2	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	All Connections OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	181483	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	181493	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	2L	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	1019	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.8180	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	7852.80	kw
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
12/11/2023 13:50	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 15:19	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	27	°C
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2193	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2926.32	kw
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63733	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	.75	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	4	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	.27	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	.32	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	.37	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	.75	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	1.17	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations VCB New	8	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	.59	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	.59	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	.64	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	.11	%
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54948	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	57309	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	114	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	91.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	64.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	47.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	9 Month Operations VCB New	3	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	9 Month Operations VCB New	3	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	115	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 9:17	Distribution	Manslick Substation Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	Fence and barbed wire rusty, gaps under fence . Fence has hole in the back near transformer.	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 15:18	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5837.76	kw
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2162	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47613	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	43398	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52621	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.6	VDC
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	7.86	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	5.24	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	3	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	2	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	318	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	318	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	5	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	69.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	102.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	94.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations	1	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps A Ø	55.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps B Ø	44.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps C Ø	78.0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Unknown Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations A Ø	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations B Ø	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations C Ø	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Switching Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations Ground	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Maintenance Operations	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations This Read Vac	0	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AF	223	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AL	223	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.360	millivolts
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 13:14	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	312	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	3855	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	3861	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	436.32	kw
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	34	°C
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.1818	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	13	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	13	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	0.0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	10.0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	5.0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	0	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.7	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	55.1	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.5	VDC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	562	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	14432	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	14420	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 11:04	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments	Knob is broken on temp reset	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	4239.36	kw
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.4416	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	2	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	120.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	332	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	332	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	150.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	150.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	2	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	10.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	10.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	20.0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	211	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	0	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	211	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 10:59	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments	counter not working	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	2796.00	kw
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	57	°C
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	44	°C
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.4660	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.7	VDC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	220.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	260.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	200.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	731	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	731	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	20.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	20.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	20.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	1	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	762	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	762	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	1	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	12.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	12.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	12.0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	326	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	326	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.360	millivolts
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	posts and rails rusty, cudzu and growing up fence in back corner of station	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 12:16	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	2	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	146	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	146	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	3	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	100.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	136.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	233	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	233	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations VCB New	3	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	130.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	5	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	155.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	155.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	3	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	202	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	202	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	155.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	216	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	216	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	15.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	13.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	50.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations VCB New	7	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	173	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	173	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	340.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	300.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	250.0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	53331	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	908	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	53331	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	54	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	23	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	63	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	22	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	56	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	15	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	62	°C
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	35	°F
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	67	psi
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	9 Month Operations GCB New	1	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	60	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	60	
12/12/2023 1:49	Distribution	Conestoga Substation Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14206	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14849	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15659	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	15	°C
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4284	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	15	°C
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4112.64	kw
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	111.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	63.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	277	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	277	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	66.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	35.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	34.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	19.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	250	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	250	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	2	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	4	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations VCB New	4	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	34.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	46.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	48.0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	213	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	213	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps B Ø	359.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps A Ø	369.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	9 Month Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps C Ø	378.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Unknown Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Switching Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AL	209	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Maintenance Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AF	209	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	295	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	295	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	0.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	0.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	0.0	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	122213	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	162766	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115408	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 10:21	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	60	°C
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9726	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9336.96	kw
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	290.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.5790	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	100	°C
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	11368.80	kw
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	59117	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	59123	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1376	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 10:10	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.1	VDC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps C Ø	113.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps B Ø	107.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps A Ø	148.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations VCB New	4	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations	4	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Maintenance Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AF	229	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AL	229	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Switching Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Unknown Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	1	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	167	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	167	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	2	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	98.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	89.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	100.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	1	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	232	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	232	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	113.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	123.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	122.0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	0	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13957	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	4R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments	drag hands wont reset	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.730	millivolts
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17266	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	18156	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4959.36	kw
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5166	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Present	10	°C
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 10:24	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	-2	psi
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	1	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	47.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	43.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	43.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	3	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	187	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	187	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	1	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	272	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	272	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	10	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations VCB New	10	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	106.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	118.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	104.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	187	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	187	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	39.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	33.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	41.0	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations VCB New	4	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	4	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments	cascade wont allow either float voltage to be entered	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:57	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	436	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	436	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	128.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	49.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	58.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations VCB New	6	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	6	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	494	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	494	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	170.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	119.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	172.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	442	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	442	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	91.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	95.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	106.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	137.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	111.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	83.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	379	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	379	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	380.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	419.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	263	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	513.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	263	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	145	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	145	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations VCB New	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	81.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	44.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	55.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	172	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	172	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments	heat was not on turned heat on to 70	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	239	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	239	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	20.73	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	15.94	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	97.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	130.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	107.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments	cascade wont accept AF and AL float voltages	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	243	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	243	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	2	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations VCB New	2	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	20.73	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	76.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	26.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	41.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	23.92	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	16.74	%
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	96350	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	39.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	57.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	77.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	198	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	198	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	213338	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	1L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	4R	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	2023	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	32.73	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	32.73	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	32.73	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	225	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	225	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	663.36	kw
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8292	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	151	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	151	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	301.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	290.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	231.0	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	1	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	4	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	205	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	205	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	81.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	71.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	47.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations VCB New	4	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	482	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	28779	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	28779	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	95.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	93.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	91.0	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	220	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	6	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	42	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	15	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	41	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	41	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	15	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	41	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	44	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	44	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	23	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	43	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	23	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	44	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	405	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	12207	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	12207	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments	wash out front right side	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 9:28	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77708	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56660	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56299	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9540	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2289.60	kw
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	163	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	165.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	181.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	161.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	391	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	185.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	124.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	107.0	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 8:52	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	466.67	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	42	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	445.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Needs nitrogen.	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 5:56	Distribution	Solite Substation Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments	ok	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments	ok	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2023 9:32	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	9 Month Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Unknown Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Switching Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AL	193	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AF	193	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Maintenance Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	9 Month Operations	1	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty C Ph V	.53	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps A Ø	20.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps B Ø	27.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps C Ø	18.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps C Ø	40.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps B Ø	41.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps A Ø	49.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty B Ph V	3.18	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	9 Month Operations VCB New	5	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	9 Month Operations	5	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Unknown Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Switching Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AL	199	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AF	199	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Maintenance Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	General Comments	1 50 CN	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps A Ø	27.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps B Ø	27.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps C Ø	24.0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations A Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations B Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations C Ø	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations Ground	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Unknown Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Switching Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Maintenance Operations	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations This Read Vac	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AL	173	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AF	173	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55389	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	340	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	340	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	1	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	1	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	59.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	49.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	40.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	10.24	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	10.97	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	8.04	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations VCB New	3	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	4	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	1	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	1	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	486	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	200.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	255.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	186.0	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	19.75	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	26.33	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	29.25	%
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations VCB New	1	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	2	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	486	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments	house heater not working	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	1160	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	5R	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	18554	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	18541	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	42	°C
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	42	°C
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	219638	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	165200	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments	Needs new temp gauge.	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	575.28	kw
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4794	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	18	°C
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	bad gauge	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	10	°C
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	32	°C
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection. Xfmr fuse barrels are starting to fray. There are no spare xfmr fuses.	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments	barbed wire broken in a spot	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments	Small washouts are developing along back fence of station.	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.7	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps B Ø	32.8	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.3	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	General Comments	Counters: A 130, B 198, C 210	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/8/2023 15:21	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8102	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7810	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6942	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Present	26	°C
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Max	49	°C
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3516	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Present	26	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2531.52	kw
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments	There aren't any xfmr fuses because there is a high side bkr.	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.7	VDC
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/12/2023 7:01	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10628	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10239	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10404	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations Ground	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations C Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Maintenance Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AF	194	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AL	194	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations This Read Vac	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Switching Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Unknown Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations B Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations A Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps C Ø	9.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps B Ø	10.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps A Ø	8.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty A Ph V	.11	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations VCB New	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	185	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	276893	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	276893	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	22	°C
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.80	MegaVars
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.05	MegaVars
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.80	MegaWatts
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	482	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Month Ops New	20	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	20	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	170.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	160.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	180.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	482	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Month Ops New	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	10.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	10.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	100.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	316	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	316	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations VCB New	2	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations B Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations C Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations A Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Unknown Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Switching Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations This Read Vac	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AL	193	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AF	193	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Maintenance Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps C Ø	14.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations Ground	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations	2	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps B Ø	11.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps A Ø	23.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty C Ph V	.15	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty B Ph V	.3	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	180.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	170.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	170.0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Month Ops New	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	386	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	386	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2023 12:14	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations Ground	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Maintenance Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AF	223	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AL	223	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations This Read Vac	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Switching Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Unknown Operations	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations C Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations B Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations A Ø	0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps C Ø	1.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps B Ø	18.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps A Ø	3.0	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty B Ph V	.52	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty A Ph V	.82	%
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations VCB New	1	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations	1	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Present	29	°C
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5382	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Max	46	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1291.68	kw
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/12/2023 6:58	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	VRR Time Delay	0	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	LTC Operation Checked?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	General Comments	Not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000993	LTCControl	470-2	LTC Control Insp	All Connections OK?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	VRR Time Delay	0	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	LTC Operation Checked?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	General Comments	under construction	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000994	LTCControl	470-7	LTC Control Insp	All Connections OK?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC Operations Since Last Insp	1755	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC As Left Counter	1755	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	LTC As Found Counter	1755	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Counter Readings	General Comments	under construction	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	MFD Breather green light	NotOK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000135	LTCMechanism	470-7	LTC Mechanism Patrol Inspection	General Comments	under construction	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	General Comments	under construction	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Oil Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Oil Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Readings	X3 Winding Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	General Comments	under construction	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000317	WithLTC	470-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	228	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	228	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	132.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations VCB New	6	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	131.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	139.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	6	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	236	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	236	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	44.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	67.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	62.0	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations VCB New	6	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	6	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	20904	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	20911	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	8R	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	1101	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5356.80	kw
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	53	°C
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.5580	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Base Voltage AL	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Base Voltage AF	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	LTC Operation Checked?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	General Comments	Not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	All Connections OK?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.4	VDC
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Winding Temp Present	15	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Winding Temp Max	18	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	General Comments	not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Oil Temp Max	18	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Readings	Oil Temp Present	15	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	All Connections OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	LTC Operation Checked?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Base Voltage AF	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Base Voltage AL	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Winding Temp Present	34	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Winding Temp Max	38	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Totalizer Meter Reading	.3430	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Oil Temp Present	34	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Oil Temp Max	38	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	LTC Totalizer Reading	7203.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Base Voltage AL	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Base Voltage AF	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	LTC Operation Checked?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	All Connections OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Winding Temp Present	31	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Winding Temp Max	52	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Totalizer Meter Reading	.1640	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Oil Temp Present	31	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Oil Temp Max	51	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	LTC Totalizer Reading	3444.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	All Connections OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	LTC Operation Checked?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Base Voltage AF	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Base Voltage AL	118.8	VAC
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Winding Temp Present	31	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Winding Temp Max	37	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Totalizer Meter Reading	.0660	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Oil Temp Present	31	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	Oil Temp Max	37	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	LTC Totalizer Reading	1386.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC As Left Counter	988	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC Operations Since Last Insp	988	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC As Found Counter	988	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	General Comments	Not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Oil Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	General Comments	Not in service	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Oil Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Winding Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Winding Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	General Comments	offline	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000316	WithLTC	470-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top fence rails are rusty, fence fabric seperated from post on the left hand side of the station	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2023 11:47	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	All Identified and Legible?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Landscape Good Condition?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Ambient Temp	40	°F
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2023 7:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations VCB New	2	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	126.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	2	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	132.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	123.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	195	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	195	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	191	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	191	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	113.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	125.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	116.0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations VCB New	4	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	4	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1600	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	214660	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	214646	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	6422.40	kw
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.8920	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	Limbs growing over top of fence	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2023 10:31	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	202	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	202	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	115.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	145.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	138.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	1	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations VCB New	1	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	10.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	10.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	10.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	346	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	346	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	11	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	11	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	6.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	6.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	6.0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	0	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue			AssetInspectionQuestionUnit
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	0			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations VCB New	0			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00			%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00			%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00			%
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments				
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments				
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	85758			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	85765			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	5L			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	Neutral			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	9L			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	644			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	All Connections OK?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	General Comments				
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	LTC Operation Checked?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	LTC Output Voltage Level	124.9			VAC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AF	124.0			VAC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AL	124.0			VAC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Time Delay	45			Seconds
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments	ERR 00000001	Meter battery is dead.	Meter dept. notified for replacement.	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	0.00			kw
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	52			°C
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	23			°C
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good			check oil cup
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments				
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5			psi
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y			
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments	heater and cabinet lights not working			

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.3	VDC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	two large birds nests in steel above transformer fuses	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2023 10:21	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments		
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	brabed wire rusty and sagging, one bayonet broken, fence post very loose	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
12/8/2023 10:09	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	9 Month Operations	42	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations This Read Vac	42	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations Counter AL	294	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Operations Counter AF	294	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Maintenance Operations	41	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations Counter AL	288	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations This Read Vac	38	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Maintenance Operations	37	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Operations Counter AF	288	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Readings	9 Month Operations	38	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations This Read Vac	25	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations Counter AL	313	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Operations Counter AF	313	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Maintenance Operations	24	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	9 Month Operations	25	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	9 Month Operations	35	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Maintenance Operations	34	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations Counter AF	277	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations Counter AL	277	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Operations This Read Vac	35	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations This Read Vac	46	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations Counter AL	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Operations Counter AF	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Maintenance Operations	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Readings	9 Month Operations	46	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations This Read Vac	43	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations Counter AL	275	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Operations Counter AF	275	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Maintenance Operations	42	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Readings	9 Month Operations	43	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	9 Month Operations	39	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Maintenance Operations	38	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations Counter AF	294	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations Counter AL	294	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Operations This Read Vac	39	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Maintenance Operations	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations This Read Vac	46	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations Counter AF	296	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Operations Counter AL	296	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Readings	9 Month Operations	46	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Maintenance Operations	43	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations Counter AF	288	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations Counter AL	288	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Operations This Read Vac	44	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	9 Month Operations	44	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	9 Month Operations	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations This Read Vac	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations Counter AL	302	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Operations Counter AF	302	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	Maintenance Operations	44	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	9 Month Operations	50	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Maintenance Operations	49	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations Counter AF	293	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations Counter AL	293	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Operations This Read Vac	50	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations This Read Vac	40	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations Counter AL	311	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Operations Counter AF	311	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Maintenance Operations	39	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Readings	9 Month Operations	40	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Maintenance Operations	38	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations Counter AF	281	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations Counter AL	281	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Operations This Read Vac	39	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Readings	9 Month Operations	39	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations This Read Vac	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	9 Month Operations	45	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Maintenance Operations	44	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations Counter AF	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Readings	Operations Counter AL	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations Counter AF	318	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations Counter AL	318	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations Counter AF	298	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations Counter AL	298	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations Counter AF	293	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations Counter AL	293	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations Counter AF	285	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations Counter AL	285	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	9 Month Operations	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations Counter AF	295	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations Counter AL	295	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Operations This Read Vac	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Switching Operations	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations Counter AF	485	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations Counter AL	485	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Operations This Read Vac	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	9 Month Operations	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Switching Operations	3	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations Counter AF	296	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations Counter AL	296	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	9 Month Operations	2	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Switching Operations	2	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Readings	Operations This Read Vac	2	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations Counter AF	502	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations Counter AL	502	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Switching Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations This Read Vac	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations Counter AL	492	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Operations Counter AF	492	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	9 Month Operations	1	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations Counter AL	486	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Readings	Operations Counter AF	486	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations Counter AF	275	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations Counter AL	275	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations Counter AF	303	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations Counter AL	303	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Switching Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations Counter AL	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Operations Counter AF	286	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations Ground	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations C Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations B Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Operations A Ø	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	9 Month Operations VCB New	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	9 Month Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps A Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps C Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Amps B Ø	0.0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Unknown Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations This Read Vac	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations Counter AL	500	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Operations Counter AF	500	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Maintenance Operations	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC As Left Counter	715	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC As Found Counter	715	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	General Comments	Not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	11	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	11	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Operations Since Last Insp	650	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Min Tap Position	10L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Max Tap Position	3R	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Current Tap Position	10L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC As Left Counter	1436	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC As Found Counter	1436	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	14	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Operations Since Last Insp	10	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Min Tap Position	6L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Max Tap Position	6L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Current Tap Position	10L	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC As Left Counter	2018	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC As Found Counter	2018	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	17	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	18	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000137	LTCMechanism	470-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	General Comments	Not in service	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	LTCM000134	LTCMechanism	470-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	General Comments		
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2023 11:27	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12566	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12597	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12857	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4902	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	180.00	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1176.48	kw
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	204.17	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	85.0	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	85.0	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	77.0	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	207	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:53	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	289	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	289	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	255.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	262.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	276.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	241.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	233.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	226.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	399	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	399	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	287	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	287	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	148.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	154.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	149.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	620.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	620.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	620.0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	208	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	208	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	323054	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	478	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	323054	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.8030	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	70	°C
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	55	°C
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	14454.00	kw
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	70	°C
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.3	VDC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 14:17	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.5	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.9	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.1	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	WX0323	RecloserHydraulic	618-1690	Recloser Hydraulic Patrol Inspection	General Comments	A phase counter-255, B phase-241, C phase-223	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	97773	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19291	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	counter broken	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1311.84	kw
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0932	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 13:43	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	9 Months Operations OCB New	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations This Read Oil	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	373	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	373	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	162	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	1R	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	23115	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	23115	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	189988	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	189988	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	4R	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	11R	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	25	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	25	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	27	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	35	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments	High oil temp alarm in	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	leak around guages. pressure relief alarm is in.	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	49982	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	49982	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	20	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	16L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	11L	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	145.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	50	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments	oil leak on low side throat of trans	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	155	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	155	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments	DNO	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations VCB New	9	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	9	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	99.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	92.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	92.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	190	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	190	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	164	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	164	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	86.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	90.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	98.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	108.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	103.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	100.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	529	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	529	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	15	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations VCB New	8	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	80.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	86.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	78.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	56.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	7	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	103	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	103	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	7	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	186	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	186	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	302	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	49.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	57.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	351.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	365.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	365.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	346	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	346	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Operations Counter	96	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps B Ø	64.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	8	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	22.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	2L	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	81	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	81	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments	VC not working	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	4R	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	5L	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	238046	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	238046	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	282	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	25	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	20	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	20	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	25	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	47	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	45	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	45	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	20	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.5964	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	4294.08	kw
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	96	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	267701	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	267701	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 12:04	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AL	142	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AF	142	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	General Comments	N/O	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	89	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	89	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	114.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	141.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	122.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	65	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	65	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	164.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	139.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	180.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations VCB New	9	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations	11	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps A Ø	43.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps B Ø	42.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps C Ø	42.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations This Read Vac	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Unknown Operations	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AL	324	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AF	324	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps C Phase V	16.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations VCB New	4	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations	4	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps A Ø	143.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AL	45	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AF	45	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps B Ø	167.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps C Ø	136.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations This Read Vac	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AL	30	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AF	30	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations B Ø	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations A Ø	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps C Ø	129.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps B Ø	160.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps A Ø	151.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations This Read Vac	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AL	59	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AF	59	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps A Ø	133.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps B Ø	122.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps C Ø	112.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations	8	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations B Ø	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations A Ø	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps A Ø	120.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps B Ø	130.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps C Ø	125.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations	6	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AF	48	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AL	48	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AF	42	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AL	42	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps A Ø	505.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps B Ø	570.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps C Ø	456.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	83	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	83	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AF	81	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AL	81	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps C Ø	117.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps B Ø	131.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps A Ø	125.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations	3	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps A Ø	397.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AL	310	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AF	310	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps B Ø	412.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps C Ø	417.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AF	347	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AL	347	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AL	335	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AF	335	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AL	327	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AF	327	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AL	372	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	9 Month Operations	6	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps A Ø	43.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps B Ø	42.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps C Ø	42.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AF	372	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations Counter AL	62	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	9 Month Operations	16	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	9 Month Operations VCB New	16	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations Counter AF	62	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps C Ø	113.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps B Ø	116.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps A Ø	122.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	9 Month Operations	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps A Ø	90.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps B Ø	85.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps C Ø	79.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations A Ø	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations This Read Vac	2	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AL	31	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AF	31	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps B Ø	76.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps C Ø	70.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps A Ø	78.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AL	31	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AF	31	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps A Ø	93.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps B Ø	88.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps C Ø	81.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AL	42	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AF	42	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	General Comments	DNO	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	9 Month Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations Counter AF	16	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations Counter AL	16	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps A Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps B Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps C Ø	0.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Unknown Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Switching Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations Counter AL	51	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations Counter AF	51	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps C Ø	330.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps B Ø	349.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps A Ø	387.0	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	9 Month Operations	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	General Comments		
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 12:17	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	190	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	190	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	205.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	191.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	188.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	159	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	159	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	129.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	115.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	132.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	200	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	200	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	201.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	184.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	143.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	105.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	105.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	91.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	191	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	191	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Unknown Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations Counter AF	174	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Maintenance Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	9 Month Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations Counter AL	174	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps C Ø	573.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps B Ø	523.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps A Ø	588.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	9 Month Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Maintenance Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AF	168	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AL	168	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Switching Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Unknown Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps C Ø	0.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps B Ø	0.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps A Ø	0.0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	277	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	14L	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	3L	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	4309	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	4309	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	9 Month Operations	2	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Maintenance Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AF	200	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AL	200	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps A Ø	47.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps B Ø	48.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps C Ø	58.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Unknown Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Switching Operations	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	All Connections OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Maintenance Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	9 Month Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps A Ø	52.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AF	156	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AL	156	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps C Ø	65.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps B Ø	53.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Switching Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Unknown Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	13305.60	kw
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	45	°C
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	90	°C
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.7392	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Found Counter	5170	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Left Counter	5170	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Current Tap Position	3L	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Max Tap Position	1R	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Min Tap Position	5L	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Operations Since Last Insp	367	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Present	20	°C
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Max	40	°C
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Reading	.0760	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Max	40	°C
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	LTC Totalizer Reading	1368.00	kw
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Unknown Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Switching Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations This Read SF6	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AL	1026	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	9 Month Operations GCB New	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Num Operations Last 9 Months	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Maintenance Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AF	1026	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps A Ø	0.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps B Ø	0.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Fault Operations	0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps C Ø	0.0	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Pressure	67	psi
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Ambient Temperature	39	°F
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 10:31	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 10:29	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments	50.9 volts after 1 minute trip	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	768	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	129175	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	129175	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	257	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	257	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments	OPEN	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	6	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	4	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations VCB New	4	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments	DNO	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	210	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	210	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	268.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	254.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	5	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations VCB New	5	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	436	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	436	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	255.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	11	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations VCB New	10	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	94.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	68.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	75.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	229	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	229	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	227	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	227	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	143.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	130.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	190.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	163	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	163	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	553.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	454.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	173	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	173	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	471.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	246.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	200.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	209.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	636	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	636	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	580	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	69016	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	69016	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	49	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	49	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	49	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	48	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Leaking	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.2	psi
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR needs nitro. Oil leak in the lowside throat	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	65	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	15	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	56	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	75	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	80	°C
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments	The H2 and X3 gauge seem to be wrong. H2 is keeping the fans on and should be replaced.	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments	Bathroom is out of order	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	240.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	155.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	175.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	2	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	195.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	150.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	120.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	47	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	47	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations	3	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	577.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	463.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	474.0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments		
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	77	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	77	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 10:05	Distribution	Fairmount Substation Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	7	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	3	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments	open	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	85	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	85	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	4	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	4	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	978	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	96.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	978	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	104.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	88.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Month Ops New	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Month Ops New	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	3	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	39.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	44.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	36.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	664	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	664	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Month Ops New	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	3	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	11.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	6.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	12.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	586	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	586	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	20	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	20	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments	B phase IOC	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	63.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	59.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	63.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	4	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Month Ops New	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	17	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	437	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	437	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	16	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	194.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	205.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	188.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	19	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Month Ops New	2	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	258	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	186328	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	186328	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	18	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	38	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	18	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	38	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	38	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	18	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Low oil main tank, TR needs nitro	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments	50.4 volts after 1 minute trip	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	9.4	amps
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	All Connections OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Operations Since Last Insp	236	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Min Tap Position	1L	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Max Tap Position	5R	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC As Left Counter	15537	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC As Found Counter	15537	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	General Comments	Port TR needs nitro	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	9	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	9 Month Operations	100	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	9 Month Operations VCB New	99	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps A Ø	540.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps B Ø	578.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps C Ø	589.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations Counter AF	114	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations Counter AL	114	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations This Read Vac	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Switching Operations	1	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Unknown Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Unknown Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Switching Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations This Read Vac	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations Counter AL	104	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations Counter AF	104	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps C Ø	105.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps B Ø	98.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps A Ø	95.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	9 Month Operations VCB New	84	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	9 Month Operations	84	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Unknown Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Switching Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations This Read Vac	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations Counter AL	97	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations Counter AF	97	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	9 Month Operations	78	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	9 Month Operations VCB New	78	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps A Ø	86.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps B Ø	90.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps C Ø	94.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	9 Month Operations VCB New	128	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	9 Month Operations	128	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps A Ø	171.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps B Ø	184.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps C Ø	189.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations Counter AF	146	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations Counter AL	146	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations This Read Vac	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Switching Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Unknown Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations A Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations B Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Maintenance Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations C Ø	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations Counter AF	108	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations Counter AL	108	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations This Read Vac	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations Ground	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Unknown Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Switching Operations	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	9 Month Operations	88	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	9 Month Operations VCB New	88	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps A Ø	190.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps B Ø	207.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps C Ø	202.0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	General Comments		
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	General Comments	this is not onsite	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H1 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H1 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H2 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H2 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H3 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	H3 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	HV Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	HV Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	LV Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	LV Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Top Oil Temperature Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Top Oil Temperature Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	TV Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	TV Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	This is not onsite	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/7/2023 9:46	Distribution	Bishop Substation Inspection	TX000315	WithLTC	BI-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	2	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	22.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	234	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	234	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	49.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	25.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	109	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	108093	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	101166	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	130147	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8142	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1465.56	kw
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210.00	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 7:05	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AF	178	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AL	178	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations This Read Vac	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Switching Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Unknown Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Maintenance Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations Ground	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations C Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations B Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations A Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps C Ø	83.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps B Ø	27.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps A Ø	44.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations	6	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps A Ø	190.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps B Ø	191.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps C Ø	176.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations A Ø	1	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations	3	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations C Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations Ground	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Maintenance Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AF	179	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AL	179	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations This Read Vac	1	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Switching Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Unknown Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations A Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations B Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations C Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations Ground	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Maintenance Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AF	165	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AL	165	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations This Read Vac	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Switching Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Unknown Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps C Ø	71.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps B Ø	77.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps A Ø	125.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations	2	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Unknown Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Switching Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations This Read Vac	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AL	174	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AF	174	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Maintenance Operations	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations	2	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations Ground	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations C Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations B Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations A Ø	0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps C Ø	78.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps B Ø	67.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps A Ø	84.0	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	1303	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	1303	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	360	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1306.80	kw
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.2178	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	All Connections OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	891	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	3L	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	14712	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	14712	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.7260	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	60	°C
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	6969.60	kw
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.0	VDC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 6:56	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Max	36	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Present	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Max	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Present	19	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Max	39	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Output Voltage Level	117.4	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AF	117.4	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AL	117.4	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	All Connections OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Found Counter	21503	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Left Counter	21503	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Current Tap Position	2L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Max Tap Position	3R	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Min Tap Position	5L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Operations Since Last Insp	1137	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	13	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	13	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.4	amps
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.2	VDC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.2	VDC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.8	VDC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations Counter AL	174	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations Counter AF	174	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	General Comments	vc is correct	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	9 Month Operations	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps A Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps B Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps C Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	314	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	314	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Month Ops New	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	123	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	123	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Month Ops New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	53	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AF	53	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments	carded	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	120.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	120.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	120.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Month Ops New	4734	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	4736	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	200.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	220.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	220.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	363	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	363	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	160.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	160.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	160.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	4	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Month Ops New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	879	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	879	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations This Read AM	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Month Ops New	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	53	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	53	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99989	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99989	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Month Ops New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Month Ops New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	780.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	780.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	780.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	153	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	152	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations This Read AM	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	597	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	1L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	11R	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	3L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	19746	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	19746	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	34	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	68	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	34	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	68	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	34	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	68	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	28	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	58	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Max	43	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.8	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Max	405	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	208.33	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	43	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	445.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	460.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	512	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	512	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1878	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1878	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	488	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	488	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	90.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	90.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	90.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Month Ops New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	748	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	748	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Month Ops New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	200.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	200.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	200.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	278	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	278	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	449	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	449	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	75.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	75.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	75.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	367	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Month Ops New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	30.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	30.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	30.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	367	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	426	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	426	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	12.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	12.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	12.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Month Ops New	11	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	11	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	110.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	110.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	120.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	465	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	417	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	245	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	245.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	245.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	245.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	245	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	110.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	110.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	110.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	605	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	608	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	351	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	1.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	351	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	1.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	1.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	380	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	380	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	4.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	2.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	2.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Month Ops New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	125	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	125	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	111	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	111	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	120	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	120	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Max	38	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Max	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Present	18	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AF	117.8	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AL	117.8	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Output Voltage Level	117.8	VAC
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Operation Checked?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	All Connections OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Found Counter	17407	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Left Counter	17407	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Current Tap Position	2L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Max Tap Position	4R	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Min Tap Position	3L	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	254	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	7	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	7	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	69	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	69	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	10	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	10	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	68	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	68	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps A Ø	133.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps B Ø	133.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps C Ø	136.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations Counter AF	136	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations Counter AL	136	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations Counter AL	113	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations Counter AF	113	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	9 Month Operations	12	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	9 Month Operations VCB New	12	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps A Ø	29.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps B Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps C Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations Counter AF	151	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations Counter AL	151	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	9 Month Operations	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps A Ø	35.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps B Ø	35.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps C Ø	35.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations Counter AF	128	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations Counter AL	128	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations Counter AF	146	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations Counter AL	146	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	9 Month Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps A Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps B Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps C Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations Counter AF	117	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations Counter AL	117	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations This Read Vac	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	9 Month Operations VCB New	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	9 Month Operations	4	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps C Ø	36.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps A Ø	36.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps B Ø	36.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps C Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps B Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps A Ø	29.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	9 Month Operations VCB New	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	9 Month Operations	2	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations Counter AL	130	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations Counter AF	130	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	9 Month Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations Counter AL	141	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations Counter AF	141	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps A Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps C Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps B Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps A Ø	140.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps B Ø	140.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps C Ø	140.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations Counter AF	129	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations Counter AL	129	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations Counter AL	112	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations Counter AF	112	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	9 Month Operations VCB New	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	9 Month Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps B Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps C Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps A Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	9 Month Operations VCB New	6	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	9 Month Operations	6	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations Counter AF	123	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations Counter AL	123	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps C Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps B Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps A Ø	26.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	9 Month Operations	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations Counter AF	153	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations Counter AL	153	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations Counter AL	116	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations Counter AF	116	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps C Ø	22.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps B Ø	22.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps A Ø	22.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	9 Month Operations VCB New	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	9 Month Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations Counter AF	110	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations Counter AL	110	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations This Read Vac	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps C Ø	23.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps B Ø	23.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps A Ø	23.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	9 Month Operations	4	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations Counter AL	113	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	9 Month Operations	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps A Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps B Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps C Ø	18.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations Counter AF	113	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	9 Month Operations	4	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	9 Month Operations VCB New	3	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps A Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps B Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps C Ø	265.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations Counter AF	130	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations Counter AL	130	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations This Read Vac	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Switching Operations	1	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	95	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	95	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	9	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	9	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2023 5:37	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	192	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	192	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	640.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	640.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	640.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	646	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	646	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	0	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	240234	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	240234	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	520	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	3870.00	kw
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	.6450	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 15:24	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	9 Month Operations VCB New	3	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	9 Month Operations	3	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps A Ø	112.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AF	211	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AL	211	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Switching Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Unknown Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps B Ø	118.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps C Ø	139.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Maintenance Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	263	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	263	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	78.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	80.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations VCB New	5	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	5	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	105.0	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	718	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	3R	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	28679	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	28679	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	1.0878	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	7832.16	kw
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.0	VDC
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 15:20	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	65.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	92.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	51.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	173	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	173	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	1	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	1	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	27.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	188	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	188	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	34.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	29.0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	1L	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	2R	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	32390	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	8L	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	583	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	32390	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments	Meter was showing an error, could not get reading off of it, needs to be fixed.	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:17	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	459	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	459	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	2	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	372.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	384.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	382.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	258	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	258	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	2	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	2	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Operations Counter	181414	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps B Ø	57.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps C Ø	56.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	361	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	140185	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	140185	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	872	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	228	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	65.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	228	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	1	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	1	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	61.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	74.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	2	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	2179.20	kw
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.2270	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 15:10	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	442.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	443.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	446.0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	9 Month Operations GCB New	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	51	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	51	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	44	°F
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	87	psi
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	0	Seconds
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4320	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4320	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	10	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	30	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	20	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	10	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	1165	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	77486	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	77486	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	11664.00	kw
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.2150	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	45	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments	no fuses in sub	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 15:12	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	46966	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	46966	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5R	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1095	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	53	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	311	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	311	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Month Ops New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Months Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	435.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	466.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	636	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	461.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	636	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Month Ops New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	747	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	747	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Month Ops New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	778	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	778	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	5	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	6	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	126.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	124.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Month Ops New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	5	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	25.98	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	122.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AL	609	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AF	609	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Month Ops New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	569.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	577.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	552.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C Ø	178.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B Ø	203.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A Ø	242.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Month Ops New	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AF	893	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AL	893	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	2	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	910	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	910	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	2	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Month Ops New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	59.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	60.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	51.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Month Ops New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	325	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	325	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AL	963	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AF	963	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps C Ø	111.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps B Ø	128.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps A Ø	123.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Month Ops New	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	330	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	330	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Month Ops New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	372.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	361.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	338.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	43	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	70	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	43	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	42	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	69	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	19	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	53	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	579	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	15L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	5L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	12L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	219175	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	219175	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	37	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	55	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	27	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	37	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	506	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	206072	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	206072	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	47	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	56	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	36	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	9 Months Operations OCB New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	246	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	30605	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	30605	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	60	°C
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro in trans and 6pack	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations	6	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations VCB New	5	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps A Ø	144.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps B Ø	174.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps C Ø	153.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations C Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AF	102	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AL	102	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations This Read Vac	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	96	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	96	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	41.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps B Ø	33.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps A Ø	39.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations VCB New	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	4	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	107	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	107	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	4	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	114.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	117.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	105.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations VCB New	4	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	8	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	8	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	8	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	102	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	102	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	9	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	72	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	72	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	287.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	320.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	312.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations Counter AF	155	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations Counter AL	155	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations This Read Vac	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	9 Month Operations	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	32483	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1L	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	2R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations This Read Vac	2	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations Counter AL	98	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations Counter AF	98	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations B Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations A Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps C Ø	58.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps B Ø	57.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps A Ø	59.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	9 Month Operations	3	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps B Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps C Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations A Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps A Ø	0.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	9 Month Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations This Read Vac	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations Counter AF	88	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations Counter AL	88	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	5R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	8R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	1R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	124005	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations This Read Vac	2	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations Counter AL	105	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations Counter AF	105	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps C Ø	9.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps B Ø	10.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps A Ø	9.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations A Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations B Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	9 Month Operations	10	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	9 Month Operations VCB New	8	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations A Ø	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations B Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations C Ø	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations Ground	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Maintenance Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations Counter AF	106	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations Counter AL	106	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps C Ø	71.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps B Ø	72.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps A Ø	73.0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	9 Month Operations	2	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations This Read Vac	1	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Switching Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Unknown Operations	0	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	General Comments		
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:32	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	5R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	8R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	1R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	124005	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	124005	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	1R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	2L	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments	no counter	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	3R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	2L	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	1R	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Unable to Reset	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	434	°F
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 14:11	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	34	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	75.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	71.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	29	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	10	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	13.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	14.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	26	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Found Counter	15476	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Left Counter	15476	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Operations Since Last Insp	800	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	General Comments	no nitrogen on ltc, has desicant	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	LTC Totalizer Reading	5166.72	kw
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Reading	.7176	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 13:20	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	189	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	189	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	173.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	153.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	175.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	1	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	153.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	150.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	155.0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	2	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	212	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	212	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	74503	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79203	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	74760	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	11525.76	kw
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2006	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	55	°C
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	33	°C
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments	turned heater on	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.3	VDC
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	large tree overhanging fence in front corner.	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 13:06	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Unknown Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AL	333	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AF	333	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Unknown Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AL	308	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AF	308	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AF	371	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AL	371	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Unknown Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AL	390	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AF	390	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AL	400	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AF	400	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AL	377	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AF	377	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps C Ø	30.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps B Ø	30.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps A Ø	30.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps C Ø	80.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps B Ø	80.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps A Ø	80.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AL	384	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AF	384	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps A Ø	570.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps B Ø	570.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps C Ø	570.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AF	378	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AL	378	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AL	410	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AF	410	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps C Ø	4.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps B Ø	4.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps A Ø	4.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	385	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	385	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	366	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	366	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps C Ø	140.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps A Ø	140.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps B Ø	140.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	368	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	368	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	175.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	451	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	451	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	175.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	175.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	512	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	512	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	467	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	467	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	12	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	244	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	244	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	350	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	400.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	400.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	400.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	3	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	350	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	228	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	228	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	4	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	12	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	14	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	190.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	190.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	190.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	32.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	32.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	32.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	4	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	4	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	208	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	208	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	70.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	217	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	180.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	217	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	180.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	180.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	215.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	215.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	549	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	549	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	215.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	243	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	243	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	238	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	238	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	55.0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	1	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	16	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	173.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	210.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	172.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	11.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	246	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1984	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	184.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	215.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	170.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	34	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	34	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	26	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	26	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	162.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	167.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	152.0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	11L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	92975	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	85747	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	5L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	43067	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	6L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6816.96	kw
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9468	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	179	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	88668	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	88668	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	6L	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Operation Checked?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	All Connections OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	.8870	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	2838.40	kw
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 11:56	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	78	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	99.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	61.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	51.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	56	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	58016	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64486	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	66569	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	46	°C
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	38	°C
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4370	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3448.80	kw
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	OK	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	106	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	10	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	81685	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	81685	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	OK	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	271	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	22431	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	22431	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
12/6/2023 11:20	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	40	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	60110	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	60	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	78	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro 6 pack	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	429	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45650	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33778	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45173	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2108	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2179.44	kw
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	255.00	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments	put spill kit in sub	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 10:44	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	69.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	32	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	55	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	87.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	68.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	94.0	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82955	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	75374	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Regulator As Left Counter	154525	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	23	°C
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5600	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3744.00	kw
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	42	°C
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	22	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	fence fabric and posts rustY	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments	heavy vegitation on and through fence.	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/6/2023 10:27	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	9.54	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	7.16	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	1.22	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	1.53	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	.31	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty A Ph V	3.05	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	9.54	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	13.71	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	13.71	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	8.35	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	7.75	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	.85	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	4.77	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations VCB New	12	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	1.26	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	1.48	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	1.48	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations VCB New	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.4	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.4	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations VCB New	2	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	2.98	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	6.56	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations This Read Vac	0	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations VCB New	1	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	4.77	%
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	107	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	107	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	431.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	507.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	443.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	1	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	4	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	159	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	159	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	284	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	284	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	762.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	2	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations VCB New	2	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	796.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	759.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	155	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	155	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations VCB New	6	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	6	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	100.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	110.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	200	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	200	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	110.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations VCB New	2	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	2	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	600.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	600.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	600.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	209	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	209	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations VCB New	25	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	25	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	3	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations VCB New	3	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	200.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	200.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	200.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	225	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	225	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	204	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	204	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	1	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations VCB New	1	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	80.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	80.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	80.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	13	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations VCB New	13	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	163	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	163	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	890.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	877.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	890.0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	19	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	19	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations VCB New	20	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	20	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	55	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	40	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	ok	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	253	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	106357	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	106357	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	50	°C
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/5/2023 12:35	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	32	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	1	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	1	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	194	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	216.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	220.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	194	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments	A,B IOC	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	195.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations VCB New	4	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	5	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	9 Month Operations GCB New	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	185.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	171.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	167.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	944	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	944	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	642	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	642	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	9	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	315.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	332.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	306.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	9 Month Operations GCB New	9	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	9 Month Operations GCB New	5	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	30.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	38.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	26.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments	VC-1357 not 1358	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1357	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1357	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	5	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	9 Month Operations GCB New	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	53.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	277	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	277	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	50.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	49.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	9 Month Operations GCB New	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	725	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	243.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	725	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	199.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	182.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	125	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	125	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations VCB New	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	155.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	106.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	105.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	183	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	183	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	124.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	110.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	160.0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations VCB New	0	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	528	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	183689	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	183689	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	794	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	139778	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	139778	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	62	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	31	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	62	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	62	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	58	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	31	°C
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	62	°C
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/6/2023 12:45	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments	ok	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/5/2023 13:52	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments	as left counter was entered wrong last 1/4 (JB corrected AL counter from 9/1/23)	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	396	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	14932	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	14920	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	1	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	194	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	194	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	7	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations VCB New	6	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	1.61	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	1.29	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations VCB New	2	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	1.29	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	2.25	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	1	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	76.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	72.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	203	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	203	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	1.61	%
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	124.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	76.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	1	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	87.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	3	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	1	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	87.0	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	716	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	14524	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	14524	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	202	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	202	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	7	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations VCB New	6	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments	switched for disconnect repair	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	193	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	1.61	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	2.25	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	1.61	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	151.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	1	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	121.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	130.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	102.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	108.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	108.0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	1.29	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	1.29	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	3	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	1	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	193	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	1	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	1	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	0	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments	operated for disconnect repair	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1471	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments	needs battery	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1799	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments	needs battery	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	841	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	41110	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	41110	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	373	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	40	°C
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	20	°C
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.5340	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	3844.80	kw
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 13:59	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	194	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.1	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	43.4	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	34.9	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	171	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments	phasing is backwards, A and C phases should be swapped	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	137	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	377604	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4246	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	206348	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	159.17	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	0	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	0	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	temp guage bad	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	152.88	kw
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7644	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	65	°C
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments	center phase of HV switch wire tied	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 13:48	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46538	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40596	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10476	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7920.00	kw
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8250	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	3	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	15.59	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	78.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	113.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	91.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations VCB New	8	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	11	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	19	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	19	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	3	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	328	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	328	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	138.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	160.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	132.0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	0	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments	SPR has been disabled	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/4/2023 13:22	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Unknown Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Switching Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations This Read Vac	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AL	194	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AF	194	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Maintenance Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations Ground	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations C Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations B Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations A Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps C Ø	12.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps B Ø	0.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps A Ø	0.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	9 Month Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Maintenance Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AF	163	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AL	162	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations This Read Vac	1	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Switching Operations	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Unknown Operations	1	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations Ground	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations C Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations B Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations A Ø	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps C Ø	15.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps B Ø	21.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps A Ø	10.0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	9 Month Operations	1	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Regulator As Left Counter	66776	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Regulator As Left Counter	170895	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Min Tap Position	5L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Regulator As Left Counter	245184	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.2694	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	48	°C
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	215.52	kw
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 12:57	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.9	VDC
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2004.48	kw
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2528	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	75	°C
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	152.50	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments	needs power to and new fan controls	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Blades	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	150.0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	110.0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	125.0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations VCB New	5	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	5	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	158	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	158	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	0	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	xfmr fuses are deteriorated	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments	needs yard light	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 11:58	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1474	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Found Counter	6539	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Left Counter	6539	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Operations Since Last Insp	521	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments	needs some oil	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.3540	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	90	°C
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	3398.40	kw
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Operations Counter	7	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps B Ø	84.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps C Ø	43.0	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	General Comments	counter entered wrong last time	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:45	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Positive DC Ground	13.4	VDC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.5	VDC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.4854	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	4659.84	kw
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	391	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	391	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	77.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	94.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	83.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Unknown Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Switching Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations This Read Vac	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AL	346	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AF	346	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Maintenance Operations	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations C Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations B Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations A Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations	1	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations VCB New	1	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps C Ø	93.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps B Ø	102.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps A Ø	96.0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	386	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	106623	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	106623	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.4910	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	4713.60	kw
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	no SPR	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 11:51	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.3	VDC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	3	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	18	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	18	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	203	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	203	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	15	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments	Breaker Open	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 11:08	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 11:06	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1514	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	895	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	10	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	96.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	108.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	100.0	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	507	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	23716	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	23716	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	4849.92	kw
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.5052	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 10:38	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	187961	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	88757	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	110413	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.6498	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	779.76	kw
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments	fence needs fixed in two spots from vandalism	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 10:31	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.1	VDC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.1	VDC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments	AF and AL float range cascade	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	49031	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	49038	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	661	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.5850	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	5616.00	kw
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	52	°C
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	62	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	3	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations VCB New	2	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	23.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	1	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	21.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	50.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	1	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	215	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	215	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	52.0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	9	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39647	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	10	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations VCB New	7	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	180.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	188.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	175.0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	1	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	1	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	1-BG, 1-CG	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	0	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	237	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	237	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	3	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	1	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36493	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	38388	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2819.52	kw
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5874	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2023 9:57	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	SPR removed from sertvice cascade	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments	no spare fuses in sub	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:52	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments	AF and AL float voltage range wrong in cascade	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.1	VDC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	690	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	11R	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	23225	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	23219	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.2988	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	2868.48	kw
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	110.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	100.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	105.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	194	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	194	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	155	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	155	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	0	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments	high side switch has burnt off arcing horn on one phase	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 9:29	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.8	VDC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	698385	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	698399	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	541	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.3984	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	1912.32	kw
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	204	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	204	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	30.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	64.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	61.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	3	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations VCB New	3	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	61.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	47.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	77.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	194	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	194	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	86.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	55.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	22.0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	175	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	175	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations VCB New	3	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	3	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments	fence at ditch area needs attn	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 9:21	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.4	VDC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments	AF and AL battery float range	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	507	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	17786	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	17780	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	3935.52	kw
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.5466	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments	Center fan not working	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	4	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	214	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	214	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations VCB New	4	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	32.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	41.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	34.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	45.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	39.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	65.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations VCB New	3	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	3	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	258	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	258	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	52117	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	45.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	75.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	52.0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations VCB New	5	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	7	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments	2-BG	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	26.86	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	210	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	210	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	2	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	2	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50289	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42172	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1336.32	kw
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5568	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	192	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	192	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	66.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	80.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	104.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	70.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	72.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	205	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	205	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	74.0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	0	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	Light	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:56	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.5	VDC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.300	millivolts
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	16011	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	3R	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	434	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	16000	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.5	psi
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	5402.88	kw
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.5628	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	2	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	2	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	272	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	272	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	2	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	180.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	120.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	60.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	7.0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	191	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	191	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	0	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 8:31	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.4	VDC
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.6	VDC
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	31380	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	121.4	volts
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	11L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	37396	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	24880	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	1L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	6L	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3546.72	kw
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4778	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	160.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	50.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	144	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	100.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	144	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations VCB New	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	5.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	5.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	225	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	225	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	60.0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments	Xfmr fuse barrels are frayed and whole station needs wildlife protection.	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2023 8:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.6078	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	38	°C
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	70	°C
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	4376.16	kw
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.8190	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	38	°C
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	7862.40	kw
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	All Connections OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Operation Checked?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	51137	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	1360	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	51130	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	All Connections OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Time Delay	45	Seconds
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Operation Checked?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	1L	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	4R	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	1101	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	19052	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	19046	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	541	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	541	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	92.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	95.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	124.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations VCB New	6	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	6	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations VCB New	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	8.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	9.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	15.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	219	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	219	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	192	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	192	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	110.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	110.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	113.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations VCB New	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Maintenance Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AF	204	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AL	204	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations This Read Vac	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Switching Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Unknown Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations Ground	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations C Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations B Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations VCB New	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations A Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps C Ø	97.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps B Ø	98.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps A Ø	86.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps B Ø	62.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps C Ø	67.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps A Ø	61.0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations VCB New	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations	1	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations A Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations B Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Unknown Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Switching Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations C Ø	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations Ground	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations This Read Vac	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AL	195	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AF	195	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Maintenance Operations	0	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	609	°F
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	Gap under fence in right hand corner. some posts show rust	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/1/2023 14:47	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.5880	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	33	°C
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	2822.40	kw
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	360350	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	360357	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	16L	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	1075	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	507	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	507	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	2	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations VCB New	2	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	187.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	217.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	172.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations VCB New	1	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	468	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	468	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	1	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	83.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	95.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	112.0	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2023 13:10	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	164.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	115.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	112.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	3	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Month Ops New	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	762	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	762	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	922	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	922	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	8	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Month Ops New	8	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	172.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	254.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	179.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	3	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	568	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	568	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations This Read AM	5	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	5	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Month Ops New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	4	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	8	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	903	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	903	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Month Ops New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	8	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	165.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	183.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	167.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Month Ops New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	432.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	546.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	517.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	369	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	369	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	932	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	9L	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	8R	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	5L	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	283447	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	283447	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	80	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	80	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	90	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	6.0	psi
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	2L	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	1L	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6L	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	65	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	86373	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	86373	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	90	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	90	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	35	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	70	°C
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	450.0	psi
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AL	54	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AF	54	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps C Ø	86.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps A Ø	90.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps B Ø	123.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	9 Month Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	9 Month Operations	6	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	9 Month Operations VCB New	3	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations This Read Vac	3	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AL	41	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AF	41	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	General Comments	A and B phase IOC	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations B Ø	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations A Ø	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps C Ø	244.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps B Ø	253.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps A Ø	207.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	9 Month Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps A Ø	119.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps B Ø	108.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps C Ø	110.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AF	63	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AL	63	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations Counter AL	19	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations Counter AF	19	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	9 Month Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps C Ø	105.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps B Ø	112.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps A Ø	123.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps A Ø	199.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps B Ø	123.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps C Ø	185.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations Counter AF	90	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations Counter AL	90	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	9 Month Operations	2	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations Counter AL	37	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations Counter AF	37	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps C Ø	736.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps B Ø	714.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps A Ø	740.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	9 Month Operations	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps A Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps B Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps C Ø	0.0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Maintenance Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AF	23	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AL	23	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Switching Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Unknown Operations	0	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	General Comments		
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 7:26	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	bottle at 300	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments	needs nitrogen	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 12:21	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	427	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	427	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	326.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	268.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	216.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations VCB New	11	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	11	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	212	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	212	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	32.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	44.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	30.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps C Ø	98.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps B Ø	115.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps A Ø	165.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AL	212	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AF	212	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations This Read Vac	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	330	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	330	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	191.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	211.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	214.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	3	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	200.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	180.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	170.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations This Read Vac	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations A Ø	1	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	99965	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	99965	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	2	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AL	71	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AF	71	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps C Ø	393.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps B Ø	417.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps A Ø	439.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	9 Month Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Operations Counter AL	154	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Operations Counter AF	154	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Amps B Ø	0.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Amps A Ø	0.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK000499	BreakerVacuum	069-BT6-5	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Operations Counter AL	194	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Operations Counter AF	194	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	9 Month Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Amps C Ø	293.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Amps B Ø	303.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Amps A Ø	317.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	KB0129	BreakerVacuum	069-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Amps B Ø	114.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Amps C Ø	105.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Switching Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Unknown Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Operations A Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Operations B Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Operations C Ø	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Fault Operations Ground	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Operations This Read Vac	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Operations Counter AL	150	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Maintenance Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Operations Counter AF	150	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Amps A Ø	126.0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	BK001824	BreakerVacuum	069-2327	VCB Readings	9 Month Operations	0	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	124685	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	124685	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	8L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	1L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	10L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	743	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Present	30	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Max	65	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Reading	.6798	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Present	40	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Max	65	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	LTC Totalizer Reading	12236.40	kw
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Present	40	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Max	55	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Reading	.4400	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Present	30	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Max	65	°C
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	LTC Totalizer Reading	7920.00	kw
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	684	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	10L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	2L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	8L	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	106758	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	106758	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 12:54	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Unknown Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Switching Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	9 Month Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Operations This Read Vac	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Operations Counter AL	156	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Operations Counter AF	156	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Maintenance Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Amps A Ø	286.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Amps B Ø	217.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Amps C Ø	256.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Operations A Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Operations B Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Operations C Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Fault Operations Ground	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001793	BreakerVacuum	829-2320	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Unknown Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Switching Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Operations This Read Vac	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Operations Counter AL	228	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Operations Counter AF	228	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Maintenance Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Operations Ground	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Operations C Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Operations B Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Operations A Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Amps C Ø	206.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Amps B Ø	215.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Amps A Ø	202.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Readings	9 Month Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001795	BreakerVacuum	829-2319	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Amps A Ø	76.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Amps B Ø	68.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Amps C Ø	88.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	9 Month Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Operations A Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Operations B Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Operations C Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Fault Operations Ground	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Maintenance Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Operations Counter AF	185	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Operations Counter AL	185	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Operations This Read Vac	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Switching Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Readings	Unknown Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BK001792	BreakerVacuum	829-2318	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps A Ø	560.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps B Ø	500.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps C Ø	560.0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations A Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations B Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations C Ø	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations Ground	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Maintenance Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AF	160	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AL	160	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations This Read Vac	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Unknown Operations	0	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Switching Operations	2	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	All Connections OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Operation Checked?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Min Tap Position	14L	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Operations Since Last Insp	998	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Found Counter	27888	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Left Counter	27888	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Max	70	°C
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Reading	.7854	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Present	50	°C
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	LTC Totalizer Reading	14137.20	kw
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Max	80	°C
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	General Comments		
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Vegetation	None	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/29/2023 9:27	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	15	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations Counter AF	360	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations Counter AL	360	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	General Comments	this is the correct vc	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	9 Month Operations VCB New	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	9 Month Operations	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.4	VDC
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.4	VDC
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	182	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	93736	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	93736	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments	6 pack empty needs nitro	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	181	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Current Tap Position	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Left Counter	82912	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Found Counter	82912	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	55	℃
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AL	208	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AF	208	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps C Ø	110.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps B Ø	110.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps A Ø	110.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AF	215	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations B Ø	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AL	215	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations This Read Vac	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps C Ø	125.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps B Ø	125.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps A Ø	125.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations	2	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AF	376	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AL	376	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations This Read Vac	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations B Ø	4	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps C Ø	120.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps B Ø	120.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps A Ø	120.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	9 Month Operations	6	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	9 Month Operations VCB New	5	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	9 Month Operations	5	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps A Ø	150.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps B Ø	150.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps C Ø	150.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AL	414	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AF	414	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AF	360	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AL	360	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps A Ø	3.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps B Ø	3.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps C Ø	3.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AF	362	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AL	362	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps C Ø	75.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps B Ø	75.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps A Ø	75.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	9 Month Operations	8	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	9 Month Operations VCB New	8	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AL	365	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AF	365	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps A Ø	200.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps B Ø	200.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps C Ø	200.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	9 Month Operations	56	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	9 Month Operations VCB New	54	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps A Ø	100.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps B Ø	100.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps C Ø	100.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps A Phase V	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations A Ø	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations C Ø	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AF	413	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AL	413	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations This Read Vac	2	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations Counter AF	364	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations Counter AL	364	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations This Read Vac	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations B Ø	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	9 Month Operations VCB New	5	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	9 Month Operations	6	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps C Ø	8.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps B Ø	8.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps A Ø	8.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps C Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps B Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations Counter AF	356	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations Counter AL	356	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps A Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	9 Month Operations	2	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps C Ø	470.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps B Ø	470.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps A Ø	460.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations Counter AL	366	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations Counter AF	366	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps C Ø	420.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps A Ø	420.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps B Ø	420.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations Counter AF	378	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations Counter AL	378	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Operations C Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Operations Counter AF	342	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Operations Counter AL	342	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Amps C Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Amps B Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Amps A Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	9 Month Operations	1	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Maintenance Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Operations Counter AF	336	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Operations Counter AL	336	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Switching Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Readings	Unknown Operations	0	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments		
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptible	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/29/2023 4:54	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AL	70	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AF	70	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Maintenance Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps A Ø	400.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps B Ø	400.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps C Ø	400.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	277	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	277	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	274	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	274	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	400.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	400.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	400.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations VCB New	4	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	4	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	68	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	100.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	68	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	100.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	100.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	61	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	200.0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations VCB New	2	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	2	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	61	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	20	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	30	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	20	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	30	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	1255	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	9L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	1L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	6L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	170667	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	170667	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	35	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	65	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	10669.52	kw
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.7001	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	60	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	20	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	955701	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	955701	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	156	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.6861	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	10456.16	kw
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	311606	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	311606	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	5L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	2L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	594	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	40	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	65	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Reading	.6823	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	LTC Totalizer Reading	10398.25	kw
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 15:18	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps C Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AF	174	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps C Ø	506	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps B Ø	536	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps A Ø	501	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	9 Month Operations	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AL	174	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AL	149	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AF	149	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps C Ø	166	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps B Ø	167	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps A Ø	157	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	9 Month Operations	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AL	99937	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AF	99937	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps C Ø	168	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps B Ø	180	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps A Ø	166	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations VCB New	4	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations	4	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99886	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99886	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AF	151	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations	25	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AL	151	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations VCB New	25	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	13.66	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	13.66	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	13.66	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	169	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	187	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	170	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	127	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	127	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations	1	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps A Ø	530	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps B Ø	559	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps C Ø	524	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations A Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations This Read Vac	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99914	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99914	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations B Ø	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	17488	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	17488	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	6L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	11L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	686	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Output Voltage Level	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.7828	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	20	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	50	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	11929.87	kw
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	25	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	55	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Output Voltage Level	119	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AF	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AL	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	563	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	12L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	2L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	8L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	101975	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	101975	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	30	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	45	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	.4544	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	6925.06	kw
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Max	40	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Present	25	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Output Voltage Level	119	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AF	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AL	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Found Counter	221506	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Left Counter	221506	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	5L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	1L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	11L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	167	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	145	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	30	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	70	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	.8189	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	12480.04	kw
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	450	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	136983	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	136983	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	7082.03	kw
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	All Connections OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Output Voltage Level	119	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AF	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AL	120	VAC
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	.4647	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	45	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	145	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments	Customer fence tied to our fence	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 15:02	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Ambient Temperature	31	°F
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 3	84	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 2	84	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 1	84	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	9 Month Operations GCB New	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Fault Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Maintenance Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AF	17	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AL	17	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Switching Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations This Read SF6	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations This Read Vac	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	182	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	182	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	336.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	356.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	355.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Unknown Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Switching Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations This Read Vac	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AL	198	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AF	198	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Maintenance Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	114.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	126.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	125.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations VCB New	2	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	2	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations This Read Vac	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	200	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	200	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Maintenance Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations Ground	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations C Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations B Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations A Ø	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps C Ø	208.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps A Ø	205.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps B Ø	218.0	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	10793	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	487	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments	no nitrogen on LTC	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	30	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	.4090	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	29	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	29	°C
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	9816.00	kw
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.3	VDC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.3	VDC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.1	VDC
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/28/2023 12:49	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations This Read Vac	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	217	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	466.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	498.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	217	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	492.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Operations Ground	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Operations A Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Maintenance Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Amps C Ø	82.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Amps B Ø	87.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Amps A Ø	105.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Operations Counter AF	167	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Operations Counter AL	167	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Switching Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Unknown Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	9 Month Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Readings	Operations This Read Vac	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK001821	BreakerVacuum	545-2324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations This Read Vac	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Switching Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Unknown Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AL	238	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AF	238	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Maintenance Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations Ground	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations A Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	9 Month Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps C Ø	73.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps B Ø	55.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps A Ø	74.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps A Ø	269.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations VCB New	3	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations	4	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps B Ø	322.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps C Ø	314.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Unknown Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Switching Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations This Read Vac	1	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AL	221	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AF	221	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Maintenance Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations A Ø	1	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations Ground	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps A Ø	59.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps B Ø	62.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Unknown Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Switching Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations This Read Vac	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AL	376	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AF	376	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps C Ø	63.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations A Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Maintenance Operations	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations Ground	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	All Connections OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Found Counter	23718	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Left Counter	23178	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Min Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Operations Since Last Insp	877	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Max	65	°C
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Reading	.6444	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Max	65	°C
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	LTC Totalizer Reading	11599.20	kw
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	257	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	257	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1044	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1044	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	1.12	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	1.12	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	1.12	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.7	VDC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.3	VDC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.02	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.02	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.02	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	917	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	917	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	398	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	4.44	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	398	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	4.44	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	4.44	%
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:08	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	355	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	355	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.98	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.98	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.98	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	200.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	794	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	8.05	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	8.05	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	8.05	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	930	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	930	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	312	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	312	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø	60.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø	60.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø	60.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4517	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4517	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	85.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	125.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	120.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	4.07	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	10.18	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	26.48	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11589	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	85.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	8.15	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	8.15	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	8.15	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	112.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	125.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11589	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	140.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	6.65	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	5.54	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	4.44	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	1	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Month Ops New	1	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	110.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	120.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	394	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	394	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	425	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	425	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Month Ops New	6	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	6	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	1.11	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	1.11	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	130.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	95.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	4.44	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	4.44	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	7.76	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	1	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Month Ops New	1	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	534	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	534	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	35.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	25.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	40.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	6.87	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	5.5	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	6.87	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	275	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	275	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2559	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	2.04	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	2.04	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2559	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	2.04	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	130.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	85.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	2.23	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	2.23	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	2.23	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4991	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4991	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	750	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	750	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1134	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1134	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	80.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	80.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	100.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	3.38	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	3.38	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	3.38	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	90.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	849	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	120.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	849	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	80.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	803	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	803	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations This Read AM	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Month Ops New	0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	5.63	%
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments	will fill tist afternoon or tomorrow	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments	part of roof fell in	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	729	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	16168	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	16168	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	started filter and reset alarm	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	559	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	101820	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	101820	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments	tree limbs overhanging fence	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 11:04	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	204	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	204	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AL	218	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AF	218	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	General Comments	DNO	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps C Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps B Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps A Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps B Ø	121.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps C Ø	118.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps A Ø	123.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations VCB New	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AF	251	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AL	251	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AL	162	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AF	162	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps C Ø	1.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps B Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps A Ø	0.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps A Ø	168.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps B Ø	175.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps C Ø	161.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AF	156	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AL	156	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations VCB New	6	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations	6	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AL	158	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AF	158	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps A Ø	1.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps B Ø	1.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps C Ø	1.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps C Ø	276.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps B Ø	293.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps A Ø	283.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AF	162	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AL	162	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	188	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	170	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	199	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	674	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Found Counter	61387	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Left Counter	61387	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	122786	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	9	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	15	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments	counter entered wrong last check	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	68593	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Gauge(s) Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1014	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Left Counter	65339	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Found Counter	65339	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	67	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	25	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Present	23	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Max	23	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	27	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	119821	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments	counter entered wrong last check	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Ambient Temp	26	°F
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1464.48	kw
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6102	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	General Comments	A and B phase IOC	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AF	103	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AL	103	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations This Read Vac	4	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations A Ø	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations B Ø	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	9 Month Operations	7	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	9 Month Operations VCB New	3	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps A Ø	83.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps B Ø	88.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps C Ø	86.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps C Ø	176.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps B Ø	171.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps A Ø	172.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	9 Month Operations VCB New	12	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	9 Month Operations	14	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations A Ø	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations B Ø	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	General Comments	A and B phase iOC	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AF	77	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AL	77	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations This Read Vac	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	9 Month Operations	1	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps A Ø	128.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps B Ø	128.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps C Ø	126.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations Counter AF	54	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations Counter AL	54	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Unknown Operations	0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations This Read Vac	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AL	38	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AF	38	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	General Comments	C phase IOC	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps B Ø	132.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps A Ø	105.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations C Ø	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps C Ø	107.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	9 Month Operations	2	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps C Ø	223.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps B Ø	224.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps A Ø	240.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations Counter AF	48	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations Counter AL	48	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps C Ø	684.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps B Ø	697.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	9 Month Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps A Ø	691.0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	General Comments		
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AF	47	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AL	47	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Switching Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Unknown Operations	0	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:20	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	General Comments		
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	199	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/28/2023 10:18	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	General Comments	BATTERY WATER FROZEN	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	54.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	54.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	54.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	209	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	209	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	2	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AF	131	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AL	131	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations	20	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations VCB New	20	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps A Ø	221.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps B Ø	131.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps C Ø	141.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AF	291	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AL	291	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AF	309	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AL	309	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations	5	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations VCB New	5	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps A Ø	217.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps B Ø	233.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps C Ø	190.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AF	160	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AL	160	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps C Ø	196.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps B Ø	206.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps A Ø	206.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps A Ø	190.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps B Ø	190.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps C Ø	186.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AF	210	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AL	210	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps A Ø	817.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps B Ø	772.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps C Ø	696.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AL	179	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AF	179	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Unknown Operations	4	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations This Read Vac	4	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AL	63	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AF	63	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations	12	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations VCB New	8	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps C Phase V	44.72	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AF	662	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AL	662	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Unknown Operations	2	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations This Read Vac	2	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AL	79	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AF	79	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations VCB New	8	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations	10	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AL	670	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AF	670	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations VCB New	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AL	819	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AF	819	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations B Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations VCB New	3	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations	3	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF001289	PowerFuse	BY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF001289	PowerFuse	BY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Unknown Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Switching Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps A Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AL	435	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AF	453	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps B Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps C Ø	0.0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1199	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Found Counter	49754	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Left Counter	49754	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	9	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	26	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	57	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	57	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	57	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Present	23	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Max	54	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	General Comments	ok	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1402	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Found Counter	145075	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Left Counter	145075	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15R	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	22	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Present	22	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	4750	psi
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Ambient Temp	20	°F
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 9:55	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations This Read SF6	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AL	62	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AF	62	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Num Operations Last 9 Months	2	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	9 Month Operations GCB New	2	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Fault Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Ambient Temperature	33	°F
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	General Comments	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations C Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations B Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations A Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps C Ø	624.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps B Ø	642.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps A Ø	471.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations Ground	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AF	183	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AL	183	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations	7	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations VCB New	7	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations This Read Vac	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Unknown Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Unknown Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations This Read Vac	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AL	215	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AF	215	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations C Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations B Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations A Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps C Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps B Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps A Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations VCB New	8	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations	8	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Unknown Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations This Read Vac	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AL	215	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AF	215	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations Ground	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations C Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations B Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations A Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps C Ø	0.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps B Ø	0.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps A Ø	0.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations VCB New	1	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations	1	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations	10	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations VCB New	6	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps A Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps B Ø	120.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps C Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps A Phase V	17.75	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps B Phase V	17.75	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps C Phase V	17.75	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations B Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations C Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations Ground	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AF	513	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AL	513	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations This Read Vac	4	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Unknown Operations	4	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps C Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps B Ø	120.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps A Ø	180.0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations VCB New	23	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations	23	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations A Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations B Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations C Ø	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations Ground	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Maintenance Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AF	83	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AL	83	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations This Read Vac	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Switching Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Unknown Operations	0	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	All Connections OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Operations Since Last Insp	5320	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Max Tap Position	11R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Current Tap Position	5R	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Left Counter	161103	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Found Counter	161103	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	19	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.3	psi
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Totalizer Reading	13578.84	kw
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Max	45	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Reading	.8910	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Present	35	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Operation Checked?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	All Connections OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Found Counter	75337	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Left Counter	75337	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Min Tap Position	1L	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Operations Since Last Insp	1458	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Reading	.8982	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	LTC Totalizer Reading	8622.72	kw
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.5	amps
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	General Comments		
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Vegetation	None	
11/28/2023 7:14	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Left Counter	64215	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Found Counter	157792	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	General Comments	V/C 64215 MAY HAV BEEN CHANGED OUT	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty A Ph V	4.17	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	9 Month Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations This Read Vac	2	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AL	116	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty B Ph V	4.17	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty C Ph V	4.17	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AF	116	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps B Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps C Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AF	103	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AL	103	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations This Read Vac	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	122	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	122	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	General Comments	A/B TOC AND IOC	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations Counter AF	173	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations Counter AL	173	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations B Ø	5	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations A Ø	5	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps B Phase V	55.90	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps A Phase V	55.90	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps C Ø	87.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps B Ø	52.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps A Ø	60.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty C Ph V	8.94	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty B Ph V	11.93	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty A Ph V	12.52	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	9 Month Operations VCB New	11	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	9 Month Operations	21	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations This Read Vac	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AL	106	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AF	106	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps C Ø	32.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps B Ø	21.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps A Ø	28.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty C Ph V	5.37	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	9 Month Operations	1	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations This Read Vac	10	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	9 Month Operations	6	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	9 Month Operations VCB New	4	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty A Ph V	.15	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty B Ph V	.08	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty C Ph V	.04	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps A Ø	59.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps B Ø	66.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps C Ø	62.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps A Phase V	.35	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps C Phase V	.35	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations A Ø	1	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations C Ø	1	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps C Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps B Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps A Ø	0.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty C Ph AM	15.66	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty B Ph AM	15.66	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty A Ph AM	15.66	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Months Operations	13	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Month Ops New	13	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Month Ops New	20	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Months Operations	20	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty A Ph AM	38.55	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty B Ph AM	33.73	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty C Ph AM	37.34	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps A Ø	141.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps B Ø	134.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps C Ø	132.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AF	276	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AL	276	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AL	63	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AF	63	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AF	35	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AL	35	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Month Ops New	24	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Months Operations	24	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	32.52	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	40.95	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	31.32	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps A Ø	140.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps B Ø	137.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps C Ø	130.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AF	154	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AL	154	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps C Ø	429.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps B Ø	447.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps A Ø	445.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	54.58	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	54.58	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	54.58	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Months Operations	20	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Month Ops New	20	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AL	760	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AF	760	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AL	232	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations This Read AM	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AF	232	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty A Ph AM	26.5	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty C Ph AM	25.29	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps A Ø	75.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Months Operations	10	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Month Ops New	10	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Month Ops New	22	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Months Operations	22	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	34.93	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	36.14	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	33.73	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps A Ø	86.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps B Ø	97.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps B Ø	81.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps C Ø	86.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps C Ø	75.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AL	43	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AF	43	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Switching Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Unknown Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Maintenance Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps C Ø	110.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps B Ø	82.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations	1	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps A Ø	109.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations VCB New	1	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps A Ø	245.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps B Ø	243.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps C Ø	208.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Maintenance Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AF	245	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AL	245	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Switching Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Unknown Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations	2	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Maintenance Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AF	303	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AL	303	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Switching Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Unknown Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations	2	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps A Ø	194.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps B Ø	207.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps C Ø	216.0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Regulator As Left Counter	43846	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Current Tap Position	1R	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Regulator As Left Counter	44444	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Regulator As Left Counter	39327	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5742.72	kw
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Max	35	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5982	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Present	15	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Operations Since Last Insp	896	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Current Tap Position	1R	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Left Counter	61137	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Found Counter	61137	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Reading	1.2510	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	LTC Totalizer Reading	9007.20	kw
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	40	°F
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations	5	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations VCB New	4	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps A Ø	65.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps B Ø	77.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps C Ø	119.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations A Ø	1	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Maintenance Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AF	193	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AL	193	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations This Read Vac	1	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Switching Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AL	262	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AF	262	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps A Ø	577	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps B Ø	629	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps C Ø	617	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Maintenance Operations	0	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AL	312	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AF	312	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	General Comments		
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Vegetation	None	
11/27/2023 15:28	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AF	317	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AL	317	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	7	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	164.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	124.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	175.0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations VCB New	17	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	17	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	300	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	300	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps C Ø	300	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps B Ø	300	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps A Ø	300	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	9.61	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AF	490	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AL	490	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty B Ph V	15.38	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty A Ph V	4.8	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations VCB New	11	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations	11	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Unknown Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	.45	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	210	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	237	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	210	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	327	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	327	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	991	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	114734	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	114734	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AF	272	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AL	272	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps C Ø	356	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps B Ø	352	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps A Ø	350	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	268	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	279	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	289	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations VCB New	8	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	8	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	1.83	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AL	331	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AF	331	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	100	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	3.57	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	3.13	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	3.13	%
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations VCB New	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	7	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	377	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	377	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Found Counter	914734	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Left Counter	914734	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Current Tap Position	1R	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Max Tap Position	8R	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Min Tap Position	14L	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Operations Since Last Insp	16992	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Num Operations Last 9 Months	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations Counter AF	147	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations Counter AL	147	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations This Read SF6	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	9 Month Operations GCB New	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Fault Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Ambient Temperature	32	°F
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	General Comments	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Pressure	68	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	7175.52	kw
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	.9966	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	LTC Totalizer Reading	17884.8	kw
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Reading	1.242	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Present	35	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	°F
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Left Counter	77415	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Found Counter	77415	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Operations Since Last Insp	1432	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	General Comments		
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:19	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	16142.4	kw
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	80	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	1.121	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Max	75	°C
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1000	psi
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129	VDC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	General Comments		
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Vegetation	None	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/27/2023 15:18	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations This Read Vac	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Switching Operations	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations Counter AL	115	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations Counter AF	115	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	9 Month Operations VCB New	4	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	9 Month Operations	5	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations Counter AF	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations Counter AL	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	9 Month Operations	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations Counter AL	136	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations Counter AF	136	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps C Ø	418.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps B Ø	407.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps A Ø	417.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	9 Month Operations VCB New	24	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	9 Month Operations	24	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations Counter AF	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations Counter AL	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps C Ø	233.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps B Ø	230.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps A Ø	235.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	9 Month Operations	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps A Ø	120.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps B Ø	80.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps C Ø	118.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Switching Operations	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations This Read Vac	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations Counter AL	107	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations Counter AF	107	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	9 Month Operations	3	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps A Ø	193.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps C Ø	201.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps B Ø	220.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations Counter AF	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations Counter AL	116	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations This Read Vac	4	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Switching Operations	4	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	9 Month Operations	6	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	9 Month Operations	3	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	9 Month Operations VCB New	3	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations Counter AL	91	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations Counter AF	91	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	9 Month Operations	29	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	9 Month Operations VCB New	27	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Switching Operations	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations This Read Vac	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations Counter AL	117	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations Counter AF	117	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps B Ø	90.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps C Ø	59.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations Counter AL	127	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations Counter AF	127	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps A Ø	55.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	9 Month Operations VCB New	8	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	9 Month Operations	8	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps A Ø	193.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps B Ø	144.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps C Ø	195.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	9 Month Operations VCB New	2	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	9 Month Operations	5	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations A Ø	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations B Ø	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations C Ø	1	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations Counter AF	117	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations Counter AL	117	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations This Read Vac	3	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	9 Month Operations VCB New	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	9 Month Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations Counter AF	118	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations Counter AL	118	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations	16	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations VCB New	16	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty A Ph V	3.14	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty B Ph V	3.84	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty C Ph V	1.4	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps A Ø	34	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps B Ø	46	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps C Ø	35	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Switching Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AL	206	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AF	206	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps B Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps A Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations Counter AF	113	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Unknown Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Switching Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps C Ø	0.0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations Counter AL	113	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	9 Month Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	9 Month Operations VCB New	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Maintenance Operations	0	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Switching Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AL	210	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AF	210	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Maintenance Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations	6	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations VCB New	6	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps C Ø	25	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps B Ø	11	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps A Ø	26	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty A Ph V	1.05	%
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps A Ø	114	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps B Ø	125	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps C Ø	141	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty C Ph V	1.54	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty B Ph V	1.54	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations VCB New	12	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations	12	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AL	286	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Switching Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Maintenance Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AF	286	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC As Found Counter	4775	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC As Left Counter	4775	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Current Tap Position	6R	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Max Tap Position	8R	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Min Tap Position	3L	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Operations Since Last Insp	593	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Switching Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AF	301	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Maintenance Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps C Ø	186	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps B Ø	160	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps A Ø	155	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty C Ph V	.77	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AL	301	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty B Ph V	.77	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty A Ph V	1.54	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations VCB New	9	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations	9	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations Ground	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations C Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations B Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations A Ø	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Maintenance Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AF	282	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AL	282	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations This Read Vac	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Switching Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Unknown Operations	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps C Ø	185	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps B Ø	156	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps A Ø	173	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty C Ph V	2.1	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty B Ph V	4.19	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty A Ph V	5.24	%
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations VCB New	9	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations	9	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Winding Temp Present	20	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Winding Temp Max	60	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Totalizer Meter Reading	.2430	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Oil Temp Present	20	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	LTC Totalizer Reading	5832.00	kw
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28832	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28819	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC As Left Counter	2125	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC As Found Counter	2125	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Operations Since Last Insp	666	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Min Tap Position	3L	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Max Tap Position	8R	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Current Tap Position	6R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30475	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Reading	.69	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2208	kw
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Totalizer Meter Reading	.4345	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Oil Temp Max	35	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	LTC Totalizer Reading	10428.00	kw
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X3 Winding Temp Present	21	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X3 Winding Temp Max	36	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X1 Winding Temp Max	36	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X1 Winding Temp Present	21	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X2 Winding Temp Max	36	°C
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X2 Winding Temp Present	21	°C
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Operation Checked?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	All Connections OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Found Counter	44409	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Left Counter	44409	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Current Tap Position	2R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Max Tap Position	4R	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Min Tap Position	7L	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Operations Since Last Insp	1187	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Ambient Temperature	32	°F
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Pressure	66	psi
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	General Comments	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Max	80	°C
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	LTC Totalizer Reading	5779.2	kw
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Reading	.602	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	32	°F
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Vegetation	None	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	General Comments		
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/27/2023 15:06	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/27/2023 15:17	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Foundation Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Tank Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushing Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps B Ø	96.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps A Ø	99.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps C Ø	115.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations A Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations B Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations C Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations Ground	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	9 Month Operations VCB New	2	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	9 Month Operations	2	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Maintenance Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AF	202	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AL	202	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations This Read Vac	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Switching Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Unknown Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushing Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Foundation Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Tank Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Maintenance Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AF	167	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations B Ø	1	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AL	167	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations This Read Vac	1	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Switching Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	9 Month Operations	5	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	9 Month Operations VCB New	4	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps A Ø	92.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations Ground	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps C Ø	93.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps B Ø	79.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Unknown Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations C Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	11	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations VCB New	11	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	41.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	63.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	45.0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	568	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	568	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations This Read Vac	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Operation Checked?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	All Connections OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	545	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	14547	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	14547	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	0	°C
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	0	°C
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.5910	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	5673.60	kw
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.8	VDC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/21/2023 14:34	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Switching Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations This Read Vac	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AL	195	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AF	196	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Maintenance Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	267.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	259.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	261.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations Ground	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations C Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations B Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations A Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	397.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	414.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	418.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations A Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations B Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations C Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations Ground	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Maintenance Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AF	181	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AL	181	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations This Read Vac	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Switching Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Unknown Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C Ø	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	328	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	328	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations This Read Vac	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AF	124.5	VAC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Operation Checked?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	All Connections OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	88414	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	88414	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	399	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.5400	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	44	°C
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	64	°C
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	7392.00	kw
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/20/2023 14:12	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Adjusted Amps C Phase V	55.90	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Adjusted Amps B Phase V	55.90	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Fault Adjusted Amps A Phase V	55.90	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Operations Counter AF	118	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Amps C Ø	58.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Amps B Ø	49.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Amps A Ø	49.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	9 Month Operations VCB New	3	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	9 Month Operations	8	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Amps A Ø	173.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Amps B Ø	156.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations	2	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps A Ø	79.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps B Ø	67.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps C Ø	62.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	9 Month Operations	2	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	9 Month Operations VCB New	2	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Amps A Ø	40.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Amps B Ø	36.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Amps C Ø	32.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AF	138	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AL	138	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Amps C Ø	148.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Unknown Operations	5	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Operations Counter AF	37	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Operations Counter AL	37	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Operations This Read Vac	5	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Operations Counter AL	21	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Operations Counter AF	21	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Fault Adjusted Amps C Phase V	44.72	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Unknown Operations	4	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Operations This Read Vac	4	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Readings	Operations Counter AL	118	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	All Connections OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Operation Checked?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Found Counter	48663	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Left Counter	48663	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Operations Since Last Insp	854	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	58	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	27	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Present	22	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Max	51	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	LTC Totalizer Reading	12813.12	kw
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Reading	.8898	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Max	58	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Switching Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations This Read Vac	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AL	250	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Unknown Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AF	250	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Maintenance Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations Ground	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations C Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations B Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations A Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations	6	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations VCB New	6	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps A Ø	197.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps B Ø	227.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps C Ø	215.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Unknown Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Switching Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations This Read Vac	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AL	268	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AF	268	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Maintenance Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations Ground	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations C Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations B Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations A Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps C Ø	45.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps B Ø	49.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps A Ø	44.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations	5	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations VCB New	5	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations	5	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations VCB New	3	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps A Ø	68.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps B Ø	111.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps C Ø	73.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations A Ø	1	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations B Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations C Ø	1	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations Ground	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Maintenance Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AF	180	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AL	180	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations This Read Vac	2	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Switching Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Unknown Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps A Ø	305.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps B Ø	367.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps C Ø	327.0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations A Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations B Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations C Ø	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Unknown Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Switching Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations This Read Vac	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AL	158	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AF	158	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Maintenance Operations	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations Ground	0	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	45	°F
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.3	VDC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	General Comments	Work order for + ground. All positive posts cleaned of corrosion.	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Negative DC Ground	53.4	VDC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Vegetation	None	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	General Comments		
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2023 12:13	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Operations Counter	15	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps A Ø	102.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Operations Counter	1802	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Operations Counter	2007	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	All Connections OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Operation Checked?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Found Counter	74354	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Left Counter	74354	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Operations Since Last Insp	614	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	LTC Totalizer Reading	4308.48	kw
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Max	52	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Present	24	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Reading	.4488	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Present	22	°C
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Vegetation	None	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	General Comments		
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/20/2023 10:38	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations This Read Vac	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	227	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps A Ø	95.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps B Ø	103.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps C Ø	112.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	227	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	255	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	255	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations This Read Vac	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	52.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	42.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	34.0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations VCB New	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	0	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Foundation Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	All Connections OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Operation Checked?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	1012	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	310125	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	310125	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Present	19	°C
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	LTC Totalizer Reading	3646.08	kw
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Reading	.5064	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.4	VDC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	General Comments	Positive posts had corrosion. posts were cleaned	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.4	VDC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Positive DC Ground	20.5	VDC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	51.5	VDC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	51.5	VDC
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	General Comments		
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2023 9:58	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Vegetation	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	918	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	918	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps B Ø	66.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps A Ø	64.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps C Ø	68.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AF	191	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AL	191	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps A Ø	58.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps B Ø	68.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps C Ø	91.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AL	132	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AF	132	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AL	620	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AF	620	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps C Ø	210.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps B Ø	199.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps A Ø	205.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	filter needs replaced	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	15L	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Left Counter	19010	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Found Counter	19010	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	761	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	75	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	1 fan not working	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Left Counter	19338	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Found Counter	19338	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	874	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Amps A Ø	258.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Amps B Ø	270.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Amps C Ø	219.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	9 Month Operations	1	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Operations Counter AF	18	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Operations Counter AL	18	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002114	BreakerVacuum	FA-12KV TR 1	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002115	BreakerVacuum	FA-1123	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002116	BreakerVacuum	FA-1148	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002117	BreakerVacuum	FA-1149	VCB Patrol Inspection	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	9 Month Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	9 Month Operations VCB New	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Amps A Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Amps B Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Amps C Ø	0.0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Operations A Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Operations B Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Operations C Ø	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Fault Operations Ground	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	General Comments		
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Maintenance Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Operations Counter AF	13	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Operations Counter AL	13	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Unknown Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Switching Operations	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Readings	Operations This Read Vac	0	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Patrol Inspection	Follow-up Action Required?	n	
11/29/2023 7:38	Distribution	Farnsley Quarterly Inspection	BK002118	BreakerVacuum	FA-1150	VCB Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps B Ø	120	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps A Ø	120	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty B Ph V	2.1	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations VCB New	4	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations	4	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Unknown Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Switching Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps C Ø	120	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AF	362	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AL	362	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations	7	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations VCB New	7	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Unknown Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Switching Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AL	124	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps A Ø	80	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps B Ø	80	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps C Ø	80	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AF	124	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Maintenance Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps C Ø	60	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Maintenance Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AF	445	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AL	445	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Switching Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Unknown Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps B Ø	60	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps A Ø	60	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty A Ph V	1.05	%
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations VCB New	4	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations	4	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Regulator As Left Counter	85338	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	General Comments	Needs control changed out	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Follow-up Action Required?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Regulator As Left Counter	97126	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	General Comments	Needs control changed out	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5873	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Min Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	General Comments	needs control changed out	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Follow-up Action Required?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Unknown Operations	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Switching Operations	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AL	205	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AF	205	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Maintenance Operations	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps C Ø	21	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps B Ø	39	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps A Ø	41	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations VCB New	9	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations	9	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations	6	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations VCB New	6	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps C Ø	65	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps B Ø	75	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps A Ø	59	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty C Ph V	2.61	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Maintenance Operations	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AF	212	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AL	212	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Switching Operations	0	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Unknown Operations	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.04	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Present	65	°C
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2496	kw
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	All Connections OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Operations Since Last Insp	382	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Left Counter	272016	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Found Counter	272016	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:19	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:24	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	129	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	105	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps B Ø	30.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	130	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	91	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	84	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	64	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52978	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13194	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Regulator As Left Counter	104545	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6480	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1166.40	kw
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Maintenance Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AF	186	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AL	186	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Switching Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Unknown Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps C Ø	47	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps B Ø	49	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps A Ø	47	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	9 Month Operations	0	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	9 Month Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Switching Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Unknown Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps A Ø	64	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps B Ø	80	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps C Ø	79	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps C Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Maintenance Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AF	192	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AL	192	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:16	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps A Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps B Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps C Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Unknown Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Switching Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AL	407	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AF	407	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Maintenance Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Unknown Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps A Ø	138	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps B Ø	137	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps C Ø	136	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Maintenance Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AF	344	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AL	344	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Switching Operations	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Regulator As Left Counter	72320	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Maintenance Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AF	377	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AL	377	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Switching Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Unknown Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps C Ø	60	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps B Ø	60	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps A Ø	60	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty C Ph V	3.46	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty B Ph V	4.84	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty A Ph V	4.84	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations	3	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations VCB New	3	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Regulator As Left Counter	28057	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty A Ph V	1.29	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty B Ph V	1.29	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty C Ph V	1.29	%
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps A Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps B Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps C Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations A Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations B Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations C Ø	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations Ground	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Maintenance Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AF	216	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AL	216	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations This Read Vac	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Switching Operations	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Regulator As Left Counter	66488	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Reading	.947	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	LTC Totalizer Reading	9091.2	kw
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5172	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1241.28	kw
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	All Connections OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.5	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Found Counter	260772	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Left Counter	260772	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Operations Since Last Insp	150	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Regulator As Left Counter	160082	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Regulator As Left Counter	210612	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Regulator As Left Counter	20321	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Operations Counter	31	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1080	kw
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Reading	.45	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps B Ø	41.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps C Ø	43.0	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Operations Counter	17	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129	VDC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2023-05-11 00:00:00.000000000	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 14:13	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 14:12	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Regulator As Left Counter	134228	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Max Tap Position	7R	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Current Tap Position	3R	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Regulator As Left Counter	157349	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Max Tap Position	14R	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Regulator As Left Counter	8764	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5340	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2563.20	kw
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.0	VDC
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 14:08	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	4.14	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	4.14	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	4.14	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AF	170	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AL	170	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	14.6	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	14.6	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	14.6	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	4	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	239	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	239	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AL	124	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AF	124	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations VCB New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AF	183	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AL	183	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty C Ph V	15.46	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty B Ph V	15.46	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty A Ph V	15.46	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	9 Month Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AF	163	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AL	163	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps B Ø	43.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps C Ø	46.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps A Ø	46.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty C Ph V	20.61	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty B Ph V	29.2	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty A Ph V	30.92	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations VCB New	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AF	225	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AL	225	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty A Ph V	6.01	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations VCB New	4	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations	5	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps A Ø	156.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps B Ø	157.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps C Ø	157.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AF	148	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AL	148	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations This Read Vac	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Unknown Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AL	125	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AF	125	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty B Ph V	3.44	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps C Ø	206.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps B Ø	211.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps A Ø	213.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty C Ph V	7.73	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations VCB New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	9 Month Operations VCB New	5	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	9 Month Operations	5	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AL	170	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AF	170	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps A Ø	403.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps B Ø	398.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps C Ø	400.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001271	PowerFuse	MD-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001271	PowerFuse	MD-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF001271	PowerFuse	MD-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations VCB New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps A Ø	308.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps B Ø	315.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps C Ø	305.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations This Read Vac	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AL	167	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AF	167	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AF	16	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AL	16	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	2.25	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	2.25	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	2.25	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps C Ø	101.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps B Ø	101.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps A Ø	105.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Months Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Month Ops New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AL	618	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AF	618	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AF	518	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AL	518	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps C Ø	118.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps B Ø	118.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps A Ø	121.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty C Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty B Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty A Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Months Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Month Ops New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Month Ops New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Months Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty A Ph AM	4.58	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty B Ph AM	4.58	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty C Ph AM	3.81	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps A Ø	104.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps B Ø	102.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps C Ø	106.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AL	606	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AF	606	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AL	521	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AF	521	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Month Ops New	3	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Months Operations	3	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty A Ph AM	3.81	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty B Ph AM	3.81	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps C Ø	126.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps B Ø	125.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps A Ø	128.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty C Ph AM	3.81	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty A Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty B Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty C Ph AM	.76	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps A Ø	120.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps B Ø	116.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps C Ø	119.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AF	668	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AL	668	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AL	372	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AF	372	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AL	539	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AF	539	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Month Ops New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Months Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.2	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.2	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.2	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps A Ø	885.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps B Ø	872.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps C Ø	879.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty A Ph AM	.8	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty B Ph AM	.8	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty C Ph AM	.8	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AL	570	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AF	570	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Month Ops New	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Months Operations	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty A Ph AM	5.58	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty B Ph AM	8.77	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty C Ph AM	2.39	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps A Ø	163.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AF	976	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AL	976	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps B Ø	151.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps C Ø	167.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations C Ø	2	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations B Ø	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations A Ø	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty A Ph AM	10.68	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty B Ph AM	9.92	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty C Ph AM	3.05	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps A Ø	16.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Months Operations	10	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Month Ops New	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps B Ø	15.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps C Ø	16.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations This Read AM	4	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AL	646	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AF	646	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AF	565	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AL	565	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AF	451	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AL	451	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AF	369	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AL	369	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Month Ops New	14	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Months Operations	14	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AL	518	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AF	518	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AF	384	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AL	384	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	1.93	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	1.93	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	1.93	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Months Operations	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Month Ops New	1	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AF	594	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AL	594	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps C Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps B Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps A Ø	0.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AL	322	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AF	322	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Unknown Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Switching Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations This Read AM	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AL	644	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AF	644	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Maintenance Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps C Ø	198.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps B Ø	189.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps A Ø	184.0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Month Ops New	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Months Operations	0	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	599	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Min Tap Position	2L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Max Tap Position	10L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Left Counter	24641	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Found Counter	24641	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Max	52	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	53	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	53	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	71	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	68	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Present	60	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Found Counter	177436	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Left Counter	177436	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	23	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	33	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1192	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	58	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Found Counter	13634	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Left Counter	13634	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	550	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	71	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	50	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Max	64	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	71	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	71	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	71	°C
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	General Comments		
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/17/2023 11:52	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	4	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations VCB New	4	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	243	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	243	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations VCB New	2	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	2	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1592	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1592	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	3	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations VCB New	3	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	283	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	283	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	160	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	160	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	160	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	125	VAC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	11791	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	11791	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	3R	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	1R	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	84	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3634.56	kw
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.3786	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 7:10	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Maintenance Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AF	197	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AL	197	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations This Read Vac	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Switching Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Unknown Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations Ground	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations C Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations B Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations A Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps C Ø	96	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps B Ø	96	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps A Ø	93	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	9 Month Operations	3	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	9 Month Operations VCB New	3	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations A Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations B Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations C Ø	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps C Ø	70	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps B Ø	67	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps A Ø	68	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty C Ph V	1.87	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty B Ph V	2.5	%
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	9 Month Operations VCB New	12	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	9 Month Operations	12	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations Ground	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Maintenance Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AF	183	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AL	183	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations This Read Vac	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Switching Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Unknown Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	341	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	341	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	1	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	9 Months Operations OCB New	1	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-02-22 00:00:00.000000000	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	123	VAC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	123	VAC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	751	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	2R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	3R	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	6407	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	6407	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	2914.56	kw
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.3036	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	50	°C
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/17/2023 7:01	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	150.0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	150.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	150.0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	9 Month Operations GCB New	0	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	72	°F
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	127.0	VAC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	686	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	1R	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	43382	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	43382	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	9103.36	kw
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.8960	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	60	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 15:05	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	2	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations VCB New	2	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	180.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	180.0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	298	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	298	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	180.0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	60.0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	60.0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	60.0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	369	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	369	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Found Counter	4005	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Left Counter	4005	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Current Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Operations Since Last Insp	383	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	LTC Totalizer Reading	5857.92	kw
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Max	55	°C
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Reading	.6102	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.5	VDC
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 14:58	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps C Ø	58.0	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps A Ø	58.0	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Operations Counter	10	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Regulator As Left Counter	134906	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Regulator As Left Counter	118123	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Regulator As Left Counter	133201	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9204	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2208.96	kw
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 14:17	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps A Ø	29.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps B Ø	17.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps C Ø	16.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps B Phase V	2.15	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations B Ø	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Unknown Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Switching Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations This Read Vac	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AL	225	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AF	225	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Maintenance Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Unknown Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Switching Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations This Read Vac	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AL	251	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AF	251	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Maintenance Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations C Ø	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations B Ø	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps C Phase V	2.15	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps C Ø	4.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps B Ø	0.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps A Ø	0.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations	3	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations This Read Vac	5	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Switching Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Unknown Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AL	251	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AF	251	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Maintenance Operations	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations C Ø	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations B Ø	2	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations A Ø	1	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps C Phase V	2.15	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps B Phase V	2.15	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps A Phase V	1.08	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps C Ø	11.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps B Ø	12.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps A Ø	14.0	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations VCB New	5	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations	10	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Operations Since Last Insp	721	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Left Counter	92354	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Found Counter	92354	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Reading	.8502	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	LTC Totalizer Reading	2040.48	kw
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AF	929	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AL	929	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations This Read Vac	5	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations This Read Vac	4	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AL	232	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AF	232	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations B Ø	4	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps C Ø	76.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps B Ø	89.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps A Ø	97.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty C Ph V	5.02	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty B Ph V	8.61	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty A Ph V	5.74	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations VCB New	4	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations	8	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations VCB New	8	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty A Ph V	7.17	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty B Ph V	13.63	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty C Ph V	.72	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps A Ø	85.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps B Ø	87.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps C Ø	92.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AF	721	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AL	721	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations This Read Vac	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty C Ph V	2.15	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps A Ø	97.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps B Ø	84.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps C Ø	76.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty A Ph V	5.02	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations VCB New	2	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations	3	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps A Ø	91.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	882	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	882	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations This Read Vac	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty C Ph V	5.74	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty B Ph V	7.89	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty A Ph V	5.02	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations VCB New	2	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations	3	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations B Ø	3	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps C Ø	93.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations C Ø	2	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations This Read Vac	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	297	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	207	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations A Ø	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps C Ø	89.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps B Ø	93.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations	9	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations VCB New	4	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty A Ph V	6.46	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty B Ph V	3.59	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty C Ph V	6.46	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps A Ø	76.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps B Ø	74.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Month Ops New	14	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Months Operations	15	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Month Ops New	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Months Operations	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty A Ph AM	10.46	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty B Ph AM	2.85	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty C Ph AM	2.85	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps A Ø	78.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty A Ph AM	30.43	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty B Ph AM	38.04	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty C Ph AM	9.51	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps A Ø	58.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps B Ø	56.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps C Ø	54.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps A Phase AM	8.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations A Ø	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations This Read AM	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	General Comments	a/b ioc	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AF	841	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AL	841	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps B Ø	76.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps C Ø	77.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps A Phase AM	8.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty B Ph AM	3.8	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty C Ph AM	3.8	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Months Operations	9	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Month Ops New	8	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps A Ø	9.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps B Ø	11.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps C Ø	11.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations This Read AM	6	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps C Phase AM	8.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations C Ø	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AF	774	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AL	774	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations This Read AM	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AL	704	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Operations Counter AF	704	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations C Ø	6	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps C Phase AM	48.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps C Ø	120.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps B Ø	123.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Amps A Ø	120.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty C Ph AM	5.21	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty B Ph AM	6.42	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Accumulated Fault Duty A Ph AM	2.43	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations This Read AM	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AL	806	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AF	806	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	9 Months Operations	18	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	9 Month Ops New	12	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations A Ø	1	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 11:35	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Regulator As Left Counter	22660	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Regulator As Left Counter	22530	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Regulator As Left Counter	1945	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	RG000029	Regulator	004-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5196	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1662.72	kw
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Switching Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Unknown Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AL	184	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AF	184	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Maintenance Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps C Ø	123.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps B Ø	137.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps A Ø	110.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations	1	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Maintenance Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AF	133	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AL	133	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps C Ø	5.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps B Ø	30.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps A Ø	5.0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations VCB New	5	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations	5	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Switching Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Unknown Operations	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	General Comments		
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:50	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Unknown Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Switching Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations This Read Vac	1	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AL	403	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AF	403	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Maintenance Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations C Ø	1	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations	1	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps C Ø	38.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps B Ø	39.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps A Ø	37.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Maintenance Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AF	325	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AL	325	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Switching Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps C Ø	52.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps B Ø	76.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps A Ø	47.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Unknown Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Unknown Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Switching Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps A Ø	10.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps B Ø	10.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps C Ø	13.0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Maintenance Operations	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AF	325	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AL	325	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Min Tap Position	15L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Regulator As Left Counter	81711	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Regulator As Left Counter	112959	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Min Tap Position	16L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	General Comments	no counter	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6126	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4410.72	kw
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	General Comments	no spare fuses in sub	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 10:23	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.4	VDC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Current Tap Position	9L	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Found Counter	1450	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Left Counter	1467	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Operations Since Last Insp	46	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	LTC Totalizer Reading	1886.40	kw
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Present	35	℃
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Reading	.3144	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps C Ø	110.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps B Ø	140.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Unknown Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Switching Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps A Ø	130.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Maintenance Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AF	148	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AL	148	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AL	167	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Unknown Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Switching Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations This Read Vac	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps C Ø	120.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps B Ø	125.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations B Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations A Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps A Ø	180.0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations C Ø	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations Ground	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Maintenance Operations	0	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AF	167	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 10:00	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Operations Since Last Insp	510	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Min Tap Position	1L	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Max Tap Position	7R	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	General Comments	low indicator arm follows step	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Found Counter	16989	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Left Counter	17007	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Reading	.7998	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	LTC Totalizer Reading	7678.08	kw
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AF	196	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AL	196	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Switching Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Unknown Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Maintenance Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps C Ø	100.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps B Ø	100.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps A Ø	100.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations	1	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Maintenance Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AF	232	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AL	232	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Switching Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps C Ø	37.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps B Ø	36.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps A Ø	30.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Unknown Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations	1	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	9 Month Operations	1	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps A Ø	22.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AL	235	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AF	235	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Maintenance Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps C Ø	22.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps B Ø	22.0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Unknown Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Switching Operations	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 9:55	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Regulator As Left Counter	67859	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	General Comments	AL 123.8 Vac	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57144	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	General Comments		
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Regulator As Left Counter	80715	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	General Comments		
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Maintenance Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AF	166	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AL	166	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Switching Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Unknown Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	9 Month Operations	8	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps C Ø	143.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps B Ø	138.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps A Ø	98.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	9 Month Operations VCB New	8	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	28	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	General Comments	WASPS!!!!!	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	General Comments	700 bottle psi	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Unknown Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Switching Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations This Read Vac	2	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AL	208	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AF	208	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Maintenance Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations C Ø	1	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations B Ø	1	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps C Phase V	5.72	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps B Phase V	5.72	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps C Ø	144.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps B Ø	142.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps A Ø	103.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations VCB New	9	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations	11	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	General Comments	WASPS!!!!!!	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	52	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	General Comments	H2 bushing has broken skirt. Needs wildlife protection.	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	9 Month Operations	12	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	9 Month Operations VCB New	12	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps A Ø	0.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps B Ø	0.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps C Ø	0.0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Maintenance Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AF	194	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AL	194	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Switching Operations	0	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Unknown Operations	0	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	General Comments		
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	14.88	kw
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	52	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	48	°C
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0186	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	All Connections OK?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	General Comments	1.2 psi	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Operations Since Last Insp	718	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Min Tap Position	15L	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Max Tap Position	4L	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Current Tap Position	10L	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Left Counter	20922	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Found Counter	20922	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	General Comments	Needs Enh Wildlife prot, station needs repairs.	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	General Comments	there is not a nitrogen gauge on the LTC	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 9:43	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	LTC Totalizer Reading	4406.40	kw
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Max	45	°C
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Present	25	°C
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Reading	.3060	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Max	45	°C
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Present	30	°C
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	7.1	amps
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
11/16/2023 9:42	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Left Counter	9165	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1008	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Found Counter	9165	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Present	48	°C
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	General Comments	NEEDS CLEANING	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Operations Counter AF	55	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Amps A Ø	633.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	9 Month Operations VCB New	11	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	9 Month Operations	11	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Amps C Ø	610.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Amps B Ø	618.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Readings	Operations Counter AL	55	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002138	BreakerVacuum	FL-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Operations Counter AL	9	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Operations Counter AF	9	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Amps C Ø	0.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Amps A Ø	0.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	9 Month Operations VCB New	21	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Readings	9 Month Operations	21	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002139	BreakerVacuum	FL-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Operations Counter AL	83	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	9 Month Operations	8	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Operations Counter AF	83	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Amps B Ø	85.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Amps C Ø	87.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Amps A Ø	93.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	9 Month Operations VCB New	8	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002140	BreakerVacuum	FL-1495	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	9 Month Operations	9	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	9 Month Operations VCB New	9	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Amps C Ø	61.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Operations Counter AF	17	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Operations Counter AL	17	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Amps B Ø	67.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Amps A Ø	67.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002141	BreakerVacuum	FL-1496	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Operations Counter AF	38	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Operations Counter AL	38	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Amps C Ø	300.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Amps B Ø	296.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Amps A Ø	299.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	9 Month Operations VCB New	6	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Readings	9 Month Operations	6	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002142	BreakerVacuum	FL-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Operations Counter AL	8	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Operations Counter AF	8	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	9 Month Operations	3	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	9 Month Operations VCB New	3	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Amps A Ø	27.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Amps B Ø	25.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Amps C Ø	28.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002143	BreakerVacuum	FL-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	9 Month Operations	12	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	9 Month Operations VCB New	12	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Amps A Ø	167.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Operations A Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Operations Ground	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Operations C Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Fault Operations B Ø	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Unknown Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Switching Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Operations This Read Vac	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Operations Counter AL	26	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Operations Counter AF	26	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Maintenance Operations	0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Amps B Ø	170.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Readings	Amps C Ø	168.0	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	General Comments		
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 9:19	Distribution	Floyd Quarterly Inspection	BK002144	BreakerVacuum	FL-1499	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	General Comments		
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 8:21	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Month Ops New	6	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Months Operations	6	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps A Ø	10.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps B Ø	10.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps C Ø	10.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations This Read AM	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AL	2063	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AF	2063	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Months Operations	17	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Month Ops New	13	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps A Ø	100.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps B Ø	110.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps C Ø	100.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps C Phase AM	44.72	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations C Ø	4	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	General Comments	C phase IOC	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AF	495	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AL	495	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations This Read AM	4	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps A Ø	100.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps B Ø	50.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps C Ø	75.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Months Operations	12	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Month Ops New	12	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations This Read AM	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AL	331	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AF	331	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Month Ops New	34	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Months Operations	43	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps C Ø	180.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps B Ø	160.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps A Ø	210.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations This Read AM	9	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AL	390	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AF	390	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	General Comments	A, B and C phase IOC	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations A Ø	3	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations B Ø	3	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations C Ø	3	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AF	130	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AL	130	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Month Ops New	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Months Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps A Ø	250.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps C Ø	180.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps B Ø	180.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	261	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	261	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps C Ø	85.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps A Ø	66.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps B Ø	86.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AL	435	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AF	435	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	General Comments	A and B phase TOC. NO VC CHANGE	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps A Ø	90.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps B Ø	80.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps C Ø	98.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	9 Month Operations VCB New	10	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AF	684	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AL	684	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps C Ø	2.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps B Ø	1.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps A Ø	2.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AF	255	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AL	255	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Unknown Operations	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AL	738	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AF	738	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps A Ø	134.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps B Ø	142.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps C Ø	124.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps A Ø	290.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps B Ø	302.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps C Ø	300.0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Unknown Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Switching Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AL	219	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AF	219	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1732	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	13R	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Found Counter	5611	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Left Counter	5611	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Found Counter	121029	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Left Counter	121029	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1611	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	31	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	31	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	82	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Max	72	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	31	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	72	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	83	°C
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	All Connections OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Found Counter	14787	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Left Counter	14787	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	10L	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	644	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2R	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 7:32	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Operations Counter	229	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps B Ø	64.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps C Ø	69.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Operations Counter	209	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Operations Since Last Insp	655	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Max Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Found Counter	35632	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Left Counter	35632	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	LTC Totalizer Reading	5758.08	kw
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Reading	.5998	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Max	45	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 7:19	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	15.0	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	9	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17580	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	243	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	243	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	142.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	107.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	104.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations VCB New	8	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	8	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Regulator As Left Counter	13335	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations VCB New	5	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	5	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	227	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	227	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations This Read Vac	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	480262	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	480262	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	140	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	All Connections OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49827	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	1243.20	kw
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.2590	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.2010	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	160.80	kw
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 7:14	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 7:14	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations This Read Vac	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AL	320	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AF	320	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations	4	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations VCB New	4	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps C Ø	190.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps B Ø	190.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps A Ø	190.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations This Read Vac	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AL	270	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AF	270	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps C Ø	280.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps B Ø	280.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps A Ø	280.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations VCB New	10	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations	10	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations This Read Vac	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AL	446	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AF	446	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps A Ø	100.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps B Ø	75.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps C Ø	75.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps B Ø	0.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps C Ø	0.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations This Read Vac	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AL	149	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AF	149	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps A Ø	160.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps B Ø	160.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps C Ø	160.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Switching Operations	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations This Read Vac	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AL	601	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AF	601	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations	10	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations VCB New	2	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps A Ø	730.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps B Ø	730.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps C Ø	730.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Maintenance Operations	7	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AF	279	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AL	279	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations This Read Vac	8	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Switching Operations	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	661	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	661	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Month Ops New	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Months Operations	8	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Month Ops New	8	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps A Ø	205.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps B Ø	205.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps C Ø	205.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	General Comments	A phase i.o.c and t.o.c B phase i.o.c c phase i.o.c	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AF	796	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AL	796	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations This Read AM	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Months Operations	2	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Month Ops New	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps A Ø	95.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps B Ø	95.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps C Ø	96.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations B Ø	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	General Comments	b phase ioc	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AF	656	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AL	656	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations This Read AM	1	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Month Ops New	3	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Months Operations	3	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps A Ø	45.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps B Ø	45.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps C Ø	45.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AF	1031	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AL	1031	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations This Read AM	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Unknown Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps C Ø	305.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps B Ø	305.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps A Ø	320.0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Months Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Month Ops New	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Switching Operations	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AF	99970	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AL	99970	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	876	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2R	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Left Counter	200586	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Found Counter	200586	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	90	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	20	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	135	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	110	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Found Counter	231433	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Left Counter	231433	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1976	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	70	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	70	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	46	°F
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 6:50	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps A Ø	0.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps B Ø	0.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps C Ø	0.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations This Read Vac	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AL	204	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AF	204	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations This Read Vac	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AL	245	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AF	245	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations B Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations A Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps C Ø	119.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps B Ø	113.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps A Ø	107.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations This Read Vac	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AL	183	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AF	183	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations B Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations A Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps A Ø	364.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps C Ø	367.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps B Ø	390.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Found Counter	56538	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Left Counter	56538	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Max Tap Position	9R	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Min Tap Position	3L	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Operations Since Last Insp	730	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Present	40	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Max	70	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Reading	.4788	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	LTC Totalizer Reading	8618.40	kw
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Operation Checked?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	All Connections OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Operations A Ø	1	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Amps C Ø	119.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Amps B Ø	127.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Amps A Ø	125.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	9 Month Operations	2	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Operations B Ø	1	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Operations Counter AF	186	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Operations Counter AL	186	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Operations This Read Vac	2	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002046	BreakerVacuum	833-2161	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps A Ø	135.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps B Ø	117.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps C Ø	109.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations A Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations B Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AF	248	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AL	248	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations This Read Vac	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Unknown Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Switching Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Operations This Read Vac	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Operations Counter AL	163	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Operations Counter AF	163	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Maintenance Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Operations Ground	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Operations C Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Operations B Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Operations A Ø	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Amps C Ø	334.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Amps B Ø	337.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Amps A Ø	8356.0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Readings	9 Month Operations	0	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BK002055	BreakerVacuum	833-1	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	All Connections OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Operation Checked?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Operations Since Last Insp	916	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Found Counter	114000	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Left Counter	114000	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Max	80	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Reading	.6918	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Max	80	°C
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	LTC Totalizer Reading	12452.40	kw
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Positive DC Ground	20.4	VDC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Negative DC Ground	20.5	VDC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/15/2023 15:08	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.9	VDC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Operation Checked?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Operations Since Last Insp	358	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Found Counter	13022	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Left Counter	13033	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BCH001401	Charger	496-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Reading	.3198	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Present	43	°C
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	LTC Totalizer Reading	1535.04	kw
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations C Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations Ground	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	9 Month Operations	9	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	9 Month Operations VCB New	9	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps A Ø	45.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps B Ø	49.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps C Ø	47.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations A Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations B Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Maintenance Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations Counter AF	244	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations Counter AL	244	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations This Read Vac	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Switching Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Unknown Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Unknown Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Switching Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Operations This Read Vac	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Operations Counter AL	173	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Operations Counter AF	173	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Maintenance Operations	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	General Comments	ok	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Operations Ground	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Operations C Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Operations B Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Operations A Ø	0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Amps C Ø	30.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Amps B Ø	33.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Amps A Ø	46.0	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	9 Month Operations VCB New	28	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	BK001764	BreakerVacuum	496-1760	VCB Readings	9 Month Operations	28	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	General Comments	Needs Grounding upgrade	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 13:15	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Regulator As Left Counter	150801	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42434	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62105	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4452	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1068.48	kw
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	General Comments	Secondary of xfmr needs wildlife protection.	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	142	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.3	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.4	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.1	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	119	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	112	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	296	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	262	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	261	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	General Comments		
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Operations Counter	0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	General Comments	counter 10/9/9	
11/15/2023 12:47	Distribution	Sunoco Quarterly Inspection	RC901735	RecloserElectronic	865-1733	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Switching Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	183	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	183	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AL	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AF	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AF	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AL	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AL	133	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AF	133	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AF	151	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AL	151	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AF	155	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AL	155	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AL	170	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AF	170	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Found Counter	21704	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Left Counter	21704	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Current Tap Position	7L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Max Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	452	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Max	48	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Present	37	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	26	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	48	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	36	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	48	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	36	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AF	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AL	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations This Read Vac	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Switching Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AF	247	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AL	247	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps C Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps B Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps A Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps A Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps B Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps C Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AF	250	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AL	250	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AL	201	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AF	201	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps C Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps B Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps A Ø	10.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AL	192	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AF	192	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps C Ø	30.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps B Ø	30.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps A Ø	31.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Min Tap Position	8L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	421	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Max Tap Position	1R	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Current Tap Position	6L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Left Counter	45327	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Found Counter	45327	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	50	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	50	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Present	35	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Max	55	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	50	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AF	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AL	146	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps C Ø	505.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps B Ø	513.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps A Ø	530.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1095	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6R	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Current Tap Position	11L	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Left Counter	42855	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Found Counter	42855	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	90	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Present	20	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	90	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Max	80	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AL	269	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AF	269	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps A Ø	125.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps B Ø	125.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps C Ø	124.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1229	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Left Counter	38869	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Found Counter	38869	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	80	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	90	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	90	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	90	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	35	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Max	75	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Month Ops New	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Months Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps A Ø	0.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps B Ø	0.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps C Ø	0.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AF	308	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AL	308	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations This Read AM	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AL	923	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AF	376	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps C Ø	100.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps B Ø	98.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps A Ø	76.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations	3	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps A Ø	60.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps B Ø	62.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	9 Month Operations	3	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Maintenance Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations Counter AF	211	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations Counter AL	211	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps C Ø	62.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Unknown Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Switching Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Maintenance Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AF	158	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AL	158	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Switching Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Unknown Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps C Ø	76.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps B Ø	73.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps A Ø	86.0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AF	172	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AL	172	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34707	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Maintenance Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AF	432	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AL	432	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations This Read AM	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Unknown Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps C Ø	261.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps B Ø	257.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps A Ø	261.0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Months Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Month Ops New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AL	228	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AF	228	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations	5	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations VCB New	5	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	9 Month Operations	8	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps A Ø	308.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps B Ø	300.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps C Ø	309.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	9 Month Operations VCB New	8	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AF	454	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AL	454	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27737	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	General Comments	ok	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	General Comments	drag hands are stuck on moving hand	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Found Counter	197680	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Left Counter	197680	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	808	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AF	254	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps C Ø	80.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps B Ø	78.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps A Ø	77.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations VCB New	4	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations	4	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AL	254	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AF	229	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AL	229	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	9 Month Operations	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Switching Operations	0	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps A Ø	480.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps B Ø	480.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps C Ø	480.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AF	261	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AL	261	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations	1	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31006	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	289	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Max Tap Position	11	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Left Counter	962	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Found Counter	962	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Present	0	°C
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Max	0	°C
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8034	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	General Comments	no winding temp gauge	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7712.64	kw
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Max	70	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Present	40	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.1	amps
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.4	VDC
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	General Comments	need nitrogen	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 11:25	Distribution	Highland Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps A Ø	145.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps B Ø	145.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps C Ø	145.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AL	217	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AF	217	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AL	304	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AF	304	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps A Ø	110.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps B Ø	110.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps C Ø	110.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AL	258	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AF	258	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps C Ø	100.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps B Ø	100.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps A Ø	100.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations VCB New	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AF	378	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AL	378	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations This Read Vac	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Switching Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps C Ø	35.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps B Ø	40.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps A Ø	35.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	9 Month Operations VCB New	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	9 Month Operations	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps C Ø	200.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps B Ø	220.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps A Ø	200.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	9 Month Operations VCB New	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	9 Month Operations	4	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AF	360	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AL	360	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations This Read Vac	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Switching Operations	2	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AF	519	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	9 Months Operations OCB New	4	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Number of Ops last 9 Months	4	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AL	519	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations This Read Oil	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Fault Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Switching Operations	0	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 12:02	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	386	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Left Counter	25073	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Found Counter	25073	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Left Counter	86949	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	225	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Found Counter	86949	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AL	127	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps A Ø	150.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps B Ø	110.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps C Ø	133.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AF	127	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps A Ø	112.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps B Ø	110.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps C Ø	90.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AF	240	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AL	240	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps A Ø	130.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps B Ø	130.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AL	148	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AF	148	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps C Ø	130.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps A Ø	82.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps B Ø	100.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps C Ø	80.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AF	149	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AL	149	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AL	172	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AF	172	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps C Ø	78.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps B Ø	78.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps A Ø	78.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps B Ø	300.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps C Ø	300.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps A Ø	300.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations Counter AF	339	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations Counter AL	339	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Unknown Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Unknown Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	9 Month Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps A Ø	200.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps B Ø	200.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps C Ø	200.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations Counter AF	350	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations Counter AL	350	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	PT Free of Leaks?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Tank Oil Level	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Switching Operations	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations This Read Vac	1	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations Counter AL	355	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations Counter AF	355	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps C Ø	40.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps B Ø	40.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps A Ø	40.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	9 Month Operations	7	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Unknown Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations Counter AL	356	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations Counter AF	356	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations B Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Unknown Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	9 Month Operations	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps A Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps B Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps C Ø	0.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	9 Month Operations	5	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	9 Month Operations VCB New	5	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps A Ø	90.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps B Ø	90.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps C Ø	90.0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Unknown Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Switching Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations Counter AL	350	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations Counter AF	350	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	General Comments		
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Vacuum Monitor Self-Check OK?	na	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Vacuum Monitor Antenna Paint	NA	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 12:41	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations A Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps C Ø	65.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps B Ø	62.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Amps A Ø	45.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations B Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations C Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Fault Operations Ground	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	9 Month Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Unknown Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Switching Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations This Read Vac	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AL	225	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Operations Counter AF	225	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Readings	Maintenance Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BK000476	BreakerVacuum	601-0336	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	16	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations VCB New	16	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	49.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	65.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	42.0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C Ø	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	352	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	352	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations This Read Vac	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	LTC Operation Checked?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	LTCC000712	LTCControl	601-1	LTC Control Insp	All Connections OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	76356	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	76356	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	609	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Reading	.3890	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	3734.40	kw
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 10:27	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps C Ø	180.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AF	153	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AL	153	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps B Ø	138.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps A Ø	141.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	9 Month Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Unknown Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations This Read Vac	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations Ground	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations C Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations A Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AL	137	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AF	137	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Maintenance Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps C Ø	1.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps B Ø	1.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps A Ø	1.0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	9 Month Operations VCB New	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	9 Month Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF001333	PowerFuse	PV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF001333	PowerFuse	PV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	32	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	22	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Amps C Ø	8.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Amps B Ø	11.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Amps A Ø	12.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	9 Month Operations VCB New	2	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	9 Month Operations	2	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Unknown Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Switching Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Operations Counter AL	1569	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Operations Counter AF	169	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Maintenance Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Readings	Fault Operations B Ø	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	General Comments	no station grounds	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001800	BreakerVacuum	652-2305	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Amps C Ø	62.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Amps B Ø	86.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Amps A Ø	76.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	9 Month Operations	1	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Maintenance Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Operations Counter AF	163	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Operations Counter AL	163	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Switching Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Readings	Unknown Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001799	BreakerVacuum	652-2304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Unknown Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Switching Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	9 Month Operations	3	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Operations Counter AL	272	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Operations Counter AF	272	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Maintenance Operations	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Amps A Ø	71.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Amps B Ø	97.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Amps C Ø	82.0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BK001798	BreakerVacuum	652-2303	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	245292	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	245292	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	702	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	All Connections OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	LTC Operation Checked?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	LTCC000970	LTCControl	652-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	4792.32	kw
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.4992	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 9:49	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Found Counter	47614	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Left Counter	47614	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	475	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load X2 Max	100	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	General Comments	thermal load gauge at 100	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Found Counter	223228	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1099	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Left Counter	223228	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Max	80	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	2	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Min Tap Position	4L	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Max Tap Position	16R	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Left Counter	26351	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Found Counter	23651	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Max	80	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Present	20	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	120	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	50	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	120	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	120	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AL	121	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AF	121	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps C Ø	68.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps B Ø	81.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps A Ø	95.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations This Read Vac	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AL	91	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AF	91	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Maintenance Operations	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps C Ø	124.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps B Ø	132.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps A Ø	124.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	9 Month Operations	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps A Ø	190.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps B Ø	168.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps C Ø	173.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AF	209	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AL	209	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations This Read Vac	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Switching Operations	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AL	119	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AF	119	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps C Ø	79.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps B Ø	88.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps A Ø	75.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps A Ø	473.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps B Ø	448.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps C Ø	401.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AF	49	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AL	49	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Switching Operations	0	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	General Comments		
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2023 16:12	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps A Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps B Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps C Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AF	54	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AL	54	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Operations Counter AL	2	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Operations Counter AF	2	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Amps A Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Amps C Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Readings	Amps B Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002131	BreakerVacuum	ET-GND TR 1	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Operations Counter AL	11	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Operations Counter AF	11	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Amps A Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Amps C Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Readings	Amps B Ø	0.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002129	BreakerVacuum	ET-14KV TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Operations Counter AL	19	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Operations Counter AF	19	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Amps A Ø	208.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Amps B Ø	201.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Readings	Amps C Ø	196.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002130	BreakerVacuum	ET-14KV TR 1	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Operations Counter AL	163	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Operations Counter AF	163	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Amps C Ø	329.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Amps B Ø	326.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Amps A Ø	323.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Readings	9 Month Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002125	BreakerVacuum	ET-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	9 Month Operations	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Operations This Read Vac	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Operations Counter AL	36	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Amps A Ø	65.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Amps B Ø	61.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Amps C Ø	71.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Fault Operations C Ø	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Readings	Operations Counter AF	36	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002121	BreakerVacuum	ET-1166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Operations Counter AL	16	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Operations Counter AF	16	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Operations B Ø	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Operations This Read Vac	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Adjusted Amps B Phase V	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Amps C Ø	72.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Amps B Ø	64.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Amps A Ø	77.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	9 Month Operations VCB New	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Readings	9 Month Operations	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002122	BreakerVacuum	ET-1167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Operations Counter AF	42	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Operations Counter AL	42	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Operations This Read Vac	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Switching Operations	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Amps C Ø	95.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Amps B Ø	105.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Amps A Ø	102.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	9 Month Operations VCB New	1	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Readings	9 Month Operations	2	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002123	BreakerVacuum	ET-1168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	9 Month Operations	5	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	9 Month Operations VCB New	5	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Amps A Ø	94.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Amps B Ø	92.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Amps C Ø	94.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Operations Counter AF	20	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Operations Counter AL	20	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002124	BreakerVacuum	ET-1169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	Ground Lights	Positive Ground	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	General Comments	ground light	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	As Found Float Voltage	54.1	VDC
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BCH001597	Charger	ET-Battery Bank 48V	Battery Charger Patrol Insp	As Left Float Voltage	54.1	VDC
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Amps B Ø	47.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Amps C Ø	48.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Amps A Ø	50.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	9 Month Operations	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Operations C Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Operations Counter AL	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Readings	Operations Counter AF	44	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002126	BreakerVacuum	ET-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Amps C Ø	101.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Amps B Ø	105.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Amps A Ø	102.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	9 Month Operations VCB New	33	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	9 Month Operations	38	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Operations C Ø	2	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	General Comments	c phase ioc	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Maintenance Operations	3	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Operations Counter AF	65	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Operations Counter AL	65	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Readings	Operations This Read Vac	5	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002127	BreakerVacuum	ET-1422	VCB Patrol Inspection	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	9 Month Operations	6	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	9 Month Operations VCB New	6	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Amps A Ø	68.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Amps B Ø	60.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Amps C Ø	61.0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Operations A Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Operations B Ø	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Fault Operations Ground	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	General Comments		
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Maintenance Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Operations Counter AF	130	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Operations Counter AL	130	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Operations This Read Vac	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Switching Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Readings	Unknown Operations	0	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 9:43	Distribution	Ethel Quarterly Inspection	BK002128	BreakerVacuum	ET-1423	VCB Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	783	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Left Counter	16287	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Found Counter	16287	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Vegetation	None	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	9 Month Operations VCB New	3	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	9 Month Operations	3	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Unknown Operations	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Switching Operations	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Operations This Read Vac	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Operations Counter AL	34	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Operations Counter AF	34	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Maintenance Operations	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Operations Ground	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Operations C Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Operations B Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Operations A Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Amps C Ø	206.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Amps B Ø	137.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Amps A Ø	200.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002119	BreakerVacuum	SK-1127	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Maintenance Operations	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Operations Ground	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Operations C Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Operations B Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Operations A Ø	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Unknown Operations	1	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Switching Operations	0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Operations This Read Vac	1	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Operations Counter AL	61	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Operations Counter AF	61	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	9 Month Operations	34	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	9 Month Operations VCB New	33	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Amps C Ø	100.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Amps B Ø	87.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Amps A Ø	95.0	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Grounds in Place?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	General Comments		
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Foundation Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Bushing Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Tank Paint Condition	Good	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/15/2023 7:44	Distribution	Skylight Quarterly Inspection	BK002120	BreakerVacuum	SK-1128	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	47.0	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	74.0	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	82.0	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	352620	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	214905	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	430	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	214905	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	1.3710	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	65	°C
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	2467.80	kw
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 15:24	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Operations Counter	86	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Operations Counter	98	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Max Tap Position	11R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34383	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Max Tap Position	11R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33763	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Max Tap Position	10R	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29990	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Present	45	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Max	65	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Present	50	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	3151.20	kw
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.3130	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Present	50	°C
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.3	VDC
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	FE000887	Fence	891-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 15:19	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Unknown Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Switching Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations This Read Vac	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AL	201	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AF	201	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Maintenance Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations Ground	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps C Ø	135.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps B Ø	150.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps A Ø	135.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps C Ø	110.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps B Ø	110.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations Ground	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Maintenance Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AF	191	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AL	191	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations This Read Vac	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Switching Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Unknown Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps A Ø	105.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps C Ø	27.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps B Ø	25.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps A Ø	35.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations Ground	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations	2	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Unknown Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Switching Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations This Read Vac	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AL	174	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Maintenance Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AF	174	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Found Counter	43806	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Left Counter	43806	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Max Tap Position	4R	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Min Tap Position	3L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Operations Since Last Insp	154	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Reading	.7824	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Present	45	°C
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Max	60	°C
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	LTC Totalizer Reading	7511.04	kw
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	140.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	120.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	114.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations This Read Vac	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	315	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	315	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	123.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	144.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	138.0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations This Read Vac	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	278	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	278	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	1	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Min Tap Position	2L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Regulator As Left Counter	1563	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Regulator As Left Counter	1538	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Regulator As Left Counter	1445	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6750	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2160.00	kw
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Unknown Operations	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Switching Operations	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations This Read Vac	2	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AL	284	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AF	284	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Maintenance Operations	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations Ground	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations C Ø	2	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations B Ø	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations A Ø	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps C Phase V	2.63	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps C Ø	66	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps B Ø	59	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps A Ø	67	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty C Ph V	2.15	%
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty B Ph V	2.25	%
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty A Ph V	2.35	%
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	9 Month Operations VCB New	45	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	9 Month Operations	47	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 15:13	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Found Counter	162605	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Left Counter	162605	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Operations Since Last Insp	385	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	LTC Totalizer Reading	2644.8	kw
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Reading	.551	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/14/2023 14:56	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps C Ø	1	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps B Ø	6	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps A Ø	12	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5057	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7210	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8028	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Reading	.57	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	342	kw
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 14:49	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	All Connections OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	General Comments	AL 124.1Vac	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Operations Since Last Insp	411	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Min Tap Position	13L	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Max Tap Position	2R	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Current Tap Position	6L	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Left Counter	23797	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Found Counter	23792	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations C Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations	6	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations VCB New	6	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps A Ø	62.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps B Ø	53.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps C Ø	89.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AF	213	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AL	213	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations This Read Vac	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations	2	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps A Ø	28.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps B Ø	28.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps C Ø	32.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations This Read Vac	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AL	205	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AF	205	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations C Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	General Comments	Temp gauge doesn't have max hand.	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	LTC Totalizer Reading	4849.92	kw
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Present	35	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Reading	.5052	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Amps A Ø	69.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Amps B Ø	77.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Amps C Ø	72.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	9 Month Operations VCB New	4	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	9 Month Operations	4	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Operations This Read Vac	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Operations Counter AL	156	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Operations Counter AF	156	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Operations C Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.9	VDC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.3	VDC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.2	VDC
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Max	22	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Max	52	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Present	4	°C
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	General Comments	Replaced Nitro Bottle	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2250	psi
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	69.17	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations This Read Vac	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AL	53	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AF	53	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps A Ø	8.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps B Ø	11.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps C Ø	12.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations C Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK002066	BreakerVacuum	005-1478	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations VCB New	3	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations C Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps A Ø	17.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations	3	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AF	65	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AL	65	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations This Read Vac	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps B Ø	17.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps C Ø	20.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	9 Month Operations	10	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	9 Month Operations VCB New	9	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Switching Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AL	209	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AF	209	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Maintenance Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	General Comments	C-G 9-28-23	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations Ground	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Unknown Operations	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations C Ø	1	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations B Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps A Ø	0.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps B Ø	3.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps C Ø	3.0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations A Ø	0	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 12:26	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Unknown Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Switching Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations This Read Vac	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations A Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations Counter AL	44	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Operations Counter AF	44	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Maintenance Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps C Ø	300.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps B Ø	330.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Amps A Ø	300.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	9 Month Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations B Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations C Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations Ground	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations A Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations B Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations C Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Operations Ground	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Switching Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations This Read Vac	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	9 Month Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations Counter AL	78	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Operations Counter AF	78	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Maintenance Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps A Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps B Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps C Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	9 Month Operations	17	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	9 Month Operations VCB New	17	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps A Ø	20.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps B Ø	20.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Amps C Ø	2.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations A Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations B Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations C Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Fault Operations Ground	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Maintenance Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AF	138	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AL	138	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations This Read Vac	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Switching Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Unknown Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Unknown Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Switching Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations This Read Vac	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations Counter AL	101	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Operations Counter AF	101	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Maintenance Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations Ground	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations C Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations B Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Operations A Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps B Ø	200.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps C Ø	250.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps A Ø	250.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	9 Month Operations	2	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panels Dusted?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Evidence of Insects	None	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Found Counter	240012	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Left Counter	240012	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Current Tap Position	9L	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Max Tap Position	7L	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Min Tap Position	9L	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Max	35	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Present	75	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Max	40	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X1 Winding Temp Present	70	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Present	35	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Max	65	°C
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AF	188	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations Counter AL	188	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Switching Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	9 Months Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	General Comments	ok	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/14/2023 11:14	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7610.40	kw
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1812	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	42000	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations VCB New	7	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps A Ø	0.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps B Ø	0.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations	19	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps C Ø	0.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Maintenance Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AF	598	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AL	598	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Unknown Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Switching Operations	12	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations This Read Vac	12	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps C Ø	235.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps B Ø	312.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps A Ø	257.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Unknown Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Switching Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Maintenance Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AL	243	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AF	243	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K80091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps C Ø	170.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AL	297	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Switching Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Unknown Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Maintenance Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AF	297	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps B Ø	208.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps A Ø	183.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations VCB New	10	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations	10	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps B Ø	101.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps C Ø	69.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Maintenance Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AF	294	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AL	294	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Switching Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Unknown Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps A Ø	75.0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Found Counter	37011	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Left Counter	37011	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Current Tap Position	4L	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Max Tap Position	1R	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Min Tap Position	11L	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Operations Since Last Insp	883	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Present	25	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Max	80	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Reading	.4670	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	LTC Totalizer Reading	8406.00	kw
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Max	70	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Present	20	°C
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:39	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	9 Month Operations	2	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Unknown Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Switching Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations This Read Vac	2	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AL	176	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AF	176	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Maintenance Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty A Ph V	.89	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps A Ø	48	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps B Ø	49	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps C Ø	52	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps A Phase V	5.99	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps C Phase V	5.99	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations A Ø	1	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations C Ø	1	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AF	184	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AL	184	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Switching Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Unknown Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps C Ø	123	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps B Ø	104	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps A Ø	126	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty C Ph V	2.23	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	9 Month Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Maintenance Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	9 Month Operations	10	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	9 Month Operations VCB New	10	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty A Ph V	2.68	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty B Ph V	.89	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps A Ø	83	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps B Ø	87	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps C Ø	78	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Unknown Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Switching Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AL	216	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AF	216	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Maintenance Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps A Ø	300	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps B Ø	300	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps C Ø	300	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty C Ph V	1.08	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty B Ph V	1.08	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty A Ph V	1.08	%
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Unknown Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Switching Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AL	99749	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Maintenance Operations	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AF	99749	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Found Counter	44875	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Left Counter	44875	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Operations Since Last Insp	767	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Max	80	°C
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Reading	1.0488	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	LTC Totalizer Reading	15102.72	kw
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50	VDC
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 7:23	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps C Ø	90	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps B Ø	89	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps A Ø	96	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty C Ph V	1.34	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty A Ph V	.45	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	9 Month Operations	5	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Unknown Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Switching Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Maintenance Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AF	173	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AL	173	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations This Read Vac	3	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Switching Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations Counter AL	128	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations Counter AF	128	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps C Ø	114.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	9 Month Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps B Ø	89.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps A Ø	100.0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Unknown Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	9 Month Operations	5	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty B Ph V	1.34	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Switching Operations	3	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations This Read Vac	3	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AL	173	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AF	173	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Maintenance Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps A Ø	73	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps B Ø	47	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps C Ø	86	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	9 Month Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps A Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps B Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps C Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations Counter AF	66	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations Counter AL	66	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Switching Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Switching Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations Counter AL	186	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations Counter AF	186	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	9 Month Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps A Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps C Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps A Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations A Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations B Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations C Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations Ground	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	General Comments	open	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Maintenance Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AF	414	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AL	414	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations This Read Vac	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Switching Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Unknown Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps B Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps C Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps C Ø	10	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps B Ø	10	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps A Ø	8	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	9 Month Operations VCB New	4	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	9 Month Operations	7	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Unknown Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Maintenance Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AF	170	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Switching Operations	3	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations This Read Vac	3	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AL	170	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Switching Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations Counter AL	144	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations Counter AF	144	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps C Ø	44.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	9 Month Operations	4	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	9 Month Operations VCB New	4	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps A Ø	26.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps B Ø	23.0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Unknown Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Switching Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations This Read Vac	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AL	186	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AF	186	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Maintenance Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations Ground	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations C Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations B Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations A Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps C Ø	25	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps B Ø	40	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps A Ø	30	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations	1	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	9 Month Operations	-1	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	9 Month Operations VCB New	-1	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Amps A Ø	164	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Amps B Ø	132	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Unknown Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Amps C Ø	166	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Switching Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Operations Counter AL	190	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Operations Counter AF	190	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Maintenance Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	9 Month Operations	2	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps A Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps B Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps C Ø	0.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations Counter AF	174	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations Counter AL	174	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations This Read Vac	2	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Switching Operations	2	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Unknown Operations	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BK002040	BreakerVacuum	522-1	VCB Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Found Counter	14528	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Left Counter	14528	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Operations Since Last Insp	542	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Max Tap Position	16R	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations A Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps C Ø	25	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps B Ø	40	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps A Ø	30	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations	1	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations Ground	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Maintenance Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AF	186	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations B Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations C Ø	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AL	186	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations This Read Vac	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Switching Operations	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Switching Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations Counter AL	95	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations Counter AF	95	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Maintenance Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	9 Month Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps A Ø	73.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps B Ø	61.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps C Ø	64.0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Operation Checked?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Output Voltage Level	0	VAC
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Min Tap Position	3L	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Operations Since Last Insp	124	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC As Found Counter	4200	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC As Left Counter	4200	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Current Tap Position	1R	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Left Counter	32540	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Found Counter	32540	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50	VDC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 7:17	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	General Comments	out of service	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	LTC Totalizer Reading	0	kw
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Max	25	°C
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Reading	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	General Comments	out of service	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53	VDC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	BCH001567	Charger	694-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	27	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Totalizer Meter Reading	.2650	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Winding Temp Max	55	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X1 Winding Temp Present	32	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X2 Winding Temp Present	34	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X3 Winding Temp Present	33	°C
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	LTC Totalizer Reading	6360.00	kw
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	General Comments	conduit and fittings in station	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 7:17	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	9 Month Operations	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Unknown Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations This Read Vac	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AL	156	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AF	156	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps C Ø	305	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps B Ø	325	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps A Ø	322	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Unknown Operations	3	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations This Read Vac	3	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AL	168	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AF	168	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	9 Month Operations	8	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	9 Month Operations VCB New	5	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty A Ph V	1.4	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty B Ph V	1.4	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty C Ph V	1.4	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps A Ø	123	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps B Ø	131	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps C Ø	121	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps A Phase V	18.81	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps B Phase V	18.81	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps C Phase V	18.81	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	9 Month Operations	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps A Ø	9	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps B Ø	7	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Unknown Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AL	152	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AF	152	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps C Ø	12	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps C Ø	294	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps B Ø	275	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps A Ø	258	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty C Ph V	18.69	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty B Ph V	18.69	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty A Ph V	17.76	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AF	422	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AL	422	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Unknown Operations	0	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 7:19	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps C Phase V	12.26	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps B Phase V	12.26	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps A Phase V	12.26	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps C Ø	201	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps B Ø	173	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps A Ø	205	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	9 Month Operations VCB New	2	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AF	189	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AL	189	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations This Read Vac	2	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Unknown Operations	2	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	9 Month Operations	4	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AF	502	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AL	502	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Unknown Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps C Ø	198	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps B Ø	197	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps A Ø	192	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty C Ph V	21.03	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty B Ph V	17.29	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty A Ph V	16.82	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations VCB New	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations	4	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Maintenance Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AF	255	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AL	255	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations This Read Vac	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Switching Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Unknown Operations	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps C Ø	400	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations A Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations B Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations C Ø	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations Ground	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps B Ø	400	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps A Ø	400	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations	1	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Found Counter	59428	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Left Counter	59428	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Operations Since Last Insp	685	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Max	70	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Reading	.585	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	LTC Totalizer Reading	8424	kw
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	LTC Totalizer Reading	15148.8	kw
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Max	85	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Present	55	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Reading	1.052	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Max	85	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Present	50	°C
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	All Connections OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Left Counter	103646	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Current Tap Position	2L	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Max Tap Position	3R	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Min Tap Position	7L	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Operations Since Last Insp	502	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Found Counter	103646	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.6	amps
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 7:09	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Winding Temp Max	48	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Totalizer Meter Reading	.201	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	LTC Totalizer Reading	4824	kw
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Oil Temp Present	33	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC As Found Counter	7774	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Operations Since Last Insp	390	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC As Left Counter	7774	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	LTC Operation Checked?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	All Connections OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations Counter AF	58	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations Counter AL	58	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	9 Month Operations	6	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	9 Month Operations VCB New	6	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty A Ph V	.11	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty B Ph V	.11	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps A Ø	72	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps B Ø	68	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps C Ø	65	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Operations Counter AL	198	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Operations Counter AF	198	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Amps C Ø	89	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	9 Month Operations	9	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	9 Month Operations VCB New	9	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Accumulated Fault Duty A Ph V	.21	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Amps B Ø	86	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Amps A Ø	71	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	9 Month Operations	13	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations Counter AL	111	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations Counter AF	111	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	9 Month Operations VCB New	13	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty B Ph V	.53	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty C Ph V	.16	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps A Ø	5	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps C Ø	19	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps B Ø	16	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	9 Month Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations Counter AF	149	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations Counter AL	149	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	9 Month Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	9 Month Operations VCB New	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations Counter AL	175	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations Counter AF	175	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations C Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	9 Month Operations	1	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	9 Month Operations VCB New	1	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps A Ø	139	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps B Ø	165	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps C Ø	161	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations Ground	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Maintenance Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations Counter AF	143	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations Counter AL	143	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations This Read Vac	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Switching Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations B Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations A Ø	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Unknown Operations	0	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Vegetation	None	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	General Comments		
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/14/2023 6:59	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67016	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62243	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27928	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations C Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations B Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps C Ø	99	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations Ground	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps A Phase V	14.43	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps B Phase V	14.43	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps B Ø	103	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps A Ø	124	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps C Phase V	14.43	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations A Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Maintenance Operations	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations	3	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Unknown Operations	3	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Switching Operations	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations This Read Vac	3	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AL	243	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AF	243	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations	1	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty A Ph V	.72	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty C Ph V	.72	%
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps A Ø	32	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Maintenance Operations	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations C Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps B Ø	53	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps C Ø	24	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations B Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations A Ø	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Unknown Operations	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AF	295	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Switching Operations	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations Ground	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AL	295	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations This Read Vac	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Left Counter	11975	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Found Counter	11975	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Operations Since Last Insp	300	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Reading	.5922	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Present	50	°C
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Max	60	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	LTC Totalizer Reading	5685.12	kw
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51	VDC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/13/2023 14:37	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	General Comments	Neighbors fence is within inches of station fence.	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1084.32	kw
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Max	53	°C
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Present	33	°C
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4518	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Operations Counter	11	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps C Ø	102.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitrogen gauge.	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Operations Counter	523	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps C Ø	42.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps B Ø	74.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Regulator As Left Counter	184520	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Regulator As Left Counter	101563	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Operations Counter	1046	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	General Comments	ok	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps A Ø	11.5	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps B Ø	17.1	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps C Ø	12.5	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:43	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Regulator As Left Counter	197416	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2884.32	kw
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2018	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	141.00	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 14:30	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	13.68	kw
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0228	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Present	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Present	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 14:10	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Unknown Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Switching Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations This Read Vac	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations Ground	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations C Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations B Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations A Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps C Ø	87.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps B Ø	85.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps A Ø	80.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	9 Month Operations VCB New	14	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Maintenance Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations Counter AF	174	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations Counter AL	174	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	9 Month Operations	14	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Unknown Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Switching Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations Counter AL	164	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations Counter AF	164	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Maintenance Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations Ground	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations C Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations B Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations A Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	9 Month Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps A Ø	45.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps B Ø	63.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps C Ø	70.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	9 Month Operations VCB New	14	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	9 Month Operations	14	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps A Ø	40.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations A Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps B Ø	42.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps C Ø	33.0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations B Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations C Ø	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations Ground	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Maintenance Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations Counter AF	189	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations Counter AL	189	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations This Read Vac	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Switching Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Unknown Operations	0	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Operations Since Last Insp	948	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Min Tap Position	6R	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Max Tap Position	14R	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Current Tap Position	14R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC As Left Counter	71167	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC As Found Counter	71167	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.2	VDC
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	LTC Totalizer Reading	6727.68	kw
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Totalizer Meter Reading	.7008	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Winding Temp Max	60	°C
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Regulator As Left Counter	112131	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.7	VDC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Regulator As Left Counter	103328	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	General Comments		
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 13:27	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Regulator As Left Counter	110917	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Operations Counter	71	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Operations Counter	31	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Regulator As Left Counter	7442	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Min Tap Position	3L	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Max Tap Position	6R	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 13:16	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5082	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1626.24	kw
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations This Read Vac	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AL	147	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AF	147	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Switching Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Unknown Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Maintenance Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations Ground	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations C Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations B Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations A Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps C Ø	135.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps B Ø	110.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps A Ø	105.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations	1	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations	1	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps A Ø	60.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps B Ø	75.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps C Ø	88.0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations A Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations B Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations C Ø	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations Ground	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Maintenance Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Unknown Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Switching Operations	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations This Read Vac	0	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AL	132	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AF	132	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	General Comments	Need to bring spare fuses.	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	General Comments	ok	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 13:23	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Regulator As Left Counter	90290	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Regulator As Left Counter	92757	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Regulator As Left Counter	137875	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7287	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	General Comments	AL 123.8	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7495	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7187	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	General Comments	AL 123.7	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6642	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Max	51	°C
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	531.36	kw
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2814	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2026.08	kw
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Unknown Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	9 Month Operations GCB New	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Switching Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations This Read SF6	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations Counter AL	101	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations Counter AF	101	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Num Operations Last 9 Months	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Maintenance Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps A Ø	13.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps B Ø	11.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps C Ø	15.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Fault Operations	0	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	General Comments	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Ambient Temperature	64	°F
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	SF6 Pressure	66	psi
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Unknown Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	9 Month Operations	3	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	9 Month Operations VCB New	3	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps A Ø	18.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps B Ø	16.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps C Ø	23.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations A Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations B Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations C Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations Ground	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Switching Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations This Read Vac	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations Counter AL	180	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations Counter AF	180	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Maintenance Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	General Comments		
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps A Ø	47.7	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Operations Counter	250	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps C Ø	45.4	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps B Ø	47.4	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps A Ø	32.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	9 Month Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps B Ø	28.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps C Ø	27.0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations A Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations B Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Unknown Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Switching Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations This Read Vac	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations Counter AL	171	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations Counter AF	171	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Maintenance Operations	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations C Ø	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations Ground	0	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Operations Counter	88	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.300	millivolts
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.3	amps
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BCH001437	Charger	492-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	18.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	4.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	20	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	BAT001507	Battery	492-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	624	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	2184	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	2176	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 12:27	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	.3540	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	41	°C
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	849.60	kw
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off ground....left corner post of station is washing out. Fence has places that has been pieced tc	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments	Boom needs gravel on high side	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	VRR Time Delay	45	Seconds
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	General Comments		
11/13/2023 12:23	Distribution	Deer Branch Quarterly Inspection	LTCC000889	LTCControl	575-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.9	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.1	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps C Ø	3.0	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Operations Counter	304	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	General Comments	ok	
11/13/2023 12:34	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	9 Month Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps A Ø	100.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps B Ø	100.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps C Ø	120.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Switching Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations This Read Vac	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AL	85	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AF	85	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations A Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations B Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations C Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations Ground	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Maintenance Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Unknown Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Switching Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations This Read Vac	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AL	267	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AF	267	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Maintenance Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations Ground	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations C Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations B Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations A Ø	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps C Ø	139.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps B Ø	118.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps A Ø	93.0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations	0	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Found Counter	68047	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Left Counter	68047	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Max Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Operations Since Last Insp	367	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Reading	.6910	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	LTC Totalizer Reading	2211.20	kw
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	BCH001543	Charger	649-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	General Comments	there is no spill kit in sub	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 12:09	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.5	VDC
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.5	VDC
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BAT001652	Battery	514-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	General Comments	Fiber cabinet needs replacing	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.4	VDC
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.4	VDC
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Regulator As Left Counter	138471	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Regulator As Left Counter	261499	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Regulator As Left Counter	205252	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	General Comments	AL 124.1	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3156	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	378.72	kw
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	General Comments	Rusted tank, max gauge arm broken	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	General Comments	max hand broken	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	General Comments	rusted tank, max arm broken	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations A Ø	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations B Ø	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations This Read Vac	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Switching Operations	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Unknown Operations	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AL	213	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AF	213	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Maintenance Operations	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations Ground	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations C Ø	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps C Ø	31.0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps B Ø	19.0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps A Ø	23.0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations	0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	291	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	36	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	213	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	118841	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	136740	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115155	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	496.80	kw
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Present	22	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.4140	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Max	46	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	22	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	44	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	1470	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	7L	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	10R	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	389491	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	389481	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	General Comments	Added oil	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	1730.16	kw
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	48	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	32	°C
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	.9612	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	General Comments	fence fabric and railing rusty	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 11:42	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	General Comments	All equipment has been removed. ALL GROUND HAVE BEEN REMOVED	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Trash?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
11/13/2023 11:32	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	General Comments	fuse barrells need replacing.	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	General Comments	lots of rust on top rails	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:47	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.1	VDC
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34953	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37163	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	General Comments	lower arm slugish, but did reset	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Regulator As Left Counter	32216	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Max	52	°C
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1355.04	kw
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	General Comments		
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Present	27	°C
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5646	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BAT001684	Battery	508-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Regulator As Left Counter	39550	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	General Comments	Had to adjust low band. Left working	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Regulator As Left Counter	90524	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Unknown Operations	0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Switching Operations	0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations This Read Vac	12	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations Counter AL	189	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations Counter AF	189	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Maintenance Operations	0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	General Comments	3 ABCG ops	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations Ground	3	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations C Ø	3	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations B Ø	3	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations A Ø	3	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps C Phase V	7.89	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps B Phase V	7.89	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps A Phase V	7.89	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps C Ø	23.0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps B Ø	33.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps A Ø	32.0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	9 Month Operations VCB New	2	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	9 Month Operations	14	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Regulator As Left Counter	102689	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Regulator As Left Counter	73902	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Regulator As Left Counter	120772	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	General Comments	AL 124.2	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Regulator As Left Counter	80401	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	2	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations VCB New	2	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	75.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	53.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	94.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	174	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	174	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations This Read Vac	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Operations Counter	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps C Ø	92.0	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps B Ø	88.0	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps A Ø	106.0	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	General Comments	134/117/119	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations This Read Vac	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	184	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	184	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	88.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	41.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	50.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1144.80	kw
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4770	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations This Read Vac	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	200	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	200	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	111.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	113.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	108.0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	0	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5016	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1203.84	kw
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Max	28	°C
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	3795	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	3802	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	7L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	1R	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	675	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	LTCC000980	LTCControl	508-2	LTC Control Insp	All Connections OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	LTC Totalizer Reading	2162.88	kw
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Max	50	°C
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Present	50	°C
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Reading	.4506	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations	2	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations A Ø	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations B Ø	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations C Ø	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations Ground	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Maintenance Operations	0	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AF	195	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AL	195	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations This Read Vac	2	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Switching Operations	2	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Unknown Operations	0	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	General Comments	SPR disabled	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 11:11	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	General Comments	ok	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 11:26	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.5	VDC
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 11:03	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	55.0	VDC
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Regulator As Left Counter	457514	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Regulator As Left Counter	910072	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Regulator As Left Counter	258299	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5538	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Present	42	°C
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	443.04	kw
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps A Ø	40.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps B Ø	60.0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps C Ø	20.0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations A Ø	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations B Ø	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations C Ø	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations Ground	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Maintenance Operations	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AF	143	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AL	143	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations This Read Vac	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Switching Operations	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Unknown Operations	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Unknown Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Switching Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations This Read Vac	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AL	139	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AF	139	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Maintenance Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations Ground	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations C Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations B Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations A Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps C Ø	40.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps B Ø	60.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps A Ø	60.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps B Ø	40.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps C Ø	40.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps A Ø	60.0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	9 Month Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AL	131	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AF	131	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Maintenance Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations Ground	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations C Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations A Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations B Ø	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Unknown Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations This Read Vac	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Switching Operations	0	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 10:13	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	9 Months Operations OCB New	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Fault Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Maintenance Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Number of Ops last 9 Months	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AF	57	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AL	57	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations This Read Oil	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Switching Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Unknown Operations	0	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-05-12 00:00:00.000000	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Leaks	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Pressure OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Leaks	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Left Counter	104739	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Found Counter	104739	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Operations Since Last Insp	196	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Reading	.6378	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	LTC Totalizer Reading	4592.16	kw
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.6	VDC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 10:10	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.3	VDC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BAT001670	Battery	888-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Regulator As Left Counter	81794	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Max Tap Position	8R	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Regulator As Left Counter	85288	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Max Tap Position	7R	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Regulator As Left Counter	84567	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Max Tap Position	7R	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Max	70	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2099.52	kw
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2916	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Max	65	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Unknown Operations	1	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Switching Operations	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations This Read Vac	1	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AL	179	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AF	179	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Maintenance Operations	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations A Ø	0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps C Phase V	1.75	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps B Phase V	1.75	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps A Phase V	1.75	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps C Ø	67.0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps B Ø	69.0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps A Ø	61.0	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations	2	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Regulator As Left Counter	22051	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50573	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Regulator As Left Counter	68445	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	BAT001612	Battery	510-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps A Ø	90.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps B Ø	91.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps C Ø	95.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Unknown Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Switching Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations This Read Vac	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AL	14	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AF	14	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Maintenance Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations A Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations	2	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations VCB New	1	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps A Ø	83.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps B Ø	87.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps C Ø	87.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps A Phase V	1.75	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations A Ø	1	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Maintenance Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AF	4	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AL	4	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations This Read Vac	1	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Switching Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Unknown Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps B Ø	115.0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps A Ø	126.0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps C Ø	118.0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Unknown Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Switching Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations This Read Vac	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AL	159	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AF	159	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Maintenance Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations A Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Unknown Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Switching Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations This Read Vac	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AL	170	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AF	170	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations	2	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations VCB New	2	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Maintenance Operations	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations A Ø	0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps C Ø	90.0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps B Ø	125.0	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps A Ø	83.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5091.84	kw
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Max	37	°C
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0608	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AL	121.5	VAC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AF	121.5	VAC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Output Voltage Level	121.9	VAC
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Operations Since Last Insp	654	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Min Tap Position	2L	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Max Tap Position	10R	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Current Tap Position	2R	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Left Counter	216733	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Found Counter	216725	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.5	VDC
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BAT001665	Battery	689-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Regulator As Left Counter	91533	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Regulator As Left Counter	88322	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91280	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Reading	.1680	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Present	48	°C
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Max	48	°C
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	LTC Totalizer Reading	1344.00	kw
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	General Comments	Xfmr fuses are starting to fray and 1407T handle doesn't have a ground strap. Bus needs wildlife protection.	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 9:20	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 9:36	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Maintenance Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations A Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps C Ø	303.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps B Ø	275.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps A Ø	297.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AF	183	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AL	183	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations This Read Vac	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Switching Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Unknown Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Unknown Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Switching Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations This Read Vac	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AL	74	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AF	74	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Maintenance Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	General Comments	Breaker is offline	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations Ground	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations C Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations B Ø	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps C Ø	0.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps B Ø	0.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps A Ø	0.0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations VCB New	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations	0	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	General Comments	ok	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	General Comments	The plant has a small section of fence connected to ours. Pictures were taken and will be uploaded to distsubs.	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 9:43	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Operations Counter	179	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	General Comments	ok	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	General Comments		
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Regulator As Left Counter	155411	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BAT001662	Battery	640-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	All Connections OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	General Comments	hands drag a bit but reset	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Found Counter	9695	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Operations Since Last Insp	489	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Left Counter	9699	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	LTC Totalizer Reading	1961.28	kw
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Max	65	°C
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Max	0	°C
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Present	0	°C
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Reading	.5448	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	General Comments		
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	259.56	kw
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4326	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations This Read Vac	1	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Switching Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Unknown Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AL	44	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AF	44	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Maintenance Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations Ground	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations C Ø	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations B Ø	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations A Ø	1	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps A Phase V	1.75	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps C Ø	20.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps B Ø	30.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps A Ø	90.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations VCB New	2	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations	3	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations	4	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations VCB New	3	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps A Ø	10.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps B Ø	0.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps C Ø	5.0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps B Phase V	1.75	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations A Ø	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Unknown Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Switching Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations This Read Vac	1	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AL	1566	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AF	1566	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Maintenance Operations	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	General Comments	1 op Inst flag B/C-G	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations Ground	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations C Ø	0	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations B Ø	1	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2023 8:47	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	General Comments	There aren't any spare fuse barrels.	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	General Comments		
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2023 8:48	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Switching Operations	1	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations This Read Vac	1	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AL	266	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AF	266	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps C Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps B Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps A Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations VCB New	1	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations	2	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Switching Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AF	194	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AL	194	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations This Read Vac	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps C Ø	122.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps B Ø	117.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps A Ø	130.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations VCB New	3	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations	3	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations	1	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations VCB New	1	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps A Ø	197.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps B Ø	175.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps C Ø	175.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AF	168	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AL	168	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations This Read Vac	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Switching Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AF	198	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AL	198	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations This Read Vac	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps C Ø	212.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps B Ø	212.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps A Ø	201.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations VCB New	2	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations	2	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations	10	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations VCB New	8	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps A Ø	128.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps B Ø	128.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps C Ø	122.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations This Read Vac	2	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Switching Operations	2	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AL	186	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AF	186	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps B Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps C Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps A Ø	0.0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Unknown Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Switching Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AL	152	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AF	152	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations	0	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Found Counter	52009	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Left Counter	52009	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1204	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	General Comments		
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2023 12:19	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.8	VDC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.8	VDC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	°F
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.0	VDC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	LTCC000982	LTCControl	653-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Max Tap Position	1L	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Operations Since Last Insp	562	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Found Counter	2019	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Left Counter	2026	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	LTC Totalizer Reading	3735.36	kw
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Present	34	°C
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Reading	.7782	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps C Ø	33.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps B Ø	31.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps A Ø	35.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations A Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations B Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations C Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations Ground	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Maintenance Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations	4	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations VCB New	4	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AF	207	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AL	207	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations This Read Vac	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Switching Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Unknown Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Maintenance Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AF	229	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations Ground	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations C Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations B Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations A Ø	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AL	229	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations This Read Vac	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Switching Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Unknown Operations	0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps C Ø	36.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps B Ø	33.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Amps A Ø	44.0	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	9 Month Operations VCB New	15	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	9 Month Operations	15	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 14:12	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations A Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations B Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations C Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations Ground	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Maintenance Operations	3	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps C Ø	77.0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps B Ø	69.0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps A Ø	73.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	9 Month Operations VCB New	2	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations Counter AF	180	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations Counter AL	180	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations This Read Vac	4	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Switching Operations	1	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Unknown Operations	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	9 Month Operations	6	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps C Ø	89.0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps B Ø	95.0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps A Ø	83.0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Unknown Operations	1	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Switching Operations	1	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations This Read Vac	2	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AL	188	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AF	188	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Maintenance Operations	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations VCB New	3	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations	5	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations Ground	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations C Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations B Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations A Ø	0	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Found Counter	16535	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Left Counter	16541	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Current Tap Position	8L	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Max Tap Position	3L	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Min Tap Position	11L	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Operations Since Last Insp	836	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	VRR Time Delay	60	Seconds
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	LTC Output Voltage Level	122.9	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	All Connections OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Reading	.5058	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Max	35	°C
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	LTC Totalizer Reading	4855.68	kw
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Regulator As Left Counter	275781	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Operations Since Last Insp	937	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Left Counter	17374	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Found Counter	17370	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Present	39	°C
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Max	49	°C
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Reading	.4806	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	LTC Totalizer Reading	3460.32	kw
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Regulator As Left Counter	361654	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Regulator As Left Counter	557228	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	General Comments	ok	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Swept?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Broom on Site?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 15:25	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps C Ø	.6	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps B Ø	.5	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps A Ø	.4	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Operations Counter	228	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Operations Counter	0	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	General Comments	Counters:265/247/241	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	894.24	kw
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1178	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1668	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	6L	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8R	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3L	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Left Counter	51622	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Found Counter	51622	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	85	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	90	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	90	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Max	40	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	General Comments	Fence is not connected but within two feet.	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	General Comments	ok	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 13:58	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AL	117	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	4	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations VCB New	4	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	68.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	44.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	83.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AF	117	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	3	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations VCB New	3	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	40.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	53.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	83.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	169	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	169	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps A Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps B Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps C Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AF	144	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AL	144	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	20	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations VCB New	8	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	18.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	17.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	18.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	67.08	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	6	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations This Read Vac	12	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	6	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	164	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	164	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AL	139	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AF	139	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps C Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps B Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps A Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	9 Month Operations	3	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	9 Month Operations VCB New	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations This Read Vac	2	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Switching Operations	2	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps A Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps B Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AF	138	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AL	138	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	171	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	6	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations VCB New	5	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	171	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	General Comments	open	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps C Ø	151.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps B Ø	115.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps A Ø	124.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations This Read Vac	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Switching Operations	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	9 Month Operations VCB New	1	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	9 Month Operations	2	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AF	133	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AL	133	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	36	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations VCB New	36	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	106.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	121.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	114.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AF	205	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AL	205	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	192	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	192	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	18.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	18.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	1.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations VCB New	20	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	20	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AF	163	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AL	163	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	General Comments	DNO	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps C Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps B Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	9 Month Operations	18	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	9 Month Operations VCB New	18	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps A Ø	0.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	214	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	229.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	225.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	236.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations VCB New	27	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	214	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	27	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations	26	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations VCB New	26	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps A Ø	340.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	356.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps C Ø	350.0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Maintenance Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AF	181	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AL	181	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations This Read Vac	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Switching Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Unknown Operations	0	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	35	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	35	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	35	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	35	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	45	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	50	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	40	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	40	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	35	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	45	°C
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	134	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Min Tap Position	7L	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4L	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Left Counter	85145	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Found Counter	85145	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	350	psi
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	General Comments	Needs nitro	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.9	VDC
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 13:29	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24420	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25640	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23519	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Max	56	°C
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	268.80	kw
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6720	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Unknown Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Switching Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations This Read AM	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AL	411	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AF	411	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Maintenance Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps C Ø	60.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps B Ø	50.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps A Ø	50.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations Ground	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Months Operations	10	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Month Ops New	10	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	General Comments	Needs wildlife protection on secondary side.	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	9 Month Ops New	18	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps A Ø	50.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps B Ø	40.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps C Ø	40.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations Ground	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Maintenance Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AF	234	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AL	234	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations This Read AM	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Switching Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Unknown Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations Ground	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Maintenance Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AF	99950	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AL	99950	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations This Read AM	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Switching Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Unknown Operations	0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Months Operations	13	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Month Ops New	13	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps C Ø	100.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps B Ø	100.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps A Ø	100.0	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Switching Operations	0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations This Read Vac	1	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AL	192	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AF	192	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Maintenance Operations	0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	General Comments	1 op - BN T	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations Ground	0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations C Ø	0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations B Ø	1	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations A Ø	0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps B Phase V	1.31	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps C Ø	55.0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps B Ø	30.0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps A Ø	40.0	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations VCB New	3	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations	4	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Left Counter	508811	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1434	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Found Counter	508811	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 13:04	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.4	VDC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BAT001661	Battery	869-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Found Counter	24057	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Left Counter	24069	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Operations Since Last Insp	1081	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	27	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Present	39	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Max	3	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Reading	.5502	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Max	57	°C
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	LTC Totalizer Reading	7922.88	kw
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	General Comments	Nitro bottle at 1100psi.	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps C Ø	220.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps B Ø	233.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps A Ø	214.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Unknown Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Switching Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations This Read Vac	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AL	154	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AF	154	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Maintenance Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations Ground	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations B Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations A Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps A Ø	13.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps B Ø	12.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps C Ø	13.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations A Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations B Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations C Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations Ground	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Maintenance Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AF	236	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AL	236	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations This Read Vac	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Switching Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Unknown Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations	3	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations VCB New	3	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps A Ø	73.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps B Ø	80.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps C Ø	76.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations A Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations B Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations C Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations Ground	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Maintenance Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AF	206	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AL	206	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Unknown Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations This Read Vac	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Switching Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps B Ø	138.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps A Ø	131.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AL	202	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AF	202	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Maintenance Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations Ground	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations C Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations B Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations A Ø	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps C Ø	134.0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Unknown Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Switching Operations	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations This Read Vac	0	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	General Comments	There are four wildlife disks missing from the two transfer switches.	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	General Comments	ok	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 12:47	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	45	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	51	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	44	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	51	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	115.92	kw
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	52	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	44	°C
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0276	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	7.0	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	213	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 12:00	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Switching Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations This Read SF6	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AL	394	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AF	394	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Num Operations Last 9 Months	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	9 Month Operations GCB New	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps A Ø	56.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps B Ø	40.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps C Ø	50.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Fault Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AF	675	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	9 Month Operations GCB New	14	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps A Ø	70.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AL	675	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations This Read SF6	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Switching Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Num Operations Last 9 Months	14	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps B Ø	97.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps C Ø	85.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Fault Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations This Read SF6	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AL	571	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AF	571	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Num Operations Last 9 Months	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Fault Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps C Ø	76.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps B Ø	81.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps A Ø	75.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	9 Month Operations GCB New	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Switching Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations This Read SF6	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AL	749	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AF	749	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Num Operations Last 9 Months	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Fault Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps C Ø	125.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps B Ø	128.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps A Ø	85.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	9 Month Operations GCB New	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AL	406	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations This Read SF6	3	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Switching Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AF	406	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Num Operations Last 9 Months	3	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	General Comments	A, B, C phase IOC	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Fault Operations	3	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	9 Month Operations GCB New	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps A Ø	175.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps B Ø	168.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps C Ø	177.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations This Read SF6	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Switching Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Unknown Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AL	370	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AF	370	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Num Operations Last 9 Months	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Maintenance Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Fault Operations	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps C Ø	443.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps B Ø	448.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	9 Month Operations GCB New	0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps A Ø	443.0	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1081	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Found Counter	118202	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Left Counter	118202	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	57	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	General Comments		
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/10/2023 14:36	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.1	VDC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.5	VDC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BAT001688	Battery	699-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.6	VDC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	General Comments	Left at 124.2V	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Left Counter	17814	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Found Counter	17805	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Operations Since Last Insp	849	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Min Tap Position	15L	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	LTC Totalizer Reading	8380.80	kw
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Max	77	°C
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Reading	.5820	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Max	80	°C
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Present	47	°C
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Found Counter	386050	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Left Counter	386050	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	537	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	General Comments	Two fans are not working.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1322	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Left Counter	335403	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Found Counter	335403	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Unknown Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Switching Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations This Read Vac	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps A Ø	360.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps B Ø	384.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps C Ø	372.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations A Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations B Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations C Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations Ground	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Maintenance Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AF	161	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AL	161	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	General Comments	ok	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AF	272	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AL	272	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Months Operations	3	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Month Ops New	3	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps A Ø	80.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps B Ø	80.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps C Ø	80.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Switching Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations This Read AM	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AL	421	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AF	421	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Maintenance Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations Ground	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations Ground	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations This Read AM	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AL	366	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Maintenance Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AF	366	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Switching Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps C Ø	50.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps B Ø	50.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps A Ø	50.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Months Operations	1	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Month Ops New	1	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Reading	.7740	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Present	33	°C
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Max	49	°C
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	LTC Totalizer Reading	1857.60	kw
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps A Ø	282.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps B Ø	276.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps C Ø	264.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations A Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations B Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations C Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Unknown Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Switching Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations This Read Vac	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AL	11	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations Ground	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AF	11	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Maintenance Operations	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	General Comments	ok	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Operations Since Last Insp	895	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Min Tap Position	3L	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Found Counter	86563	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Left Counter	86567	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AF	413	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Maintenance Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations Ground	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations C Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps C Ø	40.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps B Ø	40.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps A Ø	40.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Months Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Month Ops New	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AL	413	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations This Read AM	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Switching Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations This Read AM	1	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Switching Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Month Ops New	1	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Months Operations	2	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps A Ø	100.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps B Ø	100.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps C Ø	100.0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AL	197	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AF	197	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Maintenance Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations A Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations B Ø	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations C Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations Ground	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	General Comments	c phase ioc	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Operations Counter	7	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations VCB New	1	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations	7	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps C Ø	99.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps B Ø	108.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps A Ø	102.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations A Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations B Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations C Ø	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations Ground	0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	General Comments	2 switching ops and 4 maintenance ops when commissioning SEL.	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Maintenance Operations	4	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AF	215	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AL	215	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations This Read Vac	6	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Switching Operations	2	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Unknown Operations	0	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2023 11:12	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	General Comments	ok	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Operations Counter	501	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	General Comments		
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps C Ø	11.0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
11/9/2023 15:13	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	General Comments	Old sub from factory has fence connected to ours and 2 sides of site fence.	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	General Comments	SPR has been disabled and removed.	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 11:23	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BCH001623	Charger	712-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.9	VDC
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	BAT001695	Battery	712-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Regulator As Left Counter	177458	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	General Comments	Counter not working	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10300	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Regulator As Left Counter	304553	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9390	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2253.60	kw
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations C Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations B Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps C Ø	90.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps B Ø	66.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps A Ø	90.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Maintenance Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AF	142	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AL	142	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations This Read Vac	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Switching Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Unknown Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations C Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations B Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps C Ø	126.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps B Ø	132.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps A Ø	132.0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Unknown Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Switching Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations This Read Vac	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AL	185	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AF	185	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Maintenance Operations	0	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps C Ø	55.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps B Phase V	5.33	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps C Phase V	5.33	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations B Ø	1	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations C Ø	1	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Unknown Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Switching Operations	1	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps B Ø	62.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Maintenance Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AF	203	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps A Ø	56.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations VCB New	2	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations	5	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AL	203	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations This Read Vac	3	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection. One xfmr fuse barrel is starting to fray.	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	General Comments	ok	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	General Comments	Small washout in back right portion of station.	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 10:35	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Unknown Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Switching Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations This Read Vac	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AL	213	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AF	213	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Maintenance Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps C Ø	47.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps B Ø	34.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations B Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations C Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps A Ø	37.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations	4	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations VCB New	4	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations	11	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Maintenance Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations C Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AF	208	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations VCB New	10	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AL	208	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations This Read Vac	1	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Switching Operations	1	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Unknown Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps A Ø	64.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps B Ø	50.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps C Ø	54.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations B Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations	10	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations VCB New	10	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Unknown Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Switching Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations This Read Vac	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AL	137	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AF	137	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Maintenance Operations	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps A Ø	96.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps B Ø	160.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps C Ø	192.0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations A Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations B Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations C Ø	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations Ground	0	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	LTCC000991	LTCControl	337-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Operations Since Last Insp	984	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Left Counter	145009	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Found Counter	145006	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	LTC Totalizer Reading	10085.76	kw
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Max	65	°C
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Present	32	°C
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Reading	1.0506	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Max	45	°C
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Present	31	°C
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.9	VDC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8014	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Regulator As Left Counter	133528	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7788	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1421.76	kw
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8886	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 10:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Operations Counter	78	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Operations Counter	323	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	General Comments	1 op- BG	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	General Comments	Bus Discs have fallen, too large for insulators, No spare fuses	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 9:52	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	General Comments	ok	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	75.04	kw
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Present	23	°C
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3752	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BCH001553	Charger	312-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	General Comments	ok	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Regulator As Left Counter	445172	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	General Comments	Fiberglass is starting to fray on spare fuse.	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.1	VDC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	General Comments	ok	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 9:42	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	CH000535	ControlHouse	312-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps A Ø	217.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps B Ø	230.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps C Ø	220.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations VCB New	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations A Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Unknown Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Switching Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations This Read Vac	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AL	179	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AF	179	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Maintenance Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations Ground	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations C Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations B Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps C Ø	74.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps B Ø	90.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps A Ø	88.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations VCB New	3	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations	3	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations A Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations B Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations C Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Unknown Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Switching Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations This Read Vac	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AL	178	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AF	178	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Maintenance Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations Ground	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Unknown Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations This Read Vac	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AL	348	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AF	348	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Maintenance Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations C Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations Ground	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps B Ø	27.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps C Ø	33.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations A Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations B Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps A Ø	21.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations VCB New	1	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations	1	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AL	184	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations This Read Vac	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Unknown Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Switching Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AF	184	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Maintenance Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations Ground	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations C Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations B Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	9 Month Operations	7	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations A Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps C Ø	46.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps B Ø	43.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps A Ø	42.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	9 Month Operations VCB New	7	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Maintenance Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AF	153	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AL	153	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Switching Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations Ground	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations C Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations B Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations A Ø	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps C Ø	87.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps B Ø	89.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps A Ø	89.0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Unknown Operations	0	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	9 Month Operations	1	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	9 Month Operations VCB New	1	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Found Counter	129614	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Left Counter	129616	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Operations Since Last Insp	968	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AL	124.3	VAC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AF	122.9	VAC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	All Connections OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	LTC Totalizer Reading	12009.60	kw
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Max	46	°C
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Present	33	°C
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Reading	1.2510	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67668	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Ambient Temp	58	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 9:35	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Regulator As Left Counter	65576	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56330	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	250.20	kw
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4170	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	General Comments	needs wildlife	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 9:03	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Unknown Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Switching Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations This Read Vac	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AL	166	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AF	166	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Maintenance Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations Ground	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations C Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations B Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations A Ø	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps C Ø	188.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps B Ø	178.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps A Ø	190.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	9 Month Operations VCB New	2	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	9 Month Operations	3	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps C Ø	41.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps B Ø	29.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps A Ø	36.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	9 Month Operations	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations A Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations B Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations C Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations Ground	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Maintenance Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AF	173	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AL	173	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations This Read Vac	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Switching Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Unknown Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps C Ø	49.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps B Ø	59.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations A Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations B Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations C Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations Ground	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Maintenance Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AF	183	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AL	183	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations This Read Vac	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Switching Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Unknown Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	9 Month Operations	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps A Ø	57.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps B Ø	257.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps C Ø	280.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	9 Month Operations	6	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Unknown Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Switching Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations This Read Vac	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AL	145	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AF	145	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Maintenance Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations Ground	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations C Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations B Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations A Ø	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps A Ø	267.0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	9 Month Operations VCB New	6	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Found Counter	229806	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Left Counter	229806	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Current Tap Position	4L	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Max Tap Position	5R	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Min Tap Position	10L	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Operations Since Last Insp	721	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	All Connections OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Present	40	°C
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Max	80	°C
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Reading	.4548	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Present	40	°C
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Max	80	°C
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	LTC Totalizer Reading	8186.40	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Switching Operations	18	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Operations This Read SF6	18	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Operations Counter AL	138	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Operations Counter AF	138	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Num Operations Last 9 Months	31	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Maintenance Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	General Comments		
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	Fault Operations	0	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Readings	9 Month Operations GCB New	13	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Ambient Temperature	78	°F
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	SF6 Pressure Pole 1	68	psi
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	SF6 Pressure Pole 2	68	psi
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	SF6 Pressure	68	psi
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	General Comments	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 13:19	Distribution	Shelbyville Quarterly Inspection	BK001927	BreakerSF6	198-658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Maintenance Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AF	156	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AL	156	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations This Read Vac	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Switching Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps A Ø	191.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps B Ø	235.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps C Ø	220.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	18.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	37.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	23.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	74	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	74	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations This Read Vac	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	113.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	140.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	106.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	226	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	226	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations Ground	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Maintenance Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps C Ø	57.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AF	170	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AL	170	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps B Ø	61.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations This Read Vac	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Switching Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps A Ø	47.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations	3	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	6	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	54.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	55.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	53.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	2	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	217	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	217	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations This Read Vac	3	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	320.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations Ground	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	320.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	320.0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99956	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99956	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations This Read Vac	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	478	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	7L	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	6R	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	3L	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	96734	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	96734	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	All Connections OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.4962	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	60	°C
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	8931.60	kw
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	279790	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	279790	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	450	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.2760	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	2649.60	kw
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/8/2023 12:09	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Fault Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Num Operations Last 9 Months	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AF	47	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AL	47	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations This Read SF6	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Ambient Temperature	75	°F
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	General Comments	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations This Read SF6	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AL	35	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AF	35	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Num Operations Last 9 Months	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Fault Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Switching Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations This Read Vac	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	9 Month Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	General Comments	open	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations Counter AF	168	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations Counter AL	169	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps C Ø	0.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps B Ø	0.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps A Ø	0.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Ambient Temperature	75	°F
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	General Comments	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Found Counter	22239	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Left Counter	22239	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Current Tap Position	6L	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Max Tap Position	7R	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Min Tap Position	9L	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Operations Since Last Insp	853	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	All Connections OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Present	32	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Max	64	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Reading	.5060	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	LTC Totalizer Reading	9108.00	kw
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AF	222	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AL	222	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps C Ø	246.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps B Ø	240.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps A Ø	240.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	33	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	33	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	General Comments	dont see a guage for the nitrigen on LTC	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps B Ø	0.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps C Ø	0.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AF	182	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AL	182	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	9 Month Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps A Ø	0.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	9 Month Operations	2	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	9 Month Operations VCB New	2	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps A Ø	157.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps B Ø	159.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps C Ø	156.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AF	194	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AL	194	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations	3	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps A Ø	81.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps B Ø	80.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps C Ø	87.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AF	216	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AL	216	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps C Ø	309.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps B Ø	329.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps A Ø	322.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AF	235	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AL	235	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps C Ø	430.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps B Ø	480.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps A Ø	460.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	9 Month Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations Counter AF	160	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations Counter AL	161	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations This Read Vac	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Switching Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps A Ø	214.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps B Ø	221.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps C Ø	219.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AF	205	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AL	205	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps A Ø	105.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AL	230	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations This Read Vac	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Switching Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations	3	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations A Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations B Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations C Ø	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations Ground	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps C Ø	92.0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AF	230	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Maintenance Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps B Ø	105.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps A Ø	170.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps B Ø	150.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps C Ø	145.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations Counter AF	160	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations Counter AL	160	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations This Read Vac	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Switching Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Unknown Operations	0	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Operations Since Last Insp	718	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Left Counter	78004	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Found Counter	78004	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	LTC Totalizer Reading	8316.00	kw
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Reading	.4620	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Max	60	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.5	amps
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	General Comments	no fuses in sub	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/8/2023 11:39	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	681	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Found Counter	332342	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Left Counter	332342	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Month Ops New	12	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Maintenance Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps C Ø	20.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps B Ø	20.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps A Ø	20.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AF	376	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AL	376	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations This Read AM	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Switching Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Unknown Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Months Operations	12	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X3 Winding Temp Max	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X2 Winding Temp Max	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X1 Winding Temp Max	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Totalizer Meter Reading	.3972	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Oil Temp Present	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Oil Temp Max	30	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	LTC Totalizer Reading	7149.60	kw
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Maintenance Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AF	537	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AL	537	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps C Ø	240.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Month Ops New	12	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Months Operations	12	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Unknown Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Switching Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations This Read AM	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps A Ø	200.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps B Ø	225.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Unknown Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Switching Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations This Read AM	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AL	407	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AF	407	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Maintenance Operations	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps C Ø	200.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Month Ops New	7	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Months Operations	7	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps B Ø	220.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps A Ø	200.0	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	All Connections OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Operations Since Last Insp	1164	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Min Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Max Tap Position	7R	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC As Left Counter	12690	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC As Found Counter	12684	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Winding Temp Present	33	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Winding Temp Max	33	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Totalizer Meter Reading	.7670	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	LTC Totalizer Reading	13806.00	kw
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Oil Temp Max	32	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Oil Temp Present	32	°C
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	300.0	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations This Read Vac	2	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations Counter AL	213	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations Counter AF	213	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations C Ø	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	9 Month Operations	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps A Ø	45.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps B Ø	23.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps C Ø	31.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations B Ø	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps B Phase V	8.61	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps C Phase V	8.61	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations This Read Vac	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations Counter AL	215	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations Counter AF	215	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	9 Month Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Amps A Ø	15.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Amps B Ø	18.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Amps C Ø	22.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations This Read Vac	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations Counter AL	202	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations Counter AF	202	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps A Ø	59.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	9 Month Operations	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps B Ø	32.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps C Ø	31.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	9 Month Operations	2	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	9 Month Operations VCB New	2	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations This Read Vac	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations Counter AL	191	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations Counter AF	191	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps A Ø	209.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps B Ø	227.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps C Ø	201.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations This Read Vac	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations Counter AL	190	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations Counter AF	190	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps A Ø	91.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	9 Month Operations VCB New	2	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	9 Month Operations	5	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps B Ø	90.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps C Ø	86.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps A Phase V	14.06	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations A Ø	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps A Ø	115.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps B Ø	130.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps C Ø	115.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps A Phase V	12.94	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations A Ø	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	9 Month Operations	4	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations This Read Vac	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations Counter AL	191	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations Counter AF	191	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations Counter AL	185	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations This Read Vac	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations Counter AF	185	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations B Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations A Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps C Ø	62.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations Ground	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations C Ø	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps A Ø	85.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	9 Month Operations	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps B Ø	69.0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000858	LTCControl	124-5	LTC Control Insp	VRR Time Delay	45	Seconds
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Operations Since Last Insp	928	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC As Found Counter	12101	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Min Tap Position	7L	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Max Tap Position	4R	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Current Tap Position	1L	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC As Left Counter	12109	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Fault Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Num Operations Last 9 Months	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations Counter AF	149	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations Counter AL	149	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations This Read SF6	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	General Comments	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 1	68	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 2	68	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 3	68	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Ambient Temperature	55	°F
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations Counter AL	106	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations Counter AF	106	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Num Operations Last 9 Months	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Maintenance Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Fault Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations This Read SF6	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Switching Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Unknown Operations	0	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 3	68	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 2	69	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 1	69	psi
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	General Comments	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Ambient Temperature	55	°F
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	General Comments		
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 14:59	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	170	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	170	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations This Read Vac	13	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	13	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	14	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	3.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	2.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	145.34	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	145.34	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	145.34	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	138.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	147.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	1	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations This Read Vac	17	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	135.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	690	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	690	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	16	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	25	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations VCB New	8	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations This Read AM	22	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	1	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	689	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Maintenance Operations	21	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps C Ø	7.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps B Ø	16.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	689	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps A Ø	6.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Months Operations	25	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Month Ops New	3	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	1	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations This Read AM	11	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	77	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	122.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	102.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	122.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	77	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	19	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	10	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Month Ops New	8	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	53	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations This Read AM	2	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	2	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Month Ops New	2	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	4	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	53	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	259.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	251.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	268.0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	ok	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1204	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	18723	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	18723	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	85	°C
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	155.00	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	80	°C
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 10:08	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	General Comments		
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PF001311	PowerFuse	GA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2023 12:59	Distribution	Gaulbert Quarterly Inspection	PF001311	PowerFuse	GA-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	711.36	kw
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Max	48	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.5928	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.3	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	241	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.2	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.7	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	31	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	DX0110	RecloserHydraulic	880-0317	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	102	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Grounds in Place?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Regulator As Left Counter	39129	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Regulator As Left Counter	304115	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Regulator As Left Counter	262016	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Present	38	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Max	51	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Present	36	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	General Comments		
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	General Comments	some top rail and post showing signs of rust as well as fabric	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/8/2023 10:27	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Maintenance Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AF	236	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AL	236	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Switching Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Unknown Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations This Read Vac	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps C Ø	11.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps B Ø	20.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps A Ø	29.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	9 Month Operations	2	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	9 Month Operations VCB New	2	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	71	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Maintenance Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AF	220	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps C Ø	74.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps B Ø	73.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps A Ø	65.0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AL	220	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations This Read Vac	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Switching Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Unknown Operations	0	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	9 Month Operations VCB New	5	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	9 Month Operations	5	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Operations Since Last Insp	813	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Found Counter	293536	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Left Counter	293544	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Reading	.6138	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Present	46	°C
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	LTC Totalizer Reading	5892.48	kw
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.680	millivolts
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.2	VDC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Swept?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Broom on Site?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	General Comments	tower leg crumbling	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/8/2023 9:14	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Oil Level	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	PT Free of Leaks?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Max	760	°C
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Present	45	°C
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Max	60	°C
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Present	45	℃
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps B Ø	0.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps C Ø	0.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Unknown Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Switching Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations This Read Vac	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AL	287	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AF	287	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Maintenance Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps A Ø	0.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations VCB New	10	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations	10	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps C Ø	27.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps B Ø	26.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps A Ø	21.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations VCB New	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations	4	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Unknown Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Switching Operations	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations This Read Vac	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AL	300	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AF	300	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Maintenance Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps A Ø	12.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps B Ø	11.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps C Ø	11.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Maintenance Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AF	188	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AL	188	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations This Read Vac	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Switching Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Unknown Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Unknown Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Switching Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations This Read Vac	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AL	190	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AF	190	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Maintenance Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations Ground	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps C Ø	38.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps B Ø	38.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps A Ø	34.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations	1	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Ambient Temp	52	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Unknown Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Switching Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations This Read SF6	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations Counter AL	152	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations Counter AF	152	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps A Ø	9.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps B Ø	10.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps C Ø	9.0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Fault Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	General Comments		
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Maintenance Operations	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Num Operations Last 9 Months	0	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Ambient Temperature	52	°F
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	General Comments	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 3	94	psi
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 2	93	psi
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 1	94	psi
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 9:01	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Switching Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations This Read Vac	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AL	207	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AF	207	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps C Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps B Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps A Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	9 Month Operations	2	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Maintenance Operations	5	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AF	99822	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AL	99822	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations	27	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps C Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps B Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations VCB New	21	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps A Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations This Read Vac	6	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Switching Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps C Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps B Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations Counter AF	176	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps A Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	9 Month Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations This Read Vac	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations Counter AL	176	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Amps B Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Amps A Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Amps C Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	9 Month Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Operations Counter AF	101	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Operations Counter AL	101	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Operations This Read Vac	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001542	BreakerVacuum	695-0449	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Operations This Read Vac	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Operations Counter AL	98	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Operations Counter AF	98	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps C Ø	115.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps B Ø	66.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps A Ø	89.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	9 Month Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	9 Month Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps A Ø	37.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps B Ø	33.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps C Ø	27.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Adjusted Amps C Phase V	5.59	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations C Ø	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations Counter AF	112	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations Counter AL	112	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations This Read Vac	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	9 Month Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps A Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps B Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps C Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations Counter AF	95	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations Counter AL	95	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations This Read Vac	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Switching Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Switching Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations This Read Vac	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations Counter AL	123	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations Counter AF	123	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	9 Month Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps A Ø	120.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps B Ø	98.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps C Ø	140.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations Ground	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations C Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations B Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations A Ø	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations Counter AF	161	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations Counter AL	161	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations This Read Vac	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	9 Month Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Amps A Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Amps B Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Amps C Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	All Connections OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Operations Since Last Insp	427	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Max Tap Position	1L	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Current Tap Position	6L	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC As Left Counter	6657	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC As Found Counter	6657	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Winding Temp Present	35	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Winding Temp Max	35	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Totalizer Meter Reading	.3120	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Oil Temp Max	35	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	LTC Totalizer Reading	7488.00	kw
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	All Connections OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	44990	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	44990	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	668	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	20	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	30	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	300	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations This Read SF6	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations Counter AL	117	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations Counter AF	117	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Fault Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps C Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps B Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Num Operations Last 9 Months	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps A Ø	0.0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	9 Month Operations GCB New	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Switching Operations	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	General Comments	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Ambient Temperature	70	°F
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Pressure Pole 1	88	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Pressure Pole 2	88	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Pressure Pole 3	88	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Ambient Temperature	70	°F
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	SF6 Pressure	65	psi
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	General Comments	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Foundation Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Fault Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	9 Month Operations GCB New	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Maintenance Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Num Operations Last 9 Months	1	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations Counter AL	89	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations Counter AF	89	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Unknown Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations This Read SF6	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Switching Operations	0	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 7:04	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 10:49	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations Ground	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Maintenance Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AF	230	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AL	230	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations This Read Vac	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Switching Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Unknown Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations C Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations B Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations A Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps C Ø	33.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps B Ø	32.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps A Ø	41.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	9 Month Operations VCB New	1	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	9 Month Operations	1	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	9 Month Operations	1	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	9 Month Operations VCB New	1	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations This Read Vac	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Switching Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Unknown Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AL	85	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AF	85	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Maintenance Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations Ground	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps A Ø	83.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps B Ø	84.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps C Ø	118.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations C Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations B Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations A Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Unknown Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	9 Month Operations	3	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	9 Month Operations VCB New	3	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations A Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations B Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations C Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations Ground	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Maintenance Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps A Ø	98.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps B Ø	101.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps C Ø	97.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AF	999967	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AL	99967	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations This Read Vac	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Switching Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps A Ø	270.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps B Ø	274.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps C Ø	278.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations A Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations B Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations C Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations Ground	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	9 Month Operations VCB New	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations This Read Vac	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AL	125	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AF	125	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	9 Month Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Switching Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Unknown Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Maintenance Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps A Ø	36.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps B Ø	34.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps C Ø	33.0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	9 Month Operations VCB New	2	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	9 Month Operations	8	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps C Phase V	31.96	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations A Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations B Ø	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations C Ø	6	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations Ground	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Maintenance Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AF	311	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AL	611	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations This Read Vac	6	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Switching Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Unknown Operations	0	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Operations Since Last Insp	768	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Left Counter	115260	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Found Counter	115237	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	LTC Operation Checked?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	All Connections OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	LTC Totalizer Reading	10598.40	kw
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Max	33	°C
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Present	33	°C
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Reading	1.1040	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Max	43	°C
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Present	29	°C
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	124.1	psi
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4110	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1972.80	kw
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Present	25	°C
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Regulator As Left Counter	35101	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/7/2023 12:55	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Regulator As Left Counter	32222	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Regulator As Left Counter	8004	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps B Ø	13.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps C Ø	9.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Operations Counter	69	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	General Comments		
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Operations Counter	61	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.8	VDC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Reading	.7860	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	General Comments	max drag hand does not appear to be working.	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	LTC Totalizer Reading	7545.60	kw
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Found Counter	53474	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Operations Since Last Insp	993	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Left Counter	53478	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	All Connections OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Operation Checked?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations VCB New	2	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations	5	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps A Ø	79.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps B Ø	86.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps C Ø	80.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations C Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations B Ø	1	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations A Ø	1	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations Ground	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Unknown Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Switching Operations	1	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations This Read Vac	3	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AL	200	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AF	200	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Maintenance Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Switching Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations This Read Vac	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations Counter AL	199	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations Counter AF	199	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Maintenance Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Unknown Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	9 Month Operations	11	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	9 Month Operations VCB New	11	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps A Ø	22.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps B Ø	32.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps C Ø	29.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations A Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations B Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations C Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations Ground	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	9 Month Operations VCB New	7	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	9 Month Operations	8	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps A Ø	19.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Unknown Operations	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Switching Operations	1	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations This Read Vac	1	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps B Ø	34.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps C Ø	21.0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations Counter AL	220	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations Counter AF	220	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	General Comments		
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations A Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Follow-up Action Required?	n	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations Ground	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations B Ø	0	
11/7/2023 15:25	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations C Ø	0	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	22987	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	22987	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	749	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	34	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	49	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	34	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	55	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	34	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	53	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	18874	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	18874	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	622	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	31	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1175	psi
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	37	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	53	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	37	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	53	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	53	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	31	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	48	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	36	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	52	°C
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	General Comments	recloser open	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Operations Counter	33	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0274	RecloserHydraulic	386-4405	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	33	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	General Comments	171/172/195	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps A Ø	36.0	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.6	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps B Ø	41.5	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Operations Counter	172	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	General Comments	ok	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 10:38	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Regulator As Left Counter	274953	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Regulator As Left Counter	350717	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15780	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	VRR Time Delay	45	Seconds
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	All Connections OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	LTCC000986	LTCControl	386-1 A	LTC Control Insp	LTC Operation Checked?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	607.20	kw
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2530	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/7/2023 10:32	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Months Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Month Ops New	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations Ground	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AL	446	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AF	446	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps A Ø	190.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Maintenance Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps B Ø	110.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations C Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps C Ø	195.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations B Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations This Read AM	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Switching Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Unknown Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations A Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Unknown Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Switching Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations This Read AM	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AL	388	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AF	388	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Maintenance Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations Ground	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations B Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations A Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps C Ø	315.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Months Operations	2	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Month Ops New	2	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps B Ø	250.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps A Ø	360.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations This Read AM	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Switching Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Unknown Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AL	472	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AF	472	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Maintenance Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps B Ø	10.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps C Ø	10.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Month Ops New	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Months Operations	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps A Ø	10.0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations A Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations B Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations C Ø	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations Ground	0	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	825	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Found Counter	346563	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Left Counter	346563	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	90	°C
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	85	°C
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/7/2023 10:05	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	185	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	406	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.8	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.2	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.2	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	434	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Regulator As Left Counter	93351	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Regulator As Left Counter	175432	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Regulator As Left Counter	377985	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0270	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	32.40	kw
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 15:26	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Reading	.6550	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Present	32	°C
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Max	42	°C
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	LTC Totalizer Reading	2358.00	kw
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	All Connections OK?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Operation Checked?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Operations Since Last Insp	1216	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Left Counter	167000	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Found Counter	166996	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Operations Counter	125	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps C Ø	95.0	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps B Ø	94.0	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps A Ø	98.0	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.2	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.8	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.9	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	General Comments		
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Operations Counter	277	
11/7/2023 9:44	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	69.17	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AF	524	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Number of Ops last 9 Months	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Maintenance Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Fault Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps C Ø	0.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps B Ø	0.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps A Ø	0.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	9 Months Operations OCB New	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AL	524	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations This Read Oil	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Switching Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Unknown Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load H2 Max	-60	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load X2 Max	-60	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load Y2 Max	-60	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations VCB New	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Unknown Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Switching Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations This Read Vac	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AL	168	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps C Ø	32.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AF	168	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Maintenance Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps B Ø	27.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps A Ø	30.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations Ground	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations C Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations B Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations A Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps C Ø	63.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps B Ø	63.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps A Ø	61.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Maintenance Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations VCB New	48	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations	56	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AF	368	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AL	368	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations This Read Vac	8	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Switching Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Unknown Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations A Ø	4	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations B Ø	4	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations C Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations Ground	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	General Comments	a,b phase ioc	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps B Ø	89.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps C Ø	96.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Unknown Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps A Ø	90.0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Switching Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations A Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations This Read Vac	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AL	163	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AF	163	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations B Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations C Ø	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Maintenance Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations VCB New	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations Ground	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations	0	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Found Counter	58705	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Left Counter	58705	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	537	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Cleaned oil out of T.C. filter cabinet and installed new absorption pads.	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	General Comments	cleand corrosion	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/7/2023 8:57	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	9 Month Operations	16	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	9 Month Operations VCB New	15	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Amps A Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Amps B Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Amps C Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	General Comments	breaker open not in service	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Switching Operations	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Operations This Read Vac	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Operations Counter AL	80	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Operations Counter AF	80	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002254	BreakerVacuum	132-BT5-6	VCB Readings	Maintenance Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Switching Operations	13	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	9 Month Operations	35	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	9 Month Operations VCB New	22	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Amps A Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Amps B Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Amps C Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	General Comments	breaker not in service	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Maintenance Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Operations Counter AF	113	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Operations Counter AL	113	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002259	BreakerVacuum	132-2547	VCB Readings	Operations This Read Vac	13	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Amps A Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Amps B Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Amps C Ø	0.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	General Comments	breaker not in service	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Maintenance Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Operations Counter AF	123	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Operations Counter AL	123	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Switching Operations	6	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Operations This Read Vac	6	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	9 Month Operations	48	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002258	BreakerVacuum	132-2546	VCB Readings	9 Month Operations VCB New	42	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	9 Month Operations	158	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	9 Month Operations VCB New	157	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Amps A Ø	64.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Amps B Ø	70.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Amps C Ø	67.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Operations Counter AF	236	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Operations Counter AL	236	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Operations This Read Vac	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Switching Operations	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002257	BreakerVacuum	132-2545	VCB Readings	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Amps C Ø	199.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Amps B Ø	202.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Amps A Ø	230.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Maintenance Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Operations Counter AF	150	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Operations Counter AL	150	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Operations This Read Vac	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	9 Month Operations VCB New	36	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Switching Operations	1	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	9 Month Operations	37	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002255	BreakerVacuum	132-2544	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	9 Month Operations	30	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Unknown Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Switching Operations	4	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Operations This Read Vac	4	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Operations Counter AL	89	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Operations Counter AF	89	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Maintenance Operations	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	9 Month Operations VCB New	26	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Amps A Ø	295.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Amps B Ø	269.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Amps C Ø	261.0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Operations A Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Operations B Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Operations C Ø	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	BK002253	BreakerVacuum	132-5	VCB Readings	Fault Operations Ground	0	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	All Connections OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCC000966	LTCControl	132-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC As Found Counter	1777	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC Operations Since Last Insp	138	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC Min Tap Position	9L	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC Current Tap Position	6L	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Counter Readings	LTC As Left Counter	1777	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	LTCM000130	LTCMechanism	132-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	HV Winding Temp Max	36	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	HV Winding Temp Present	36	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	LTC Totalizer Reading	7185.60	kw
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Oil Temp Max	34	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Oil Temp Present	34	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Top Oil Temperature Max	34	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Top Oil Temperature Present	34	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Totalizer Meter Reading	.2994	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Winding Temp Max	36	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	Winding Temp Present	36	°C
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	TX000306	WithLTC	132-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/6/2023 15:27	Distribution	West Shelby Quarterly Inspection	SWG000231	Switchgear	132-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Vegetation	None	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	189.68	kw
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2371	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Amps A Ø	21.0	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	General Comments		
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/7/2023 7:32	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Operations Counter	87	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations Ground	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations C Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations B Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Unknown Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Switching Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations This Read Vac	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AL	189	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AF	189	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Maintenance Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations A Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps C Ø	34.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps B Ø	0.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps A Ø	17.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AL	210	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations This Read Vac	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Switching Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Unknown Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	104.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	103.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	109.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations A Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations B Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations C Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations Ground	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AF	210	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Maintenance Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations Counter AL	161	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations This Read Vac	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Switching Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Unknown Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations A Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Maintenance Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations Counter AF	161	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	9 Month Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations Ground	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations C Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps A Ø	0.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps B Ø	0.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps C Ø	0.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations B Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Unknown Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Switching Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations Counter AL	172	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations Counter AF	172	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Maintenance Operations	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations Ground	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations C Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations B Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations A Ø	0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps C Ø	37.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps B Ø	37.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps A Ø	37.0	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	9 Month Operations VCB New	1	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	9 Month Operations	1	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	44802	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	8R	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	3L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	44890	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	12R	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	10R	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	46435	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5436	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	3913.92	kw
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	All Connections OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Operations Since Last Insp	711	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Max Tap Position	8R	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Left Counter	13958	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Found Counter	13958	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Reading	.9126	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Max	80	°C
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	LTC Totalizer Reading	6570.72	kw
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.3	VDC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 13:52	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Regulator As Left Counter	300025	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Regulator As Left Counter	57932	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1022	Regulator	314-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Regulator As Left Counter	131583	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Winding Temp Present	0	°C
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Oil Temp Max	47	°C
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	LTC Totalizer Reading	307.20	kw
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Oil Temp Present	37	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Readings	Totalizer Meter Reading	.0320	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	LTCC000772	LTCControl	314-2	LTC Control Insp	All Connections OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Max Tap Position	1R	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Min Tap Position	7L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Operations Since Last Insp	915	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Left Counter	12732	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	LTC As Found Counter	12726	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Amps A Ø	6.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Operations Counter	25	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC901736	RecloserElectronic	314-0737	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	621.60	kw
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2590	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	General Comments		
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Operations Counter	19	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/6/2023 13:36	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3408	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Left Counter	441591	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Found Counter	441591	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	9 Month Operations	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps A Ø	0.0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps B Ø	0.0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps C Ø	0.0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations A Ø	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Maintenance Operations	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AF	512	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AL	512	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations This Read Vac	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Switching Operations	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Unknown Operations	0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Left Counter	88674	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Operations Since Last Insp	1067	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Found Counter	88674	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	All Connections OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Output Voltage Level	120.4	VAC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	LTC Totalizer Reading	1184.40	kw
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Reading	.1974	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Amps C Ø	0.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Operations Counter AF	25	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Operations Counter AL	25	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	9 Month Operations	1	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	9 Month Operations VCB New	1	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Readings	Amps A Ø	0.0	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 11:59	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	55	°C
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Max	59	°C
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3210	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	770.40	kw
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56147	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Max Tap Position	14R	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Regulator As Left Counter	126089	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	9 Month Operations VCB New	37	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	9 Month Operations	37	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Amps C Ø	80.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Amps B Ø	78.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Operations Counter AF	42	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Operations Counter AL	42	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Amps A Ø	78.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002183	BreakerVacuum	DE-1406	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Amps C Ø	200.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Amps B Ø	198.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Amps A Ø	205.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Operations Counter AL	29	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Operations Counter AF	29	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	9 Month Operations VCB New	7	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002184	BreakerVacuum	DE-1407	VCB Readings	9 Month Operations	7	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Regulator As Left Counter	169679	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Unknown Operations	1	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Operations This Read Vac	1	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Operations Counter AL	42	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Operations Counter AF	42	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Amps C Ø	9.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Amps B Ø	10.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Amps A Ø	9.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	9 Month Operations	13	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Readings	9 Month Operations VCB New	12	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002185	BreakerVacuum	DE-1408	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Operations Counter AL	56	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Operations Counter AF	56	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	9 Month Operations	11	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	9 Month Operations VCB New	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Amps A Ø	12.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Amps B Ø	13.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Readings	Amps C Ø	12.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002186	BreakerVacuum	DE-1409	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	9 Month Operations VCB New	14	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	9 Month Operations	14	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Operations Counter AF	110	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Operations Counter AL	110	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Amps C Ø	55.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Amps B Ø	76.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Amps A Ø	63.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002187	BreakerVacuum	DE-1410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Amps C Ø	347.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Amps B Ø	364.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Amps A Ø	357.0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	9 Month Operations VCB New	6	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	9 Month Operations	6	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Maintenance Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Operations Counter AF	72	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Operations Counter AL	72	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Operations This Read Vac	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Switching Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Readings	Unknown Operations	0	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002200	BreakerVacuum	DE-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	General Comments		
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:10	Distribution	Del Park Quarterly Inspection	BK002188	BreakerVacuum	DE-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Operations Counter	106	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Operations Counter	262	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	General Comments		
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps C Ø	51.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps B Ø	43.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps A Ø	17.0	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/6/2023 12:32	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Switching Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations This Read Vac	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Unknown Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AL	135	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AF	135	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Maintenance Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	General Comments	breaker is open	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations A Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps C Ø	0.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps B Ø	0.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps A Ø	0.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations This Read Vac	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Switching Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Unknown Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations A Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Maintenance Operations	0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AF	99946	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AL	99946	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps C Ø	41.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps B Ø	38.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations	4	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations VCB New	4	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps A Ø	39.0	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	All Connections OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCControl	020-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Operations Since Last Insp	539	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Min Tap Position	4L	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Max Tap Position	5R	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC Current Tap Position	2L	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC As Left Counter	104195	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	LTC As Found Counter	104195	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Counter Readings	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	General Comments	mutiplier entered wrong last check	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	LTC Totalizer Reading	2203.20	kw
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Winding Temp Present	25	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Winding Temp Max	45	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Totalizer Meter Reading	.1530	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Oil Temp Present	25	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Readings	Oil Temp Max	45	°C
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	General Comments		
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:14	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Unknown Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Switching Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations This Read Vac	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AL	183	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AF	183	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Maintenance Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations A Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps C Ø	17.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps B Ø	36.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps A Ø	20.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations VCB New	1	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations	1	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45024	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47345	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4677	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	KR0128	Regulator	182-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Present	21	°C
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	21000	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0672	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1411.20	kw
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Present	22	°C
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.500	millivolts
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.1	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.1	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	26.1	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.0	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.9	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.7	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations A Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Maintenance Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AF	259	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AL	259	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations This Read Vac	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Switching Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Unknown Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps C Ø	11.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps B Ø	23.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps A Ø	18.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	9 Month Operations VCB New	9	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	9 Month Operations	9	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	9 Month Operations	4	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	9 Month Operations VCB New	1	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Unknown Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Switching Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations This Read Vac	3	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AL	450	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps A Ø	17.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AF	450	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Maintenance Operations	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps B Ø	13.0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations Ground	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations C Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations B Ø	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations A Ø	3	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps C Ø	19.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Operations Counter	26	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps A Ø	96.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps B Ø	78.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Unknown Operations	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Switching Operations	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations This Read Vac	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AL	297	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AF	297	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Maintenance Operations	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations Ground	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations C Ø	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations B Ø	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations A Ø	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps C Ø	61.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps B Ø	99.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps A Ø	66.0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations	0	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations VCB New	0	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	General Comments		
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 11:29	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	All Connections OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Operations Since Last Insp	644	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Left Counter	53323	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Found Counter	53323	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Reading	.3774	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Present	20	°C
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	LTC Totalizer Reading	3623.04	kw
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	General Comments	no spill kit	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 10:19	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations VCB New	2	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	2	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	118.0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	141.0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	118.0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	313	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	313	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations This Read Vac	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55436	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	52237	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	55619	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4902	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4705.92	kw
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments	no spoill kit in station	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2023 9:35	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations VCB New	8	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps A Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AL	165	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AF	165	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps B Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps C Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps C Ø	182.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps B Ø	245.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps A Ø	188.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AL	181	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AF	181	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	9 Month Operations	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps C Ø	247.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps B Ø	203.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps A Ø	224.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	9 Month Operations VCB New	6	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AF	191	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AL	191	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	9 Month Operations	6	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AF	182	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AL	182	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps C Ø	92.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps B Ø	72.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps A Ø	70.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	9 Month Operations	4	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	9 Month Operations VCB New	4	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AL	198	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AF	198	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations	4	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps C Ø	140.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps B Ø	141.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps A Ø	148.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations VCB New	4	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AF	194	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AL	194	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps A Ø	440.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps B Ø	384.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps C Ø	398.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps C Ø	188.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps B Ø	177.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps A Ø	231.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AL	288	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AF	288	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations	1	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations A Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations B Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps C Ø	320.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps B Ø	360.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations C Ø	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations Ground	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	9 Month Operations VCB New	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Unknown Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Switching Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps A Ø	320.0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations This Read Vac	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AL	227	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AF	227	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Maintenance Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	9 Month Operations	0	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	All Connections OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Operations Since Last Insp	494	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Min Tap Position	3L	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Max Tap Position	8R	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Left Counter	81777	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Found Counter	81777	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Max	80	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Reading	.7580	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Present	40	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	LTC Totalizer Reading	13644.00	kw
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Operations Since Last Insp	696	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Left Counter	64315	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Current Tap Position	2R	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Max Tap Position	9R	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Found Counter	64315	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	All Connections OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	LTC Totalizer Reading	12240.00	kw
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Reading	.6800	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Present	45	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Max	65	°C
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Positive DC Ground	30.8	VDC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.6	VDC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	57	°F
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	47.2	VDC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	General Comments		
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	General Comments	no spill kit	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 13:39	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	General Comments	added oil	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	General Comments	added oil	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Max	33	°C
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	LTC Totalizer Reading	6000.00	kw
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Reading	.6250	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Found Counter	40564	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Left Counter	40577	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Max Tap Position	2R	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Operations Since Last Insp	647	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000987	LTCControl	722-2	LTC Control Insp	All Connections OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	131.2	VDC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	66.9	VDC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	66.9	VDC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps C Ø	59.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations A Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations B Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations C Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations Ground	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps B Ø	44.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps A Ø	51.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Maintenance Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AF	290	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AL	209	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations This Read Vac	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Switching Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Unknown Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations	3	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations VCB New	3	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Unknown Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Switching Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations This Read Vac	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AL	221	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations VCB New	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AF	221	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Maintenance Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps A Ø	54.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps B Ø	44.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps C Ø	51.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations A Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations B Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations C Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations Ground	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AF	216	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps B Ø	100.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps C Ø	111.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations A Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations VCB New	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations Ground	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations C Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AL	216	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations This Read Vac	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Switching Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Unknown Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations B Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps A Ø	84.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations A Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations This Read Vac	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AL	179	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations Ground	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations C Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AF	179	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Maintenance Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps C Ø	69.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Switching Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Unknown Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps B Ø	76.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps A Ø	43.0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations VCB New	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations B Ø	0	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Operations Since Last Insp	136	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Current Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Left Counter	246839	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Found Counter	246833	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	All Connections OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	LTC Totalizer Reading	4694.40	kw
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Max	54	°C
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Reading	.6520	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.750	millivolts
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	General Comments	two arresters missing above cir 302	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	General Comments		
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 14:53	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Maintenance Operations	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AF	182	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AL	182	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations	3	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps C Ø	10.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps B Ø	0.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps A Ø	0.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Unknown Operations	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations VCB New	3	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Switching Operations	0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps A Ø	96.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps C Ø	75.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	32	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	All Connections OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Found Counter	53222	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Current Tap Position	4R	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Max Tap Position	14R	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Operations Since Last Insp	232	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Min Tap Position	3L	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	3651.84	kw
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	67	°C
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	44	°C
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.7608	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	General Comments		
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 15:14	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Max	44	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Max	41	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Present	23	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Present	30	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Max	46	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Present	15	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Max	34	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Winding Temp Max	34	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Winding Temp Present	15	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps C Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps B Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps A Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AL	303	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AF	303	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations	2	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations VCB New	2	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps A Ø	12.0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps B Ø	20.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps C Ø	20.0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations A Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations B Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations C Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations Ground	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Unknown Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Switching Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	54	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	54	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2364	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Present	16	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Max	41	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Present	12	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Max	39	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2482.20	kw
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	60.0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	120.0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	120.0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	3	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations VCB New	3	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	59	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	59	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations This Read Vac	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	1410	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	7R	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	72643	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	72633	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Regulator As Left Counter	59853	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Min Tap Position	3L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	4151.52	kw
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Present	34	°C
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Reading	.5766	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Regulator As Left Counter	63386	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Min Tap Position	2L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Max Tap Position	6R	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Current Tap Position	2R	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Current Tap Position	1R	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Min Tap Position	3L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Max Tap Position	6R	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Regulator As Left Counter	18072	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	General Comments		
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/3/2023 11:42	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations VCB New	9	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations	9	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AF	349	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AL	349	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps C Ø	44.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps B Ø	42.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps A Ø	44.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AF	126	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AL	126	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps C Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps B Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps A Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Switching Operations	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations This Read Vac	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AL	244	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AF	244	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps C Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps B Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps A Ø	0.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations	2	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	All Connections OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Operation Checked?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Time Delay	60	Seconds
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Found Counter	265240	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Left Counter	265246	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Current Tap Position	9L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Operations Since Last Insp	1080	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Min Tap Position	12L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Max Tap Position	2L	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Reading	.8550	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Present	32	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Max	54	°C
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	LTC Totalizer Reading	6156.00	kw
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps C Ø	111.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps B Ø	148.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps A Ø	109.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	9 Month Operations	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations Counter AL	170	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations Counter AF	170	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations Counter AF	171	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps C Ø	72.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps B Ø	63.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps A Ø	58.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	9 Month Operations VCB New	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	9 Month Operations	1	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations Counter AL	171	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations Counter AL	170	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations This Read Vac	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Switching Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Operations B Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Operations A Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Unknown Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps C Ø	6.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps B Ø	18.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps A Ø	31.0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations Counter AF	170	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Maintenance Operations	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	General Comments		
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Follow-up Action Required?	n	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Operations Ground	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Operations C Ø	0	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	9 Month Operations VCB New	3	
11/3/2023 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	9 Month Operations	3	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	44	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	36	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	48	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	374458	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Regulator As Left Counter	417479	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Regulator As Left Counter	202720	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	300.96	kw
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1254	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	General Comments	Barbwire rusty, large gap in bak of lot and right post washed out.	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2023 11:01	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Operations Counter	48	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps A Ø	77.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps B Ø	72.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps C Ø	105.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Operations Counter	18	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17875	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Regulator As Left Counter	209938	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Regulator As Left Counter	147553	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8410	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4036.80	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	General Comments	multiple insulators have chipped skirts	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	General Comments	wire and fabric rusty in ultiple places aroud the fence	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	General Comments		
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:45	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Operations Counter	500	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	140	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	47	°C
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	33	°C
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	General Comments		
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	General Comments	fabric and fence rusty in muiltple places	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2023 10:37	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations Ground	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations C Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations B Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Maintenance Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations Counter AF	181	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Unknown Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations A Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Switching Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations This Read Vac	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations Counter AL	181	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	9 Month Operations	1	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	9 Month Operations VCB New	1	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps C Ø	124.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps B Ø	129.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps A Ø	124.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	9 Month Operations	2	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps A Ø	49.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps C Ø	62.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps B Ø	63.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations A Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations B Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations C Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations Ground	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations This Read Vac	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Switching Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Unknown Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Maintenance Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AF	185	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AL	185	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations Ground	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations C Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations B Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations A Ø	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Maintenance Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations Counter AF	209	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations Counter AL	209	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations This Read Vac	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Switching Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Unknown Operations	0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps C Ø	141.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps B Ø	147.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps A Ø	143.0	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	9 Month Operations VCB New	5	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	9 Month Operations	5	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	All Connections OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Found Counter	83940	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Left Counter	83940	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Max Tap Position	8R	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Operations Since Last Insp	7022	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Max	85	°C
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Reading	.9400	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Max	75	°C
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	LTC Totalizer Reading	9024.00	kw
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	General Comments	no spare fuses in sub	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 16:24	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Amps C Ø	24.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Amps B Ø	18.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Amps A Ø	19.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	9 Month Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Operations A Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Operations B Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Operations C Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Fault Operations Ground	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Maintenance Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Operations Counter AF	177	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Operations Counter AL	177	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Operations This Read Vac	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Switching Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK002051	BreakerVacuum	197-2535	VCB Readings	Unknown Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps A Ø	0.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps B Ø	0.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps C Ø	0.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations A Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations B Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations C Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations Ground	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Maintenance Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AF	1242	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AL	1242	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations This Read Vac	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Switching Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Unknown Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps A Ø	77.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps B Ø	82.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps C Ø	74.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Unknown Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Switching Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations This Read Vac	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AL	203	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AF	203	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Maintenance Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations Ground	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations C Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations B Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	9 Month Operations	6	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	9 Month Operations VCB New	6	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps A Ø	133.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps B Ø	108.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps C Ø	154.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations A Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations B Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations C Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations Ground	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Maintenance Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations Counter AF	195	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations Counter AL	195	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations This Read Vac	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Switching Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Unknown Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations Ground	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations C Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations B Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations A Ø	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps C Ø	81.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps B Ø	84.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps A Ø	91.0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Maintenance Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AF	201	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AL	201	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations This Read Vac	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Switching Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Unknown Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations	0	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Operations Since Last Insp	632	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Min Tap Position	9L	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Current Tap Position	7L	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Left Counter	195118	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Found Counter	195118	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	All Connections OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	LTC Totalizer Reading	4406.40	kw
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Max	55	°C
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Present	30	°C
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Reading	.4590	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Found Counter	89652	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Left Counter	89652	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Current Tap Position	3L	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Max Tap Position	5R	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Min Tap Position	4L	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Operations Since Last Insp	555	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	All Connections OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Reading	.5364	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Present	40	°C
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Max	60	°C
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	LTC Totalizer Reading	5149.44	kw
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	General Comments		
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 15:09	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	20	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	443	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.0	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	398	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15645	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14943	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	16833	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	386.64	kw
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	37	°C
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3222	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/2/2023 14:55	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Unknown Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Switching Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations This Read Vac	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AL	212	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations C Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations B Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AF	212	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Maintenance Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps C Ø	11.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps B Ø	27.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps A Ø	16.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AL	291	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps A Ø	104.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps B Ø	92.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps C Ø	103.0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Unknown Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AF	291	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations B Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations C Ø	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Switching Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Maintenance Operations	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations This Read Vac	0	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	All Connections OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Operations Since Last Insp	908	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Current Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Left Counter	30318	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Found Counter	30311	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	LTC Totalizer Reading	4497.60	kw
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Max	53	°C
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Reading	.9370	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Swept?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Evidence of Insects	None	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Broom on Site?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 13:26	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Switching Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Amps C Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Operations This Read Vac	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Operations Counter AL	20	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Operations Counter AF	20	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Amps B Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Readings	9 Month Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Operations Counter AL	33	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Operations Counter AF	33	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	9 Month Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Amps C Ø	55.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Switching Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Operations This Read Vac	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Amps B Ø	69.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Readings	Amps A Ø	71.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	9 Month Operations	8	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	9 Month Operations VCB New	8	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Amps A Ø	238.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Amps B Ø	224.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Amps C Ø	230.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Operations Counter AF	34	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Operations Counter AL	34	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Operations This Read Vac	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Readings	Switching Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Amps B Ø	56.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Amps A Ø	69.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Amps C Ø	90.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	9 Month Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Operations Counter AF	15	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Operations Counter AL	15	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Operations This Read Vac	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Switching Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Amps A Ø	703.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Amps B Ø	669.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Amps C Ø	702.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Operations Counter AL	152	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Operations This Read Vac	22	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Switching Operations	22	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	9 Month Operations	22	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Readings	Operations Counter AF	152	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps C Ø	88.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps B Ø	63.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps A Ø	65.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AF	99816	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AL	99816	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations This Read Vac	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations VCB New	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Switching Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps B Ø	62.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps C Ø	62.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps A Ø	70.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AF	376	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AL	376	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations This Read Vac	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Switching Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations VCB New	46	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations	46	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AF	258	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations VCB New	8	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps C Ø	68.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps B Ø	78.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps A Ø	85.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AL	258	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations This Read Vac	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Switching Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations	9	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AL	712	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations This Read Vac	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations	5	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations VCB New	4	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps A Ø	96.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps B Ø	118.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps C Ø	106.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Switching Operations	1	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AF	712	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	3	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	11	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	8	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	8	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	420	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	420	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Operations Counter	307	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BX1218	RecloserHydraulic	638-2475	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps B Ø	8.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AL	188	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	9 Month Operations VCB New	3	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	9 Month Operations	4	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations This Read Vac	1	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Switching Operations	1	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Unknown Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps C Ø	12.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AF	188	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Maintenance Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations C Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations B Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps A Ø	9.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Maintenance Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AL	190	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations This Read Vac	6	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AF	190	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations C Ø	2	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	9 Month Operations	6	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps A Ø	121.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps B Ø	108.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations B Ø	2	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Switching Operations	2	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Unknown Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps C Ø	112.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations This Read Vac	1	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AL	176	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AF	176	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations C Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations B Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps C Ø	127.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps B Ø	127.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps A Ø	126.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	9 Month Operations VCB New	3	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Switching Operations	1	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Unknown Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	9 Month Operations	4	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations	11	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations VCB New	11	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	160.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps B Ø	160.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps C Ø	160.0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Maintenance Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AF	12	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AL	12	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations This Read Vac	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Switching Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Unknown Operations	0	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	All Connections OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Found Counter	19277	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Left Counter	19277	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Operations Since Last Insp	558	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Present	25	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Max	25	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Reading	.3570	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	LTC Totalizer Reading	6426.00	kw
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/2/2023 13:00	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations Counter AF	222	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations Counter AL	222	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps A Ø	46.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps B Ø	52.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps C Ø	49.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AF	182	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AL	182	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AL	96	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps A Ø	101.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps B Ø	67.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps C Ø	75.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AF	96	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AF	344	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AL	344	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps B Ø	136.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps A Ø	184.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps C Ø	171.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps A Ø	67.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps B Ø	43.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps C Ø	22.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	9 Month Operations VCB New	5	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	9 Month Operations	5	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations Counter AL	392	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations Counter AF	392	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps B Ø	267.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps C Ø	222.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps A Ø	273.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AL	255	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AF	255	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations This Read Vac	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	228	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	228	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	All Connections OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Operations Since Last Insp	2454	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Min Tap Position	6L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Max Tap Position	7R	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Current Tap Position	2L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Left Counter	38583	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Found Counter	38583	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	9496.32	kw
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	80	°C
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	.9892	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	40	°C
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Switching Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations Counter AL	194	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations Counter AF	194	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	9 Month Operations	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps A Ø	321.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps B Ø	262.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps C Ø	294.0	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AL	146105	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AF	146105	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Reset Tap Drag Hands	Unable to Reset	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Min Tap Position	7L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Max Tap Position	3R	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Current Tap Position	5L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	All Connections OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Operations Since Last Insp	593	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Left Counter	146105	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Found Counter	146105	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Reading	.5364	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Max	75	°C
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	LTC Totalizer Reading	9655.20	kw
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.3	VDC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1811.52	kw
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7548	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	General Comments		
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Ambient Temp	45	°F
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 12:21	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	295867	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45713	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	312965	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	198	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	198	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations VCB New	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	115	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	115	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AL	144	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AF	144	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations VCB New	9	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations	9	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AF	143	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AL	143	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AF	125	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AL	125	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AL	140	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AF	140	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AF	250	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AL	250	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps C Ø	245.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps B Ø	245.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations VCB New	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps A Ø	245.0	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Operations Counter	643	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps C Ø	72.0	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps B Ø	55.0	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps A Ø	61.0	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Operations Counter	150	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps A Ø	.4	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.2	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps C Ø	.3	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 13:05	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Switching Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AL	131	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AF	1310	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Maintenance Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	210	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	210	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	214	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	214	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments	2fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	205	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	205	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	30	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	30	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AL	188	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AF	188	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	237	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	237	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AL	185	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AF	185	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	146	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	146	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	9 Month Operations	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AF	128	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AL	128	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations This Read Vac	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Switching Operations	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	3	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	249	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	249	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	240	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	240	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	3	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations VCB New	2	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	3	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	249	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AF	249	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	233	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	233	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AF	224	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AL	224	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Maintenance Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	General Comments	fun trip	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations Ground	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations C Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations B Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps C Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps B Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps A Ø	0.0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	9 Month Operations VCB New	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	9 Month Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations A Ø	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AF	74	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AL	74	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Unknown Operations	0	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Switching Operations	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations This Read Vac	1	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Found Counter	27195	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	512	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Left Counter	27195	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	42	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	9	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	19	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	20	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Present	21	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Max	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Found Counter	34944	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Left Counter	34944	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	279	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	90	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	25	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	VRR Base Voltage AF	116.8	VAC
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1705	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Left Counter	106367	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Found Counter	106367	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	85	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	60	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	103	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	142	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.0	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.0	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.0	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	591	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Regulator As Left Counter	272822	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Max Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1455	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	10R	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Left Counter	120623	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Found Counter	120623	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	62	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	18	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	72	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	75	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	0	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	General Comments	There is no H2 gauge here	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	0	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	141551	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR in vacuum	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Found Counter	68655	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Left Counter	68655	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1371	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9R	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	133308	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	78	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Max	62	°C
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	139.68	kw
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1164	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	General Comments	There is one ground in the control house.	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Vegetation	None	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 11:19	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002109	BreakerVacuum	FH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002110	BreakerVacuum	FH-1209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002111	BreakerVacuum	FH-1210	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Patrol Inspection	General Comments		
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002112	BreakerVacuum	FH-1211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Patrol Inspection	Follow-up Action Required?	n	
11/8/2023 8:56	Distribution	Freys Hill Quarterly Inspection	BK002113	BreakerVacuum	FH-1212	VCB Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0090	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	43.20	kw
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Found Counter	5508	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Left Counter	5518	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Operations Since Last Insp	434	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	145	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	276	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps C Ø	.1	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps A Ø	.1	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps B Ø	.1	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	General Comments	cap bank had been disconnected from buss	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Poor	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments	Some standing water in drive with potholes.	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty, and trees overhanging fence	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 11:46	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0220	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	100	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2.20	kw
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments		
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments	Lots of potholes, ruts, and washouts.	
11/2/2023 10:23	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	179	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Operations Counter	501	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps C Ø	103.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps B Ø	62.0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps A Ø	135.0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	All Connections OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Operation Checked?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Left Counter	5121	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Found Counter	5121	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	General Comments	counter is not working	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	LTC Totalizer Reading	2920.32	kw
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Reading	.2028	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Ambient Temp	30	°F
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
11/2/2023 10:10	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	VRR Base Voltage AF	116.9	VAC
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	116.8	VAC
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	General Comments		
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2023 12:20	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Maintenance Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Operations Counter AF	169	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Operations Counter AL	169	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Switching Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Unknown Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Amps C Ø	207.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Amps B Ø	201.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Amps A Ø	207.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	9 Month Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK001783	BreakerVacuum	542-0344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations	1	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations VCB New	1	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Unknown Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Switching Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AL	365	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AF	365	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Maintenance Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps C Ø	308.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps A Ø	313.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps B Ø	329.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AF	39	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AL	39	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Switching Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Maintenance Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Unknown Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps C Ø	165.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps B Ø	177.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps A Ø	181.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Maintenance Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AF	35	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AL	35	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Switching Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Unknown Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps C Ø	639.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps A Ø	643.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps B Ø	658.0	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Found Counter	240868	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Left Counter	240868	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Max Tap Position	8R	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Operations Since Last Insp	1455	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AL	118.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AF	118.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AL	128.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AF	128.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Present	50	°C
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Reading	.9390	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Max	90	°C
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Present	60	°C
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	LTC Totalizer Reading	16902.00	kw
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BCH001578	Charger	542-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	BAT001630	Battery	542-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/1/2023 14:55	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	9 Month Operations VCB New	9	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	9 Month Operations	9	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps A Ø	179.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AF	216	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps B Ø	190.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AL	216	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps C Ø	175.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	9 Month Operations VCB New	17	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	9 Month Operations	17	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps A Ø	24.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps B Ø	24.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps C Ø	24.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations Counter AF	233	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations Counter AL	233	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps C Ø	12.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps B Ø	16.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps A Ø	14.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations VCB New	11	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations	11	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AL	200	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AF	200	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps A Ø	364.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AL	177	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AF	177	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations	9	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations VCB New	9	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps C Ø	363.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps B Ø	369.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AF	203	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AL	203	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations	11	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps C Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps B Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps A Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations VCB New	11	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps A Ø	195.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	9 Month Operations VCB New	13	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	9 Month Operations	13	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps C Ø	191.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps B Ø	215.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AF	228	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AL	228	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations	7	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations VCB New	7	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Unknown Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AL	204	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AF	204	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps A Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps B Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps C Ø	0.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Switching Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AL	220	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AF	220	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Maintenance Operations	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps C Ø	164.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps B Ø	166.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps A Ø	158.0	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations VCB New	7	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations	7	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	All Connections OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	All Connections OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Found Counter	29427	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Left Counter	29427	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Operations Since Last Insp	683	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Operations Since Last Insp	1083	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Max Tap Position	7R	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Current Tap Position	3L	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Left Counter	71896	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Found Counter	71896	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Present	25	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Reading	.7428	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Present	30	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	LTC Totalizer Reading	10696.32	kw
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Reading	.5022	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	LTC Totalizer Reading	4821.12	kw
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 14:03	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations Ground	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations C Ø	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations B Ø	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations A Ø	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	9 Month Operations VCB New	6	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	9 Month Operations	6	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps C Ø	84.0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps B Ø	77.0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps A Ø	83.0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Maintenance Operations	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AF	206	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AL	206	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations This Read Vac	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Switching Operations	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Unknown Operations	0	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	All Connections OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Min Tap Position	14L	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Operations Since Last Insp	506	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Current Tap Position	11L	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Max Tap Position	1L	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Left Counter	43868	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Found Counter	43868	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	General Comments	counter not working	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Reading	.3678	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	LTC Totalizer Reading	1765.44	kw
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Max	53	°C
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	General Comments	LTC cabinet has a leak	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.1	VDC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.326	millivolts
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Broom on Site?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Swept?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	FE000886	Fence	855-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 13:48	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	CH000534	ControlHouse	844-Control House	Control House Patrol Inspection	General Comments	turned heater up	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Max	55	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Present	25	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	LTC Totalizer Reading	5788.80	kw
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Reading	.4020	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Present	25	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Min Tap Position	11L	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Operations Since Last Insp	684	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Current Tap Position	7L	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Left Counter	262068	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Found Counter	262057	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Time Delay	45	Seconds
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	All Connections OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	LTC Totalizer Reading	5364.00	kw
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Present	38	°C
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Reading	.7450	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Found Counter	237245	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Left Counter	237257	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Current Tap Position	7R	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Max Tap Position	12R	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Min Tap Position	2R	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Operations Since Last Insp	1118	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Time Delay	45	Seconds
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	All Connections OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AL	231	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AF	231	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps C Ø	150.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps B Ø	120.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps A Ø	120.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations	2	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations VCB New	2	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps A Ø	33.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps B Ø	39.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AL	207	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AF	207	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps C Ø	12.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations	1	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations VCB New	1	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps A Ø	93.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps B Ø	123.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps C Ø	108.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AF	732	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AL	732	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AL	845	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AF	845	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps C Ø	69.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps B Ø	46.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps A Ø	64.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations VCB New	3	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations	3	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AL	257	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AF	257	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps C Ø	40.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps B Ø	24.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps A Ø	16.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations VCB New	2	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations	2	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps A Ø	133.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps B Ø	155.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps C Ø	114.0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations A Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations B Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations C Ø	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations Ground	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Maintenance Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AF	331	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AL	331	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations This Read Vac	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Unknown Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Switching Operations	0	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.570	millivolts
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	FE000894	Fence	844-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/1/2023 14:05	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	General Comments	.	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.2	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Max	45	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Reading	.0133	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Max	44	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	127.68	kw
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	LTC Totalizer Reading	6474.24	kw
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Reading	.6744	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Present	44	°C
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Found Counter	7466	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Left Counter	7477	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Current Tap Position	7R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Max Tap Position	11R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Operations Since Last Insp	1575	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Time Delay	45	Seconds
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	All Connections OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations	10	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations VCB New	10	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps A Ø	0.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps B Ø	0.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AF	182	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AL	182	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations This Read Vac	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Switching Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations	8	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations VCB New	8	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps A Ø	0.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps B Ø	0.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps C Ø	0.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations B Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AF	196	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AL	196	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations This Read Vac	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Switching Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Switching Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations This Read Vac	1	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations B Ø	1	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AF	231	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AL	231	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps B Ø	9.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations	12	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations VCB New	11	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps A Ø	9.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps C Ø	9.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Unknown Operations	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	9 Month Operations VCB New	1	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	9 Month Operations	6	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps A Ø	119.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps B Ø	104.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps C Ø	81.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Maintenance Operations	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations Counter AF	178	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations Counter AL	178	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations This Read Vac	5	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Switching Operations	5	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations	8	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations VCB New	8	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps A Ø	10.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps B Ø	11.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps C Ø	10.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations B Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AF	205	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AL	205	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations This Read Vac	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Switching Operations	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	9 Month Operations	2	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps A Ø	44.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps B Ø	34.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps C Ø	45.0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations A Ø	1	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations B Ø	1	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Maintenance Operations	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations Counter AF	167	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations Counter AL	167	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations This Read Vac	2	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Switching Operations	0	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations	10	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations VCB New	10	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps A Ø	273.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps B Ø	282.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps C Ø	331.0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations Ground	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations C Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations B Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations A Ø	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Unknown Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Switching Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations This Read Vac	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AL	205	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AF	205	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49405	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AF	78	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Fault Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	9 Month Operations GCB New	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Num Operations Last 9 Months	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Switching Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AL	78	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations This Read SF6	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Maintenance Operations	0	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	General Comments	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 1	59	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 2	59	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 3	59	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Ambient Temperature	35	°F
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Regulator As Left Counter	60261	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Max Tap Position	11R	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Current Tap Position	1R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Regulator As Left Counter	27059	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Regulator As Left Counter	52855	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Regulator As Left Counter	23495	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4227.84	kw
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8808	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Regulator As Left Counter	24994	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.873	millivolts
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BCH001479	Charger	350-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.6	VDC
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	General Comments	turned heater up	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 12:18	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.830	millivolts
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 12:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	825	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Left Counter	421967	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Found Counter	421967	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR needs nitro. In vacuum	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	853	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Left Counter	596399	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Found Counter	596399	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR need nitro	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AF	306	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AL	306	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations Ground	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Unknown Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps C Ø	0.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps B Ø	0.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Maintenance Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AF	491	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AL	491	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Switching Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Months Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Month Ops New	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps A Ø	0.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations This Read AM	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	9 Month Ops New	14	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps A Ø	30.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps B Ø	30.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Unknown Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations Ground	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Switching Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations This Read AM	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AL	627	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps C Ø	30.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AF	627	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Maintenance Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Months Operations	5	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Unknown Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps B Ø	80.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps A Ø	120.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AL	181	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AF	181	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Maintenance Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Month Ops New	5	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations Ground	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps C Ø	100.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Switching Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations This Read AM	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations B Ø	1	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations Ground	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	General Comments	B phase IOC	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Maintenance Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AF	471	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AL	471	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Month Ops New	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations This Read AM	1	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Switching Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Unknown Operations	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Months Operations	1	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps A Ø	100.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps B Ø	100.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps C Ø	100.0	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	Needs Repair	note in comments if present
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	General Comments	Red light flashing on outside of unit	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/1/2023 11:20	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations This Read Vac	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations Counter AL	166	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations Counter AF	166	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	9 Month Operations	2	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	9 Month Operations VCB New	2	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps A Ø	54.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps B Ø	101.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations C Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations B Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps C Ø	17.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	9 Month Operations VCB New	11	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	9 Month Operations	12	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps A Ø	64.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps B Ø	63.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps C Ø	61.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations This Read Vac	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations Counter AL	136	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations Counter AF	136	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations C Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations B Ø	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations This Read Vac	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations Counter AL	231	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations Counter AF	231	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations C Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations B Ø	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps B Phase V	9.39	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps C Ø	64.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps B Ø	71.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps A Ø	100.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	9 Month Operations VCB New	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	9 Month Operations	2	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations B Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations C Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps C Ø	64.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps B Ø	76.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps A Ø	62.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	9 Month Operations VCB New	2	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	9 Month Operations	2	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations Counter AF	168	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations Counter AL	168	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations This Read Vac	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations This Read Vac	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AL	245	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AF	245	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations C Ø	1	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations B Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps A Ø	77.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps B Ø	98.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	9 Month Operations	4	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	9 Month Operations VCB New	3	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps C Ø	103.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Unknown Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Switching Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations This Read Vac	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AL	216	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AF	216	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Maintenance Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations Ground	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations C Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations B Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations A Ø	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps C Ø	26.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps B Ø	56.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps A Ø	54.0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations VCB New	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	All Connections OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Max Tap Position	3R	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Current Tap Position	6L	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Min Tap Position	10L	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Operations Since Last Insp	1101	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Left Counter	26000	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Found Counter	25995	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Max	50	°C
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	LTC Totalizer Reading	5136.00	kw
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Present	49	°C
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Reading	.5350	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Max Tap Position	2R	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Current Tap Position	5L	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Left Counter	86	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Found Counter	86	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	General Comments	counter isnt working	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	All Connections OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	LTC Operation Checked?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000989	LTCControl	780-2	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Reading	.3640	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Present	22	°C
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Max	33	°C
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	LTC Totalizer Reading	3494.40	kw
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.3	VDC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.320	millivolts
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.1	amps
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Floor Swept?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Broom on Site?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 11:03	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1102	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Left Counter	456951	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Found Counter	456951	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Left Counter	44765	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Found Counter	44765	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	General Comments	vc is not working	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	17	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Found Counter	421464	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Left Counter	421464	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9R	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2396	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	145.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AF	392	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AL	392	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Month Ops New	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AL	383	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AF	383	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps B Ø	190.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps A Ø	195.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Unknown Operations	6	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations This Read AM	6	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AL	389	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AF	389	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Months Operations	12	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Month Ops New	6	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps C Ø	200.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	57.28	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	57.28	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	57.28	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps C Ø	79.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps B Ø	84.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps A Ø	85.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations This Read AM	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Month Ops New	7	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Months Operations	7	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AL	869	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AF	869	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps B Ø	250.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps A Ø	290.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Months Operations	24	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Month Ops New	18	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps C Ø	215.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	57.28	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations C Ø	6	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Unknown Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AF	421	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AL	421	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations This Read AM	6	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Unknown Operations	8	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Switching Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Month Ops New	8	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Months Operations	16	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps A Ø	71.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps B Ø	99.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps C Ø	92.0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	76.37	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	76.37	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	76.37	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AL	598	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations This Read AM	8	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AF	598	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	General Comments	a,b phase ioc	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations B Ø	2	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations A Ø	2	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	19.09	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AF	340	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AL	340	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations This Read AM	4	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Switching Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Unknown Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps C Ø	100.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps B Ø	120.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps A Ø	100.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Months Operations	54	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Month Ops New	50	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AF	392	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AL	392	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations This Read AM	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Switching Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Unknown Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations A Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps C Ø	140.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps B Ø	200.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps A Ø	150.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Months Operations	16	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Month Ops New	16	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/1/2023 10:11	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Switching Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Month Ops New	19	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Months Operations	20	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps A Ø	60.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps B Ø	60.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Unknown Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations A Ø	1	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations B Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations C Ø	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations This Read AM	1	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AL	8	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AF	8	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Maintenance Operations	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	General Comments	a phase ioc	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations Ground	0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps C Ø	60.0	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Vegetation	None	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	General Comments		
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PF001310	PowerFuse	FO-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/1/2023 10:10	Distribution	Forty Fourth Street Quarterly Inspection	PF001310	PowerFuse	FO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	9 Month Operations	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	9 Month Operations VCB New	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps A Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps B Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps C Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations Counter AF	167	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations Counter AL	167	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps C Ø	12.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps B Ø	13.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps A Ø	11.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	9 Month Operations VCB New	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	9 Month Operations	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations Counter AF	173	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations Counter AL	173	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Operations Counter AF	159	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Operations Counter AL	159	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Amps C Ø	252.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Amps B Ø	304.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Amps A Ø	284.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	9 Month Operations VCB New	4	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	9 Month Operations	4	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	9 Month Operations	3	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	9 Month Operations VCB New	3	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations Counter AL	171	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations Counter AF	171	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps C Ø	89.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps B Ø	86.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps A Ø	84.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	30.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	344	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	344	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	30.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	29.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations VCB New	3	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	3	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	0.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	217	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	217	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	4	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations VCB New	4	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	252	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	252	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	304.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps B Ø	333.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps A Ø	301.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations VCB New	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations VCB New	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	415	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	415	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps A Ø	308.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	331.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps C Ø	305.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations A Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Maintenance Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations Counter AF	154	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations Counter AL	154	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations This Read Vac	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Switching Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Unknown Operations	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations B Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps C Ø	340.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps B Ø	384.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps A Ø	368.0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	9 Month Operations	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	9 Month Operations VCB New	1	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations C Ø	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations Ground	0	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	All Connections OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Operation Checked?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	159017	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	159017	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	4L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	13L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	330	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	7398.00	kw
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.4110	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Max	45	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	All Connections OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Operation Checked?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	454	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	22289	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	22289	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.4836	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Present	45	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	70	°C
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	8704.80	kw
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.7	amps
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BCH001238	Charger	451-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.6	VDC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	General Comments		
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	FE000893	Fence	451-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments	no spill kit	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
10/31/2023 11:51	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Unknown Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Maintenance Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	5	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations VCB New	3	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps A Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps C Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps B Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	239	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AF	239	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	4	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	2	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations This Read Vac	2	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	754	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	754	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations	5	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations VCB New	3	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps A Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps C Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps B Ø	10.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	8	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations VCB New	8	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	108.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	204	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	204	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	111.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	80.0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	8L	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	2L	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	4L	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	191786	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	191786	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	281	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	All Connections OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	LTC Output Voltage Level	123.4	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	LTCC000977	LTCControl	204-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	4963.20	kw
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	20	°C
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	.5170	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.5	VDC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	General Comments		
10/13/2023 11:01	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Ground Lights	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps A Ø	318.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps B Ø	351.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps C Ø	339.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	9 Month Operations VCB New	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	9 Month Operations	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations Counter AL	145	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations Counter AF	145	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations Counter AL	206	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations Counter AF	206	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	9 Month Operations	2	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	9 Month Operations VCB New	2	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps A Ø	80.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps B Ø	96.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps C Ø	77.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations Counter AL	164	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations Counter AF	164	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps C Ø	106.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps B Ø	93.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps A Ø	93.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	9 Month Operations VCB New	16	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	9 Month Operations	16	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	249	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	249	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	5	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	180.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	183.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	172.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations VCB New	5	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000128	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000128	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000128	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000128	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000128	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000304	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	183	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	183	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	482	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	482	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations VCB New	4	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	4	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	70.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	59.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	69.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations VCB New	6	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	9	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	50.87	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	3	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	244	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	244	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations This Read Vac	3	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations VCB New	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	423	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	423	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	100.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	282.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	265.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	290.0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations VCB New	1	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations This Read Vac	0	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	183	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	183	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	0	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	650	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	1174	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	4R	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	153283	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	153283	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	1.1058	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	75	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	45	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	15923.52	kw
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	25497	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	25497	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	723	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	All Connections OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Operation Checked?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	LTCC000828	LTCControl	863-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	300	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	10556.64	kw
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.7331	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.2	amps
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	TX000326	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	30	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2023 13:51	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	157623	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	157623	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	5R	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 13:56	Distribution	Eastland Storage Quarterly Inspection	LTCM000123	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0348	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0286	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauges	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0266	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauges	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0265	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0258	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no nitrogen gauge. needs new oil level gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0236	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	236.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	252.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs oil level and oil temp gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0184	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000298	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000291	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000067	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000060	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000059	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000058	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs new nitrogen gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	no bottle on xfmr	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0399	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0382	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0376	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0375	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	needs oil level gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0374	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Unknown Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Switching Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Operations This Read Vac	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Operations Counter AL	165	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Operations Counter AF	165	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Maintenance Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Operations Ground	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Operations C Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Operations B Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Operations A Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Amps C Ø	106.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	9 Month Operations	3	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	9 Month Operations VCB New	3	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Amps B Ø	106.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Amps A Ø	86.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002052	BreakerVacuum	176-0127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	General Comments	.	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	unsure of accuracy, gauge in disrepair	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0147	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	unsure of accuracy, gauge in disrepair	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	gauge is in disrepair, unsure of accuracy	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no psi gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Operations Ground	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Maintenance Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Operations C Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Unknown Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Operations B Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Amps A Ø	237.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Amps B Ø	233.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Amps C Ø	240.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Fault Operations A Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Switching Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	9 Month Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	9 Month Operations VCB New	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Operations Counter AF	160	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Operations Counter AL	160	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Operations This Read Vac	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002043	BreakerVacuum	176-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	6408.00	kw
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	55	°C
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Present	40	°C
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.2670	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	55	°C
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Present	40	°C
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	1R	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	4L	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	157957	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	157957	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	8L	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	313	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	All Connections OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Operation Checked?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0356	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0045	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Amps C Ø	79.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Amps B Ø	79.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Operations A Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Operations B Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Amps A Ø	78.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Operations C Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	9 Month Operations VCB New	4	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	9 Month Operations	4	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Fault Operations Ground	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Maintenance Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Operations Counter AF	175	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Operations Counter AL	175	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Operations This Read Vac	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Switching Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Readings	Unknown Operations	0	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002049	BreakerVacuum	176-0075	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	9 Month Operations	2	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	9 Month Operations VCB New	2	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Switching Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Amps A Ø	97.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Amps B Ø	74.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Unknown Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Maintenance Operations	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Operations Counter AF	154	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Operations Counter AL	154	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Operations This Read Vac	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Amps C Ø	71.0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Operations A Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Operations B Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Operations C Ø	0	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Readings	Fault Operations Ground	0	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	General Comments		
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2023 10:45	Distribution	Loudon Avenue Quarterly Inspection	BK002050	BreakerVacuum	176-0076	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0251	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2023 10:55	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0234	NonLTC	912-Offline-34 kV	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BCH001596	Charger	LO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations This Read Vac	4	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	407	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	407	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments	a,b,phase ioc	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	2	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	2	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	4	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations VCB New	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	99.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	95.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	100.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1213	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1213	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	10.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	8.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	19.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations VCB New	11	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	11	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations VCB New	33	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	33	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	75.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	87.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	95.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	697	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	697	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations VCB New	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	60.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	61.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	49.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	110	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	110	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	9	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	9	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	110.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	98.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	120.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	2	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations VCB New	2	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	360.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	330.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	370.0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	245	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	245	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments	ok	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	floor has evidnence of moisture at side wall where meets floor. floor is in need of painting.	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1475	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	29121	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	29121	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments	east fence has a lot overhanging limbs, west fence has top strand of barbwire broken	
10/26/2023 11:43	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Regulator As Left Counter	167520	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Regulator As Left Counter	88598	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Regulator As Left Counter	135503	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1316.16	kw
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5484	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	100	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	29.1	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	26.6	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	21.1	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.6	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.9	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	396	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations	9	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	284	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations VCB New	9	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	284	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations This Read Vac	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps A Ø	84.0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps B Ø	84.0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps C Ø	84.0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	59129	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	59127	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1346	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	LTC Operation Checked?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	All Connections OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	LTCC000985	LTCControl	310-1	LTC Control Insp	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	26	°C
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	48	°C
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2192.00	kw
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.6850	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.1	VDC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.500	millivolts
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/25/2023 15:17	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments		
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/25/2023 11:41	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	4	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	4	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.1	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.9	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.1	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	20	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	127	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	132007	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	381148	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1218	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	292.32	kw
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments		
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 11:24	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	77	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.1	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	89	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	169536	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	130197	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2997	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	RG000213	Regulator	342-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.1890	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	113.40	kw
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Present	24	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	43	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments		
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/25/2023 10:30	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	4829	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	4829	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	85	°C
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	340.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 16:55	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0174	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations This Read Vac	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AL	181	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AF	181	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	9 Month Operations	4	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	9 Month Operations VCB New	4	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps A Ø	0.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps B Ø	0.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps C Ø	0.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations B Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations A Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps A Ø	110.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps B Ø	100.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps C Ø	100.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations A Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations B Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	9 Month Operations VCB New	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	9 Month Operations	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AF	188	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AL	188	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations This Read Vac	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	9 Month Operations	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps A Ø	110.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps B Ø	110.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps C Ø	110.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations A Ø	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations B Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	General Comments	51 on A, B, C	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AF	208	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AL	208	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations This Read Vac	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	9 Month Operations	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps A Ø	150.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps B Ø	130.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps C Ø	135.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations A Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations B Ø	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	General Comments	51 on B , N	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AF	179	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AL	179	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations This Read Vac	1	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations B Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations A Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps C Ø	140.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps B Ø	160.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps A Ø	160.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	9 Month Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AF	185	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AL	185	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations This Read Vac	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps C Ø	445.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps B Ø	480.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps A Ø	490.0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	9 Month Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Unknown Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Switching Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations This Read Vac	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AL	141	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AF	141	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Maintenance Operations	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations Ground	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations C Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations B Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations A Ø	0	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	1508	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	8R	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	48162	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	48162	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	11642.40	kw
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	.8085	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	80	°C
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	75	°C
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 15:36	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	33	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	31	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge. counter entered wrong last time	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	34	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	166	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	177	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	300	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	299	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	50442	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	52748	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	49529	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	25	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	155	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	155	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	1	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	1	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	2	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations VCB New	1	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	37	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	47	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	421.67	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:46	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	52.6	VDC
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations This Read Vac	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	328	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	328	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations VCB New	5	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	5	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	.96	kw
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0006	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	47	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	34	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.5	VDC
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.2	VDC
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	5	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations VCB New	5	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	269	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	269	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48160	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.1	volts
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49859	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47692	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/24/2023 13:32	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.4	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	116	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.7	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	87	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	100	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	13L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	171955	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12851	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Min Tap Position	14L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	212358	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3384	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	609.12	kw
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.7	psi
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/24/2023 12:14	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	5	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	5	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations VCB New	42	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	42	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations This Read Vac	6	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	108	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	108	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	60.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations VCB New	17	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	23	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps C Ø	72.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps B Ø	70.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps A Ø	77.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations Counter AF	173	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations Counter AL	173	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Switching Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Maintenance Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Unknown Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	9 Month Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Switching Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Unknown Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations Counter AL	151	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations Counter AF	151	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Maintenance Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	9 Month Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	9 Month Operations VCB New	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps A Ø	91.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps B Ø	92.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps C Ø	71.0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	148180	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	148180	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	2L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	207	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	231	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	231	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	3	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations VCB New	3	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	3	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	3	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	2	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	75.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	80.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	90.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9730	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11774	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	13.43	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	13.43	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	170.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	185.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	210.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	1	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations VCB New	3	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	4	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	213	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	213	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	1	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11004	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	3	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations VCB New	3	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	90.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	100.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps C Ø	90.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AF	700	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	700	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Operations Counter AF	165	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	General Comments	51 on A , B an N	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	9 Month Operations	2	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	9 Month Operations VCB New	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Amps A Ø	150.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Amps B Ø	165.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Amps C Ø	160.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Adjusted Amps A Phase V	13.43	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Operations A Ø	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Unknown Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Operations Counter AL	165	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Readings	Operations This Read Vac	1	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1158.40	kw
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	120	°C
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3620	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002056	BreakerVacuum	529-0042	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	520.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	525.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	520.0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations VCB New	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	160	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	160	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Operations Ground	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Maintenance Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Operations C Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Operations Counter AF	279	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Operations Counter AL	279	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Operations This Read Vac	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Switching Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Unknown Operations	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Operations B Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Operations A Ø	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	9 Month Operations VCB New	1	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Readings	9 Month Operations	1	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	All Connections OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	LTCC000971	LTCControl	860-2	LTC Control Insp	LTC Operation Checked?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BK002076	BreakerVacuum	529-608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	1111	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	168283	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	168283	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/24/2023 10:52	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	85	°C
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	.8690	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Max	80	°C
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	15642.00	kw
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.7	amps
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.0	VDC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	FE000892	Fence	529-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/24/2023 10:48	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC Operations Since Last Insp	231	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC As Left Counter	157231	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	LTC As Found Counter	157231	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Counter Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	9 Month Operations	4	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	9 Month Operations VCB New	4	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty B Ph V	2.59	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty C Ph V	2.59	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps A Ø	88.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps B Ø	90.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps C Ø	200.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AF	204	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AL	204	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	3	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	.49	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	2.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	2.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	2.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	83	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps A Ø	119.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	139.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	95.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	9 Month Operations	5	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	9 Month Operations VCB New	4	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty A Ph V	1.46	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps A Ø	230.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps B Ø	240.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99834	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps C Ø	220.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps A Phase V	6.55	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AF	170	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AL	170	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations This Read Vac	1	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99834	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations A Ø	1	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	83	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	2	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations This Read Vac	3	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	3	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	6	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations VCB New	6	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	1.91	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	2.87	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	288.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	295.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	236.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	369	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	369	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	373.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	384.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	394.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	47	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	47	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	263	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	263	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	90503	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	90503	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	122.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	115.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	113.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	394	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	392	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	51.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	66.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	14	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations VCB New	12	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	55.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	12.26	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	12.26	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	12.26	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	405	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	405	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	182.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	197.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	185.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	206	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	206	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	290	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	290	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	100.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	151.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	100.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	6.55	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	6.55	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	6.55	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	415	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	415	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	61.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	77.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	264	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	264	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	57.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	128.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	122.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	188.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	261	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	261	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	242	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	242	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	473	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	473	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	150.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	200.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	200.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	166	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	166	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	400.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	400.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	400.0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	44622	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	44622	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	2L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	884	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	8L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	5R	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	11076.48	kw
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	.7692	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	60	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	9 Month Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps A Ø	107.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps B Ø	96.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps C Ø	124.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AL	184	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AF	184	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps A Ø	25.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps B Ø	36.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps C Ø	16.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AF	200	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AL	200	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	9 Month Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps A Ø	89.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps B Ø	118.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps C Ø	92.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	9 Month Operations	1	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AF	201	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AL	201	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Switching Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AF	197	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AL	197	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps C Ø	29.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps B Ø	37.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps A Ø	42.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations	2	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	855	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	5L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	67060	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	67060	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	103.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	100.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	113.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	205	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	205	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.7314	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	50	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	70	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	10532.16	kw
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	2	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	302	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	302	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Switching Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AL	176	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AF	176	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps C Ø	224.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps B Ø	254.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps A Ø	211.0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	9 Month Operations	0	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	35049	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	35049	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	475	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	9L	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	1533	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	119310	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	119310	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	4644.00	kw
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	.6450	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.4860	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	75	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	35	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	6998.40	kw
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	13536.00	kw
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	70	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	20	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	75	°C
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.9400	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	953	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	37211	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	37211	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.0	VDC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BAT001674	Battery	717-Battery Bank	Battery Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.8	amps
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.3	amps
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	BCH001565	Charger	717-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2023 14:50	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2023 14:57	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	9	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	210	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	210	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	9	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	41.04	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	41.04	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	41.04	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	87.0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	91.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	101.0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	11	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	13	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	6	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	27.36	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	13.0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	194	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	194	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	12	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	27.36	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	6	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	18.0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	19.0	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	3705.60	kw
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.3860	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	120378	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	737	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	120378	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BCH001563	Charger	660-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/23/2023 14:44	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	152	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps C Ø	398.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	152	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps B Ø	379.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps A Ø	384.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AL	221	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AF	221	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps C Ø	40.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps B Ø	63.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps A Ø	35.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps C Ø	94.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps B Ø	95.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps A Ø	90.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AF	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AL	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations B Ø	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps C Phase V	12.55	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps B Phase V	12.55	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps C Ø	123.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations C Ø	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps B Ø	117.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps A Ø	122.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AF	226	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations Counter AL	226	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Operations This Read Vac	2	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations	4	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps A Ø	0.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps B Ø	0.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps C Ø	0.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AL	191	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations VCB New	1	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	230.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	252.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	248.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AF	191	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	2L	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	603	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	13931	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	13931	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	7464.00	kw
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	57	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.3110	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	58	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	30	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AF	225	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AL	225	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps A Ø	145.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps C Ø	150.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps B Ø	154.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps C Ø	170.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps B Ø	180.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps A Ø	170.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations	8	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations VCB New	8	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AF	210	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AL	210	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Unknown Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Switching Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations This Read Vac	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AL	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AF	197	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Maintenance Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations Ground	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations C Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations B Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations A Ø	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps C Ø	77.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps B Ø	52.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps A Ø	85.0	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	8904.00	kw
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.3710	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	All Connections OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	13360	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	13360	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	1000	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments	right side back corner and midway down back fence	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2023 14:08	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Operations Counter	45	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps A Ø	170.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps B Ø	160.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps C Ø	160.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Operations Counter	31	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	All Connections OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Operations Since Last Insp	233	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Found Counter	21996	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Left Counter	21996	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Max Tap Position	3L	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	LTC Totalizer Reading	6635.52	kw
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Present	20	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Reading	.6912	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Present	20	°C
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	General Comments		
10/23/2023 13:26	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Unknown Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Switching Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations This Read Vac	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps A Ø	151.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps B Ø	175.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps C Ø	175.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations	3	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations VCB New	3	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations A Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations B Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations C Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations Ground	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Maintenance Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AF	226	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AL	226	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	487	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	487	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	120.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	122.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	135.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Unknown Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Switching Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations This Read Vac	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AL	177	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AF	177	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Maintenance Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations Ground	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations C Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations B Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps B Ø	251.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps C Ø	255.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations A Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	9 Month Operations	2	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	9 Month Operations VCB New	2	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps A Ø	240.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	9 Month Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations A Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations B Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations C Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations Ground	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Maintenance Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AF	194	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AL	194	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations This Read Vac	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Switching Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Unknown Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps C Ø	45.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps B Ø	45.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps A Ø	45.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	9 Month Operations VCB New	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	594.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	177	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	574.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	533.0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	177	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	5	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations VCB New	5	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	58815	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	1251	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	5L	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	16R	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	58815	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	3R	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	30	°C
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	70	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.3070	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	30	°C
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	23526.00	kw
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2023 11:14	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	9 Month Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps A Ø	0.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps B Ø	0.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps C Ø	0.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AF	166	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AL	166	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	9 Month Operations	38	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Amps A Ø	256.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Amps B Ø	239.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Amps C Ø	270.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Operations Counter AL	240	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Operations Counter AF	207	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Readings	9 Month Operations VCB New	38	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK001580	BreakerVacuum	617-0140	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	330	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	330	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	330.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	317.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	315.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	29.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	31.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	36.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	341	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	341	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	257	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	130.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	163.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	166.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	257	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	9 Month Operations	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Operations Counter AF	292	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002075	BreakerVacuum	617-618	VCB Readings	Operations Counter AL	292	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Operations Counter AL	364	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Operations Counter AF	364	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	9 Month Operations VCB New	17	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Readings	9 Month Operations	17	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK002074	BreakerVacuum	617-608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AF	226	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AL	226	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps C Ø	393.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps B Ø	402.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps A Ø	420.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	355.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	343.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	351.0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	1	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	204	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	201	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	0	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	549	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	1L	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	132042	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	132042	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	All Connections OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	9277.20	kw
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	.5154	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	35	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	16870	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	16870	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	697	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	70	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	.4570	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	8226.00	kw
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.1	amps
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BCH001564	Charger	617-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 15:04	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0042	BreakerVacuum	428-Offline-Distribution	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0042	BreakerVacuum	428-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0042	BreakerVacuum	428-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	85	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	85	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps A Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps B Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps C Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AL	242	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	9 Month Operations	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AF	242	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AL	220	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AF	220	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps C Ø	235.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps B Ø	277.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps A Ø	257.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps A Ø	401.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps B Ø	400.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps C Ø	350.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AL	210	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AF	210	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AL	163	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AF	163	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps B Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps C Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps A Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps B Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps A Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AL	201	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AF	201	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AL	230	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AF	230	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps C Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps B Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps A Ø	0.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	9 Month Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AL	229	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AF	229	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps A Ø	102.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps B Ø	129.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps C Ø	101.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps A Ø	158.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps B Ø	150.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps C Ø	139.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AL	262	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AF	262	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations	5	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations VCB New	5	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps C Ø	119.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps B Ø	152.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps A Ø	158.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AF	273	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AL	273	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AF	223	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AL	223	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations	5	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations VCB New	5	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps C Ø	160.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps B Ø	173.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps A Ø	173.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations	23	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations VCB New	23	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps C Ø	77.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps B Ø	69.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps A Ø	75.0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Maintenance Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AF	275	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AL	275	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Switching Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Unknown Operations	0	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	All Connections OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Operations Since Last Insp	426	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Min Tap Position	5L	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Current Tap Position	3L	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Left Counter	13185	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Found Counter	13185	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Max	60	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Present	26	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Reading	28.0000	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Present	27	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	LTC Totalizer Reading	28000.00	kw
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Found Counter	31936	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Left Counter	31936	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Operations Since Last Insp	444	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Present	26	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	MegaVar Demand Meter Max	1.00	MegaVars
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	LTC Totalizer Reading	1500.00	kw
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Reading	1.5000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Max	45	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Kwh Reading	79000	KwH
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Present	24	°C
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 14:54	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AF	210	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	9 Month Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps A Ø	71.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps B Ø	69.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps C Ø	64.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AL	210	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AF	197	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AL	197	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	9 Month Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps A Ø	74.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps B Ø	71.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps C Ø	81.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps C Ø	135.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps B Ø	135.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps A Ø	130.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AL	223	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AF	223	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	9 Month Operations VCB New	6	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	9 Month Operations	6	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps B Ø	69.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps A Ø	71.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps C Ø	70.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	9 Month Operations	4	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AF	211	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AL	211	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations This Read Vac	2	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Switching Operations	2	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations This Read Vac	3	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps B Ø	134.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps A Ø	141.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AL	378	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AF	378	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps C Ø	158.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps B Phase V	16.96	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps C Phase V	33.91	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations B Ø	1	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations C Ø	2	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations	3	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps A Ø	169.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps B Ø	178.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps C Ø	144.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps C Phase V	16.96	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations This Read Vac	1	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations C Ø	1	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AF	369	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	9 Month Operations VCB New	4	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	9 Month Operations	5	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AL	369	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps B Ø	0.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps A Ø	0.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps C Ø	0.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	9 Month Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AL	220	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AF	220	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps C Ø	193.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps A Ø	229.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AF	344	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps B Ø	182.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	9 Month Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AL	344	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations This Read Vac	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps C Ø	117.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AL	211	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AF	211	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps B Ø	125.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations A Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations B Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps A Ø	140.0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations C Ø	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations Ground	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Maintenance Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Unknown Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Switching Operations	0	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Found Counter	217909	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Left Counter	217909	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Operations Since Last Insp	605	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	4506.00	kw
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	.7510	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	All Connections OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Operations Since Last Insp	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Min Tap Position	12L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Max Tap Position	3R	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Current Tap Position	5L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Left Counter	9850	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Found Counter	9850	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	General Comments	Counter not working.	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Reading	.5418	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Present	40	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	LTC Totalizer Reading	5201.28	kw
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Max	50	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Operations Since Last Insp	370	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Left Counter	11116	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Found Counter	11116	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Reading	.7920	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	LTC Totalizer Reading	4752.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	124.0	VDC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 14:47	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	125	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	125	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AF	159	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AL	159	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	9 Month Operations	3	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	9 Month Operations VCB New	3	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps A Ø	62.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps B Ø	64.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps C Ø	61.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	165	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AF	165	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AL	164	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AF	164	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps A Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	9 Month Operations	7	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	9 Month Operations VCB New	7	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps C Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps B Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	9 Month Operations	4	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	9 Month Operations VCB New	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps A Ø	70.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps B Ø	75.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps C Ø	107.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AF	203	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AL	203	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AF	204	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AL	204	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps A Ø	88.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps B Ø	111.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps C Ø	88.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	182.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	223.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	229.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	186	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	186	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	88.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	92.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	87.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	262	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	262	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	81.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	85.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	80.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	227	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	227	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations VCB New	5	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	5	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	191	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	191	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	131	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	131	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations VCB New	5	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations	5	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations This Read Vac	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	168	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AF	168	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Maintenance Operations	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations Ground	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations C Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations B Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	169.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	179.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	169.0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Ground Connections Intact?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Rosettes Clean and Lubed?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Vacuum and Clean Breaker?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Bearings lubricated?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	All Connections OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Left Counter	28594	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Found Counter	28594	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	General Comments	Counter not working.	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Max	40	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Reading	1.0000	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Multiplier	1	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.72	MegaWatts
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaVar Demand Meter Max	.52	MegaVars
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	LTC Totalizer Reading	1.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Kwh Reading	38914	KwH
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	707	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	12L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	10L	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	15666	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	15666	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	27	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	52	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.3510	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	27	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	52	°C
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	8424.00	kw
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	9026	KwH
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.7	amps
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 10:20	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AF	275	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AL	275	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps A Ø	325.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps B Ø	399.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps C Ø	281.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	65	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	65	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	All Connections OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	44572	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	44572	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	8L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	3R	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	11L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	518	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	10238.40	kw
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	55	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.7110	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	50	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Present	50	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations B Ø	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations A Ø	2	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps C Phase V	10.65	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps B Phase V	10.65	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps A Phase V	15.98	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	66.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	81.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	68.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	4.76	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	6.35	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	5.96	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	7	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Unknown Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Switching Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations This Read Vac	5	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AL	235	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AF	235	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Maintenance Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations Ground	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations C Ø	1	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AL	182	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AF	182	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps C Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps B Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps A Ø	0.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	9 Month Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	58.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	.4	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	54.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	57.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	242	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	3.97	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	242	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations This Read Vac	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	2.78	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations VCB New	2	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	2	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Switching Operations	3	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps C Ø	222.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps B Ø	244.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps A Ø	236.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	9 Month Operations	4	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations This Read Vac	3	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AL	157	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AF	157	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations C Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	33263	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	38136	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCM000081	LTCMechanism	662-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	9720.00	kw
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	70	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.6750	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Present	45	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	33637	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	4L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations Ground	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Unknown Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Switching Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations This Read Vac	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations Counter AF	225	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Maintenance Operations	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations Counter AL	225	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps C Ø	73.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps B Ø	95.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps A Ø	69.0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	9 Month Operations VCB New	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations C Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations B Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations A Ø	0	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	9 Month Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4992	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	45	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	48	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3594.24	kw
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	508	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	10462	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	10462	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	LTC Totalizer Reading	2073.60	kw
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.4320	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.8	amps
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 9:54	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	7	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauges	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	449	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	208	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	232	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauges	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	82163	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	104544	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92860	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	350.76	kw
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2923	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 14:30	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	180.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	180.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	180.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1434	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Operations Counter	1873	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations This Read Vac	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	398	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	398	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	11	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations VCB New	11	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	177.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	155.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	179.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	1	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations This Read Vac	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	307	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	307	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	48.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	41.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	50.0	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations VCB New	1	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	759	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	10L	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	2L	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	25860	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	25860	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Operation Checked?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	All Connections OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.3390	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	6427.20	kw
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	All Connections OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	LTC Operation Checked?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	LTCC000976	LTCControl	826-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	5639	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	5639	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	865	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.6890	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	6614.40	kw
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments	no spill kit	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 12:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BCH001614	Charger	758-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.7	VDC
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	BAT001677	Battery	758-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	86775	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Regulator As Left Counter	92246	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	73544	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments	error code on meter	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.2	psi
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99946	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99946	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	125.0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	110.0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	100.0	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations VCB New	1	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	1	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments		
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments	Metering equipment conduit in need of repair	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty and droopping in areas.	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments	2 washouts left side of gate lot area	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 11:51	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.0750	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	41	°C
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Max	48	°C
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	LTC Totalizer Reading	180.00	kw
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	435770	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	435781	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	11L	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	473	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	40	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	40	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	20.0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	0.0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	20.0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	0	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations VCB New	4	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	4	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	All Connections OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.220	millivolts
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2023 7:23	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	744	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	744	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations VCB New	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	100.0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	100.0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	100.0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	445468	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	445468	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	2R	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	1023	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	All Connections OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	LTC Operation Checked?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000981	LTCControl	719-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2550.96	kw
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3543	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BCH001608	Charger	581-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	BAT001676	Battery	581-Battery Bank	Battery Patrol Inspection	General Comments	Heater in cabinet was off, placed on auto and turned to 70 deg F	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.8802	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	4224.96	kw
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments	Fans found on manual, placed in auto	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	532129	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	532132	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	636	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	52.0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	54.0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	102	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	1	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	1	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations VCB New	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	40.0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	60.0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	40.0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.3	VDC
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments		
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2023 10:42	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments	no spill kit	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2023 10:49	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	56	°F
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	9 Month Operations GCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	72	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	72	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	1	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	24972	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	26052	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	23470	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8030	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Max	70	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7708.80	kw
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	152.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	139.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	134.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations VCB New	2	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	2	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	244	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	244	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	2	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations VCB New	2	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	202.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	218.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	233.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	261	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	261	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	277.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	268	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	268	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	298.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	281.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations VCB New	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	293	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	293	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations VCB New	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	0	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36282	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	86636	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	3672	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7182	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6894.72	kw
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments	no spill kit	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/19/2023 9:57	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	526	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	3L	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	32911	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	32911	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments	as left counter was entered wrong last quarter (JB corrected the as left counter from 7/24/23)	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps C Ø	65.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps B Ø	56.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps A Ø	66.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Maintenance Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AF	180	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AL	180	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations This Read Vac	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty A Ph V	.68	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	9 Month Operations VCB New	3	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	9 Month Operations	3	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Switching Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Unknown Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	103.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	93.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	104.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	1.7	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations VCB New	4	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	4	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	289	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	289	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	719	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	11L	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	1L	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	4L	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	32385	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	32382	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AL	180	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations This Read Vac	2	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Switching Operations	2	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Unknown Operations	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations B Ø	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations A Ø	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps C Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps B Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps A Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps C Ø	78	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps B Ø	75	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps A Ø	90	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty C Ph V	0	%
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty B Ph V	0	%
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty A Ph V	.68	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	9 Month Operations VCB New	2	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	9 Month Operations	4	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AF	180	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Maintenance Operations	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	General Comments		
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Follow-up Action Required?	n	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations Ground	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	289	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	289	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations C Ø	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	5	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations VCB New	5	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	1.7	%
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0	%
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	153	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	128	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	138	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0	
7/24/2023 15:03	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Unknown Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	9 Month Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Switching Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations This Read Vac	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations Counter AL	174	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations Counter AF	174	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Maintenance Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps A Ø	32.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps B Ø	30.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps C Ø	30.0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.4584	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	4400.64	kw
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	509755	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1537	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	509755	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Maintenance Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations Counter AF	154	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations Counter AL	155	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps C Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps B Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps A Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations This Read Vac	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Switching Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Unknown Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	9 Month Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	310.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	250.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	256	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	300.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	255	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1369	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	498973	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	498972	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	554	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	553	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	275.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	275.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	250.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps A Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps B Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps C Ø	0.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations This Read Vac	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	227	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	228	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations This Read Vac	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	243	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	242	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	1	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	90.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	90.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	90.0	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	8	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	339	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	339	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	9	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	1	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Month Ops New	11	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	20	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	0.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	0.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	0.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	528	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Month Ops New	4	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	4	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	80.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	80.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	80.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	528	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	100.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	100.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Month Ops New	16	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	16	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	100.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	305	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	305	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 14:44	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	40.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	40.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	2	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	40.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Month Ops New	2	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	621	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	621	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Month Ops New	8	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	14	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	160.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	160.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	160.0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	1	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	5	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	387	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	387	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	6	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Present	46	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	69	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.5050	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Present	46	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	66	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	12120.00	kw
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	665	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	6L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	6R	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	26934	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	26934	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	59	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/18/2023 14:15	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	All Connections OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	73720	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	214	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	73720	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	423	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	52054	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	52054	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.5880	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	14112.00	kw
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 14:13	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	544700	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	544700	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1660	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Month Ops New	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	2	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Month Ops New	2	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	140.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	130.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	150.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	282	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	282	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	412	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	412	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Month Ops New	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Month Ops New	2	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	488	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	488	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	20.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	2	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	506	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	506	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	100.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	100.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	100.0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Month Ops New	0	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	2	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations VCB New	2	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	252	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	252	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	15.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	40.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	70.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	396	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	396	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	75.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	80.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	70.0	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations VCB New	6	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	6	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15786	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments	Neighbor's fence is within 6 feet. .	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	13590	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16300	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/18/2023 14:04	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6964	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1671.36	kw
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 13:57	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations Ground	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations C Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations B Ø	3	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations A Ø	2	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps B Phase V	15.20	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	9 Month Operations VCB New	1	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	9 Month Operations	6	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Maintenance Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps A Phase V	10.13	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps C Ø	49.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps B Ø	47.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps A Ø	56.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AF	194	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AL	194	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations This Read Vac	5	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Switching Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Unknown Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	342	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	342	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	289.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	290.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	289.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations This Read Vac	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	518	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	518	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	15.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	21.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	9.0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	0	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	148650	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	140866	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	135530	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9300	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8928.00	kw
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 13:26	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	9 Month Operations GCB New	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Fault Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Maintenance Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Num Operations Last 9 Months	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AF	68	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AL	68	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations This Read SF6	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Switching Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Ambient Temperature	58	°F
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	General Comments	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Pressure	88	psi
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	8	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations VCB New	8	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	60.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	120.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	20.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	103	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	103	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	1	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	1	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	10.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	10.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	10.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations VCB New	4	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	6	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	257	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	257	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations This Read Vac	2	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations This Read Vac	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	35	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	35	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	160.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	160.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180.0	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations VCB New	5	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	5	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	758	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	18008	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	18008	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.6354	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	6099.84	kw
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.5	VDC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.2	VDC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	131.2	VDC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 12:07	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AL	167	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations This Read Vac	1	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AF	167	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations C Ø	1	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps C Phase V	5.72	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps C Ø	89.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps B Ø	77.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps A Ø	98.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations VCB New	4	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations	5	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AL	161	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AF	161	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps A Ø	64.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps B Ø	61.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps C Ø	55.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AF	173	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AL	173	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations This Read Vac	1	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations C Ø	1	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps C Phase V	5.72	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps C Ø	56.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps B Ø	67.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps A Ø	67.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	9 Month Operations	1	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps A Ø	231.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps B Ø	205.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps C Ø	199.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	9 Month Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AL	181	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AF	181	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	401	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	401	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	26.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	24.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	17.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	359	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	64.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	75.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	60.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations VCB New	3	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	3	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	359	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	278	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	278	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	971	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	10L	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	74528	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	74528	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	135.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	170.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	150.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	192	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	192	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	9 Month Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps A Ø	99.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps B Ø	116.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps C Ø	104.0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Maintenance Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AF	166	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AL	166	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Switching Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Unknown Operations	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	1	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps A Ø	255.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps B Ø	235.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps C Ø	240.0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Maintenance Operations	0	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AF	244	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AL	244	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations This Read Vac	1	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Switching Operations	1	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Unknown Operations	0	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15269	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	35	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.2610	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	70	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	4698.00	kw
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15520	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	49247	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	4L	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	49247	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	3R	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	9L	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	1107	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17187	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1945.60	kw
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6080	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	2160.00	kw
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	30	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	50	°C
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.1200	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	652	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	88989	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	88989	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Reading	.9930	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	LTC Totalizer Reading	3177.60	kw
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.0	VDC
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BCH001568	Charger	735-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.2	VDC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments	no spill kit in sub	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
10/18/2023 10:48	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	General Comments		
10/18/2023 10:44	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	3	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	335.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	335.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	325.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	1	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	1	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations This Read Vac	3	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	186	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	1	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	186	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	0.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	0.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	0.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	183	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	183	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Unknown Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AL	205	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AF	205	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Maintenance Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps C Ø	5.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps B Ø	4.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps A Ø	5.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Unknown Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Switching Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations B Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations C Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations Ground	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations A Ø	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Maintenance Operations	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AF	194	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations This Read Vac	0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AL	194	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations	4	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations VCB New	4	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps A Ø	22.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps B Ø	4.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps C Ø	0.0	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	9129.60	kw
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.6340	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	635	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	71308	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	71308	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 10:35	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	443	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	23313	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	23313	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	80	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	13622.40	kw
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.9460	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	573	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	40086	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	40086	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	70	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.7569	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	7266.24	kw
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	1	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	1	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	53	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	53	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	1	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	9 Month Operations GCB New	0	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	52	°F
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 10:28	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	9 Months Operations OCB New	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	31	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	31	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	All Connections OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	58554	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	58554	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	3L	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	416	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	65	°C
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.6237	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	14968.80	kw
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 10:23	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps B Ø	12.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps C Ø	16.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AL	375	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps A Ø	3.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	9 Month Operations VCB New	1	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	9 Month Operations	3	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations A Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations This Read Vac	2	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Switching Operations	2	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Unknown Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations B Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations C Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations Ground	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AF	375	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Maintenance Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	7	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations VCB New	7	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	69.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	59.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	62.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	346	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	346	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	302	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	302	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	2	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations VCB New	2	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	67.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	54.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	61.0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	118340	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	112214	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	136474	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4099.20	kw
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4270	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments	there is no spill kit	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 9:34	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	PF001322	PowerFuse	746-1F	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	PF001322	PowerFuse	746-1F	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	PF001322	PowerFuse	746-1F	Disconnect Powerfuse Inspection	General Comments	x	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Amps B Ø	280.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Amps A Ø	277.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Amps C Ø	328.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	9 Month Operations	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Unknown Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations A Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations B Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations C Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations Ground	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Maintenance Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations Counter AF	191	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations Counter AL	191	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations This Read Vac	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Switching Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	9 Month Operations	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Unknown Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps A Ø	0.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps B Ø	0.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps C Ø	0.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Switching Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Operations This Read Vac	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Operations Counter AL	157	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Operations Counter AF	157	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Maintenance Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Operations Ground	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Operations C Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Operations B Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Operations A Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps A Ø	360.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps B Ø	260.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps C Ø	240.0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Unknown Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Switching Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations This Read Vac	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AL	241	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AF	241	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Maintenance Operations	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	9 Month Operations	1	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations Ground	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations C Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations A Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Fault Operations B Ø	0	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	3L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	3L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	3L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.1	volts
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	85044	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Output Voltage Level	120.8	volts
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Regulator As Left Counter	51426	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Current Tap Position	4L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Min Tap Position	8L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Max Tap Position	2L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	22159	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.6	volts
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	54099	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.9	volts
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1499	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	899.40	kw
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0369	NonLTC	746-2 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0368	NonLTC	746-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	335433	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	335433	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	146	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1755	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	1053.00	kw
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.7	VDC
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/17/2023 16:25	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	104272	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	104272	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	25	°C
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Present	25	°C
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 14:54	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps C Ø	258.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps B Ø	271.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps A Ø	240.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	175	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	175	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	181	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	181	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	263.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	271.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	130.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	127	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	127	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	236.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	250.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	237.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	199	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	199	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	264.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	277.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	138.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations VCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	139	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	139	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Pressure	64	psi
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Ambient Temperature	55	°F
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	9 Month Operations GCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations This Read SF6	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AL	84	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AF	84	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Num Operations Last 9 Months	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	66	psi
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	55	°F
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Switching Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	85	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations This Read SF6	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	85	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	9 Month Operations GCB New	1	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	120.9	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Output Voltage Level	121.1	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	4265.28	kw
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.2962	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	0.0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	0.0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	0.0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	321	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	321	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	28301	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	28301	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	6L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	2L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	10L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	274	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	267	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	267	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	65.0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	70.0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	70.0	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	44	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	27652	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	2L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	293	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	27625	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	383	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	41325	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	41235	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	.3588	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	47	°C
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	5166.72	kw
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.1169	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	1683.36	kw
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.3	VDC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	65.8	VDC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.2	VDC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.5	VDC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments	there are no fuses in the sub	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	FE000891	Fence	825-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/17/2023 14:48	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments	Yard light near the control house is not working	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 14:44	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	246	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	246	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	25.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	25.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	30.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	9 Month Operations	2	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Maintenance Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Unknown Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Switching Operations	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Operations Counter AL	176	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Amps C Ø	30.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Amps B Ø	30.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	9 Month Operations VCB New	2	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Readings	Amps A Ø	30.0	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BK002057	BreakerVacuum	823-0082	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	362	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	78367	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	78367	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	LTCC000856	LTCControl	823-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	1708.80	kw
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.3560	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.9	VDC
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 14:33	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps C Ø	60.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps B Ø	30.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps A Ø	25.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	9 Month Operations VCB New	12	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Maintenance Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	9 Month Operations	12	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AF	195	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AL	195	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Switching Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Unknown Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps A Ø	120.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps B Ø	115.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps C Ø	115.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	9 Month Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Maintenance Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AF	195	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AL	195	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Switching Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Unknown Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations Ground	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations A Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations B Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Maintenance Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AF	218	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AL	218	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations C Ø	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	9 Month Operations	9	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations This Read Vac	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Switching Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Unknown Operations	0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	9 Month Operations VCB New	9	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps A Ø	30.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps B Ø	35.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps C Ø	25.0	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	6192.00	kw
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	.6450	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	43360	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	819	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	43360	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BCH001561	Charger	832-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.9	VDC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	67.2	VDC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	67.3	VDC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 14:27	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.400	millivolts
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Base Voltage AF	118.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	LTC Output Voltage Level	118.6	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	All Connections OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Base Voltage AL	118.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	501	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	6L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	1L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	68455	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	68450	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	50	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	30	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	50	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	30	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	55	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	49	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	30	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations VCB New	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	8.3	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	8.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	6.2	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	133	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	133	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	13.2	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	15.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	15.4	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations VCB New	11	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	12	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations This Read Vac	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	88	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	88	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	116	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	116	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	18.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	22.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	24.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations VCB New	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps C Ø	93.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps B Ø	78.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps A Ø	63.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	9 Month Operations VCB New	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	9 Month Operations	1	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations Counter AF	197	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations Counter AL	197	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AL	177	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AF	177	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps C Ø	70.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps B Ø	113.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps A Ø	88.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	9 Month Operations VCB New	2	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	9 Month Operations	2	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	6	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations VCB New	6	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	151.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	181.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	163.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	194	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	194	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations	11	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations VCB New	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps A Ø	0.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps B Ø	0.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	68	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	68	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	4	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations VCB New	4	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	89.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	89.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	83.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	214	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	214	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	9 Month Operations VCB New	3	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	9 Month Operations	3	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Maintenance Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations Counter AF	182	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations B Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations A Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations Ground	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations C Ø	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations Counter AL	182	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps A Ø	89.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps B Ø	89.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations This Read Vac	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Switching Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Unknown Operations	0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps C Ø	83.0	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Time Delay	60	Seconds
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	All Connections OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	86569	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	86574	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	5L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	3L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	9L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	814	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	22	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	42	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.2050	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	24	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	40	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	1968.00	kw
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	All Connections OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Operation Checked?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Time Delay	60	Seconds
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	791	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	6L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	98511	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	98515	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	2L	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	27	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	50	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	.3780	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	3628.80	kw
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	45	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	28	°C
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/18/2023 7:30	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps A Ø	74.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations VCB New	4	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations	4	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	69.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	85.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	177	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	177	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations This Read Vac	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	5	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations VCB New	5	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations This Read Vac	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	185	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	185	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	96.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	85.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	94.0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	238	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	3L	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	243827	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Found Counter	243827	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	LTCC000969	LTCControl	586-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.5010	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	1603.20	kw
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments	fence about 18" from ours	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments	ther is not a spill kit in the station	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/17/2023 13:09	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps A Ø	0.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps B Ø	0.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps C Ø	0.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations A Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations B Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations C Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations Ground	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Maintenance Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AF	187	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AL	187	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations This Read Vac	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Switching Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Unknown Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps A Ø	39.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Unknown Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Switching Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations This Read Vac	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AL	215	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AF	215	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Maintenance Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps B Ø	32.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps C Ø	37.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations Ground	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations C Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations B Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations A Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations VCB New	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps A Ø	50.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps B Ø	63.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps C Ø	48.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations A Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations B Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations C Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations Ground	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	1696	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	1696	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations This Read Vac	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations This Read Vac	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	2	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations VCB New	2	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	461	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	461	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	111.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	120.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	97.0	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Operations Since Last Insp	303	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Left Counter	15982	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Found Counter	15982	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	All Connections OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Operation Checked?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.7530	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	70	°C
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	7228.80	kw
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	1.7	VDC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	50.1	VDC
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 12:18	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.0	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.0	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.0	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	General Comments	counter 34-35-618	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Operations Counter	34	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	MX0220	RecloserHydraulic	555-4421	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	168756	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63221	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	237983	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.4850	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	582.00	kw
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments	a lot of stuff stored around the sub gate	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments		
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/17/2023 11:53	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments	There is no yard light	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Operations Counter	0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps B Ø	4.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Operations Counter	0	
10/18/2023 7:30	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	.6	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	.5	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13827	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	426957	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	854717	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0012	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1.44	kw
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	101.67	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps A Ø	80.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps B Ø	85.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps C Ø	65.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps A Phase V	.72	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations A Ø	1	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Maintenance Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations Counter AF	171	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations Counter AL	171	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	9 Month Operations VCB New	26	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	9 Month Operations	27	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Switching Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Unknown Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Maintenance Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Unknown Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Switching Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations Counter AL	179	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations Counter AF	179	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	9 Month Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps C Ø	670.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps B Ø	645.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps A Ø	640.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	9 Month Operations VCB New	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	225	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	225	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	110.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	110.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	110.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations VCB New	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations VCB New	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	258	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	258	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	33694	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	37258	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	14L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	28710	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.4520	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Max	25	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2169.60	kw
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	1.1740	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	7044.00	kw
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	1405	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	1405	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	142	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	All Connections OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	786.40	kw
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	50	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	35	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	.0983	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	20	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	8L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	2L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	4L	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	27123	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	27123	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	560	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.4	amps
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 14:51	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	All Connections OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Output Voltage Level	122.3	VAC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	14	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations VCB New	14	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	230	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	230	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	40.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	40.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	25.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	90.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	120.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	115.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	313	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	313	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	1	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations VCB New	9	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	10	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	1	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	All Connections OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	967	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	100761	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	100761	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	.5140	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	4934.40	kw
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	17.2	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	19.4	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	18.6	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	1	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations This Read Vac	1	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	191	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	191	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	400.0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	400.0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	1	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations VCB New	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	400.0	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	1616	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	75967	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	75965	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2023 14:37	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	5160.96	kw
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	62	°C
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.0752	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.8	VDC
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations VCB New	6	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	6	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	370.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	375.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	365.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	257	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	257	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	0	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	253	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	85.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	85.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations VCB New	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	85.0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	253	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 14:38	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	17978	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	862	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	17978	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	3742.08	kw
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.7796	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 14:28	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments		
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/18/2023 7:30	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	9	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations VCB New	9	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	64.0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	64.0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	64.0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations This Read Vac	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	263	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	263	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128300	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	97045	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	112229	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1539.36	kw
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6414	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	56.67	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments	Control house needs painted. W/O created	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Trash Emptied?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Evidence of Insects	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Broom on Site?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Acceptable Building Appearnce?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 12:50	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	20014	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	385632	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92299	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps B Ø	.3	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	448	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	652	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	871	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.3	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	MX0270	RecloserHydraulic	311-0690	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	53	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	930.96	kw
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	41	°C
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7758	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2023 10:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	247784	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	247784	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1958	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	62	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	50	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	63	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	63	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	51.82	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	83.7	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	23.12	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	375	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	375	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	236.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	246.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	232.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	74.93	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	69.35	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	84.5	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations VCB New	5	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	75.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	83.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	80.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	4	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	5	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	12.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	13.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	178	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	178	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	288	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	288	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	127.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	82.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	116.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	14.35	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	14.35	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	2	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	3	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations VCB New	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	11.55	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	618.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	616.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	4	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	605.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	267	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	267	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	12	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations VCB New	12	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	245	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	245	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	187	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	187	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	10	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	360	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	360	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations VCB New	10	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	36.67	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	25.51	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	199.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	170.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	189.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	184	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	238	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	238	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations VCB New	3	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	3	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	3	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations VCB New	3	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	187.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	215.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	183.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	428.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	417.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	230	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	230	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	38.5	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	38.5	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	38.5	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	455.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	184	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Month Ops New	8	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	8	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	19.27	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	19.27	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	334	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	334	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	253	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	253	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	50.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	65.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	34.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	25.29	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	1	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Month Ops New	1	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	331.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	327.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	275.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	245826	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	245826	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	Neutral	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1466	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	48	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	59	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	48	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	59	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	44	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	47	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	46	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	56	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	230	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	230	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	245	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	245	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	12.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	13.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	14.35	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	14.35	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations VCB New	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	2	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	127.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	82.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	116.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	3	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	3	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	187	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	187	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	183.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	215.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	187.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations VCB New	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations VCB New	3	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations VCB New	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	428.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	417.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	455.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	375	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	375	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	80.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	83.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	75.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	23.12	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	83.7	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	48.63	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations VCB New	8	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	12	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	184	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	6.38	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	184	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	36.67	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	25.51	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	199.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	267	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	288	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	288	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	605.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	616.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	618.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	11.55	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations VCB New	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	38.5	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	38.5	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	38.5	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	170.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	360	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	360	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	5	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	189.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	5	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations VCB New	4	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	178	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	84.5	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	69.35	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	74.93	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	232.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	246.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	236.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	267	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	178	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	238	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	238	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	10	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations VCB New	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	3	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations VCB New	10	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	331.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	19.27	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	327.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	275.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	19.27	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	8	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Month Ops New	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	9.64	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	25.29	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	7.23	%
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	34.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	65.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	50.0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	334	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	334	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	253	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	253	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	1	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
7/14/2023 12:02	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Month Ops New	8	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	150.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	140.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	140.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	214	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	214	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Amps A Ø	85.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Amps B Ø	90.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Amps C Ø	90.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Operations Counter AF	180	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Maintenance Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	9 Month Operations VCB New	2	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	9 Month Operations	4	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Unknown Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Switching Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Operations This Read Vac	2	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Operations Counter AL	180	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Operations C Ø	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Operations B Ø	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	20.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	20.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	20.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	192	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	192	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations VCB New	20	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	20	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001596	BreakerVacuum	526-0086	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	224	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	224	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	80.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	95.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	85.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps A Ø	315.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	9 Month Operations	1	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps B Ø	320.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps C Ø	300.0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Maintenance Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AF	182	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AL	182	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Switching Operations	0	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Unknown Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	194	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	194	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	70.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	90.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	70.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations VCB New	14	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	14	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	891	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	8R	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	2R	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	56275	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	56275	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	46	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	46	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	2	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations VCB New	2	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	140.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	140.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	140.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	184	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	184	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	50.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	65.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	60.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations VCB New	13	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	13	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	6926.40	kw
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.4810	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	50	°C
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	45	°C
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BCH001559	Charger	526-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 14:40	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	1	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	1	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	10.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	10.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	10.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	6.13	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	99984	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	99984	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations This Read Vac	2	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	6	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	135.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	100.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	130.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	9	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	7	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	222	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	22	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	2	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	9	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	298	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	108478	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	108478	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	1	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	10	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	6	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	223	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	223	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	5	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	LTCC000973	LTCControl	590-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	6	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	1	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	423	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	423	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	5	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	6	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	200.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	200.0	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	200.0	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	38	°C
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	48	°C
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.2214	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	42	°C
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	52	°C
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	3985.20	kw
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	27.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.6	VDC
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	32494	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	32494	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	644	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 14:39	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	4896.00	kw
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.6120	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.6	VDC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	315	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	315	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps C Ø	10.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps B Ø	50.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps A Ø	10.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	9 Month Operations	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps A Ø	11.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps B Ø	35.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps C Ø	3.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Maintenance Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Unknown Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Switching Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AF	159	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AL	159	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps B Ø	139.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps A Ø	137.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps C Ø	130.0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	9 Month Operations	1	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations A Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations B Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations C Ø	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations This Read Vac	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Switching Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Unknown Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations Ground	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Maintenance Operations	0	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AL	183	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AF	183	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	114732	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	1827	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	114732	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	.9228	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	55	°C
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	2214.72	kw
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.9	VDC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 14:15	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	A.C. Ripple on Batteries	9.800	millivolts
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Positive DC Ground	66.9	VDC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Negative DC Ground	67.0	VDC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	127.0	VDC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	All Connections OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	LTC Output Voltage Level	122.6	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	160014	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	160018	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	533	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	6L	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	1R	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	1L	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	33	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	85	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.2778	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	2666.88	kw
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	42	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	35	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	95.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	249	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	249	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	112.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	97.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	5	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations VCB New	9	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	10	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	293	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	293	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations This Read Vac	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	4	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A Ø	33.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B Ø	50.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C Ø	31.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	9.88	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations This Read Vac	3	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	185	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C Ø	2	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	185	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	53.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations This Read Vac	2	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	48.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	253	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	253	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	54.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations VCB New	2	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	4	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations Counter AF	175	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps C Ø	111.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps B Ø	122.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps A Ø	129.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations Counter AL	175	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations This Read Vac	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	9 Month Operations VCB New	5	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	9 Month Operations	6	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	9 Month Operations	4	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps A Ø	12.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps B Ø	12.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations This Read Vac	3	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AL	164	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AF	164	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps C Ø	26.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations B Ø	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations A Ø	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	1	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	203	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	5	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	142.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	135.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	140.0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	203	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	All Connections OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	LTCC000988	LTCControl	116-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	888	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	6L	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	2R	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	175259	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	175255	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	4250.88	kw
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	36	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	36	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.4428	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	90	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	30	°C
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:29	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1454.40	kw
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6060	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	160.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	153.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	1	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	163.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations This Read Vac	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	200	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	200	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	4	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations This Read Vac	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	672	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	672	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	12.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	12.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	12.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	60.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	120.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	60.0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C Ø	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations VCB New	12	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	12	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	729	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	729	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations This Read Vac	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1198	Regulator	444-1 A	Regulator Patrol Inspection	Regulator As Left Counter	143409	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Regulator As Left Counter	212470	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1200	Regulator	444-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Regulator As Left Counter	75690	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	R1202	Regulator	444-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	15805	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	661	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	15815	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	7L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	9L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	1L	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	2599.20	kw
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	60	°C
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.3610	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 15:12	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations Counter AF	174	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations Counter AL	174	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations This Read Vac	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Switching Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Unknown Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Maintenance Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations Ground	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations C Ø	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations B Ø	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations A Ø	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Amps C Ø	42.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Amps B Ø	40.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Amps A Ø	65.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	9 Month Operations	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	9 Month Operations	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Unknown Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Switching Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps A Ø	50.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps B Ø	60.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps C Ø	55.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations B Ø	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations C Ø	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations This Read Vac	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations Counter AL	203	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations Ground	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations Counter AF	203	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Maintenance Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	9 Month Operations	8	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps A Ø	31.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps B Ø	26.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps C Ø	25.0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps A Phase V	5.20	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps C Phase V	10.39	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations A Ø	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations B Ø	1	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations C Ø	2	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations Ground	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Maintenance Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Unknown Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Switching Operations	0	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations This Read Vac	4	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AL	181	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AF	181	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47875	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42175	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	52909	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2922	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2805.12	kw
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.9	VDC
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 12:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps A Ø	118.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps B Ø	111.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations Counter AF	180	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations Counter AL	180	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Switching Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	9 Month Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps C Ø	134.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AL	99984	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AF	99984	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	71.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	68.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	77.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	3	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations VCB New	3	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations VCB New	3	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations	7	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	2183	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2183	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations This Read Vac	4	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	4	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AF	189	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AL	189	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Switching Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps A Ø	72.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps B Ø	68.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps C Ø	87.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps A Ø	63.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps B Ø	70.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps C Ø	34.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	202	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	202	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	4	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	135.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	130.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	140.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	232	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	232	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Amps A Ø	320.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Amps B Ø	311.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Amps C Ø	340.0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Operations A Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Unknown Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Switching Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Operations This Read Vac	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Operations Counter AL	179	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Operations Counter AF	179	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Maintenance Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Operations Ground	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Operations C Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	Fault Operations B Ø	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Readings	9 Month Operations	0	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BK002038	BreakerVacuum	834-2	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	450	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	150238	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	150238	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	11199.60	kw
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	74	°C
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	42	°C
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Reading	.6222	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	1173.12	kw
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.3666	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Present	32	°C
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Max	54	°C
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	597776	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	597776	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	264	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.3	amps
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BCH001580	Charger	834-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.6	VDC
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	BAT001634	Battery	834-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments	SPR removed	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 11:42	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	7	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	7	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	522	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	7025	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	7016	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.1090	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	34	°C
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	46	°C
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	784.80	kw
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments	above breaker 4427 on line side, insulator has a large chip in skirt on bottom of line side disconnec	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 11:32	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	129.60	kw
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0540	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AL	170	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AF	170	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Maintenance Operations	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations Ground	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Unknown Operations	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations C Ø	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations B Ø	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Switching Operations	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations A Ø	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	9 Month Operations	1	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps C Ø	5.0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps B Ø	2.0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps A Ø	2.0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations This Read Vac	0	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	348319	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	160228	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	311776	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 12:50	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2337	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	184	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	96235	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	128024	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 11:05	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	100.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	140.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	135.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	188	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps B Ø	100.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Operations Counter	347	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AL	340	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AF	340	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Maintenance Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Unknown Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Switching Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations This Read Vac	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps A Ø	58.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps B Ø	59.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps C Ø	60.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations B Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Unknown Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Switching Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations This Read Vac	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AL	332	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AF	332	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Maintenance Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations Ground	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations B Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps C Ø	40.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps B Ø	39.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps A Ø	38.0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	9 Month Operations	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.6	volts
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Regulator As Left Counter	74176	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.1	volts
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Regulator As Left Counter	72071	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70436	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	119.3	volts
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5320	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	851.20	kw
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	85.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	All Connections OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Found Counter	39540	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Left Counter	39542	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Operations Since Last Insp	185	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Min Tap Position	6L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Reading	.8544	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	LTC Totalizer Reading	8202.24	kw
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.9	VDC
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 10:46	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 14:32	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Unknown Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Switching Operations	1	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations This Read Vac	1	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AL	239	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Maintenance Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AF	239	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	9 Month Operations	8	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	9 Month Operations VCB New	7	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps A Ø	570.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps B Ø	570.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps C Ø	590.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations Ground	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	9 Month Operations	7	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	9 Month Operations VCB New	7	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps A Ø	70.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps B Ø	110.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations B Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations Ground	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Maintenance Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AF	195	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AL	195	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations This Read Vac	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Switching Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Unknown Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps C Ø	60.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	9 Month Operations	6	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	9 Month Operations VCB New	6	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps A Ø	90.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps B Ø	100.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps C Ø	110.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations B Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations Ground	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Maintenance Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AF	188	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AL	188	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations This Read Vac	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Switching Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations A Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations B Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations C Ø	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations Ground	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Maintenance Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations Counter AF	208	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations Counter AL	208	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations This Read Vac	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Switching Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Unknown Operations	0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps C Ø	200.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps B Ø	200.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps A Ø	190.0	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations VCB New	7	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations	7	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	8814.40	kw
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	1.1018	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	710660	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	71860	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	674	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.6	VDC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 10:19	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Operations Counter	13	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Amps C Ø	34.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0169	RecloserElectronic	656-0466	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	1.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	31	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments	27.3/24.9	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	3.0	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	16995	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	17004	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	990	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	1161.60	kw
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.1210	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 9:57	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	162	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	162	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	22.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	26.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	23.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	51	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	51	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	80.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	85.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	20.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations VCB New	2	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	2	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	4	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	200.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	200.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	190.0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	99933	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	99933	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments	Drag hands not working	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	74263	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	74263	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	16L	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	16L	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	16R	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	233	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	LTCC000975	LTCControl	835-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.7590	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Present	44	°C
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Max	44	°C
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	7286.40	kw
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:46	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	379.80	kw
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6330	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	FE000899	Fence	762-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1290	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Regulator As Left Counter	1368	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.4020	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	5788.80	kw
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Regulator As Left Counter	1208	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Operations Counter AF	174	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Operations Counter AL	174	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Switching Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Unknown Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Amps C Ø	130.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Amps B Ø	120.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Amps A Ø	135.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	9 Month Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Maintenance Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Operations Counter	5	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC000145	RecloserElectronic	762-0589	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	244	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	245	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Operations Counter	9	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	General Comments		
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:38	Distribution	High Bridge Quarterly Inspection	RC901737	RecloserElectronic	762-0590	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	254	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	254	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	131.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	120.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	135.0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations C Ø	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations Ground	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	4	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations VCB New	4	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	252	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	252	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations This Read Vac	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BK000989	BreakerVacuum	812-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	587	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	93798	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	93798	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.3	VDC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 9:35	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AF	164	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AL	164	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations This Read Vac	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Switching Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps A Ø	7.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps B Ø	15.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps C Ø	8.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Maintenance Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations A Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	9 Month Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations Ground	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	9 Month Operations VCB New	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations B Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations C Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AF	208	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AL	208	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	9 Month Operations	2	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	9 Month Operations VCB New	2	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations Ground	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations C Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps A Ø	33.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps B Ø	37.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations B Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps C Ø	49.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Maintenance Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations This Read Vac	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Switching Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Unknown Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations A Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AL	190	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations This Read Vac	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Switching Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	9 Month Operations	1	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	9 Month Operations VCB New	1	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps A Ø	17.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps B Ø	19.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps C Ø	13.0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Unknown Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AF	190	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Maintenance Operations	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations A Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations C Ø	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations Ground	0	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12220	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9600	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11629	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2850	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2736.00	kw
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.5	VDC
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.5	VDC
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2023 8:58	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations Counter AF	161	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations Counter AL	161	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps C Ø	720.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps B Ø	700.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps A Ø	660.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	9 Month Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps B Phase V	37.65	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	9 Month Operations VCB New	40	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	9 Month Operations	46	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps C Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps B Ø	125.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps A Ø	130.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps A Phase V	37.65	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations This Read Vac	6	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations Counter AL	201	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations Counter AF	201	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations A Ø	3	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations B Ø	3	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	272	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	272	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C Ø	190.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B Ø	190.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A Ø	170.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations VCB New	5	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	5	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	654	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	654	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	130.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	130.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	115.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	190.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	210.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	210.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	815	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	815	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	12.55	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	12.55	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	215.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	200.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	195.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	683	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	683	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations This Read Vac	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	110.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	110.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C Ø	110.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	283	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	283	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	251	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	251	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	85.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	90.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	90.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations VCB New	12	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	12	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	200.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	200.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	215.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AL	360	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AF	360	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Switching Operations	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Operations This Read Vac	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Operations Counter AL	164	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Operations Counter AF	164	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Amps C Ø	480.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Amps B Ø	500.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Amps A Ø	470.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Readings	9 Month Operations	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	LTC Totalizer Reading	15720.00	kw
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	75	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Reading	.6550	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	70	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	435	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	70122	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	70122	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Operations Since Last Insp	679	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Current Tap Position	3L	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Found Counter	80272	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Left Counter	80272	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	70	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	21000.00	kw
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	75	°C
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	.8750	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	71430	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	11R	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64155	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments	AL 124.2	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments	AL 124.2	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67398	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4290	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	62	°C
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1029.60	kw
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments	high side bushings are in really bad shape	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1220	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	806	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.9	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.2	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.2	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	886	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	180	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.3	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.3	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.8	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	213	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	197	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	257	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	205	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.5	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.6	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.8	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	280	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments	fuses are in terrible shape	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 14:05	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments	AL 123.9	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	318561	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments	AL 123.8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	298442	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28696	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments	AL 124.5Vac	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1280.88	kw
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3558	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	335.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	361.67	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	553.68	kw
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	42	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4614	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	184	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	184	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	38.0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	41.0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	39.0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	0	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.7	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Operations Counter	263	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62339	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	265	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	24.5	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	29.5	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	28.0	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	326	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	206	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3312	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	3179.52	kw
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments		
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BAT001654	Battery	426-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	BCH001572	Charger	426-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments	temp gauge bad	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 13:58	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:54	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.2	VDC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BAT001664	Battery	671-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments	AF AL float range	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Time Delay	40	Seconds
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Left Counter	80945	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Found Counter	80937	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Operations Since Last Insp	659	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Reading	.3312	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Max	35	°C
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	LTC Totalizer Reading	3179.52	kw
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	2.83	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	216	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	216	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	1	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	1	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	2	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	57.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	59.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	61.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	158	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	158	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:50	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.7	VDC
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.5	VDC
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.1	VDC
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments	AF AL float range in cascade	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23927	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23020	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	drag hands stuck with indicator	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22507	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	2	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	1	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	300	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	300	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	1	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	86.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	86.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	83.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	243	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	83.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	92.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	98.0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	16.97	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	14.14	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	6	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	5	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations VCB New	5	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	31	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	15	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	85	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	85	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	26	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002044	BreakerVacuum	463-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	10.0	psi
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:42	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Amps C Ø	0.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Amps B Ø	0.0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	9 Month Operations	2	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	General Comments		
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Maintenance Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Operations Counter AF	194	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Operations Counter AL	194	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Switching Operations	0	
10/12/2023 15:18	Distribution	Reynolds Quarterly Inspection	BK002045	BreakerVacuum	463-BT1-2	VCB Readings	Unknown Operations	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	13L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76153	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	194021	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21697	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations Counter AL	112	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations Counter AF	112	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps C Ø	100.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps B Ø	100.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps A Ø	100.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	9 Month Operations	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2563.92	kw
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7122	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AL	102	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AF	102	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	9 Month Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps A Ø	80.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps B Ø	85.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps C Ø	70.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments	DETC needs to be changed to higher voltage	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations Counter AF	135	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations Counter AL	135	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps C Ø	55.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps B Ø	60.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps A Ø	75.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	9 Month Operations	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Operations Counter	24	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	9 Month Operations	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations Counter AF	109	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations Counter AL	109	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Unknown Operations	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	116	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations Counter AL	144	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations Counter AF	144	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps C Ø	220.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps B Ø	230.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps A Ø	240.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	9 Month Operations	1	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	9 Month Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AL	138	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AF	138	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Maintenance Operations	0	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AL	130	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AF	130	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps C Ø	130.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps B Ø	100.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps A Ø	130.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	9 Month Operations VCB New	6	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	9 Month Operations	6	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:30	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	9 Month Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AL	115	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AF	115	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps A Ø	30.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps B Ø	30.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps C Ø	30.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	9 Month Operations	2	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps A Ø	150.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps B Ø	130.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps C Ø	120.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AF	113	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AL	113	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps C Ø	270.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps B Ø	250.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps A Ø	280.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AF	116	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AL	116	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	9 Month Operations	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Left Counter	6356	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Operations Since Last Insp	407	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Found Counter	6356	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	LTC Totalizer Reading	12931.20	kw
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Reading	.5388	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	65	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	378808	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	378818	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	640	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.1570	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	753.60	kw
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Operations Since Last Insp	460	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Found Counter	7135	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Left Counter	7135	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	All Connections OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Reading	.4098	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	LTC Totalizer Reading	9835.20	kw
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	149431	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Regulator As Left Counter	826095	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	9 Month Operations	1	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	General Comments	open	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Maintenance Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AF	185	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AL	185	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Switching Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Unknown Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	211	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	211	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	100.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	80.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	81.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps A Ø	97.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps B Ø	91.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Unknown Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Switching Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations This Read Vac	10	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AL	196	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations C Ø	5	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AF	196	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Maintenance Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps C Ø	69.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	9 Month Operations	12	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps B Phase V	25.33	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps C Phase V	25.33	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations B Ø	5	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Maintenance Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AF	247	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AL	247	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Switching Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Unknown Operations	0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps A Ø	5.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	9 Month Operations	6	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	9 Month Operations VCB New	6	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps B Ø	12.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps C Ø	7.0	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	165388	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2924.64	kw
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	.4062	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:21	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5934	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	474.72	kw
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	457	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	28.4	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.8	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.3	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.5	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.6	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	487	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection and fiberglass is exposed on all xfmr fuse barrels including spare.	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 12:59	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	630	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	77639	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	77647	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.2400	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	1728.00	kw
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	58	°C
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	28.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	25.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	30.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	213	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	213	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	1	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	LTCC000979	LTCControl	574-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	867	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	2930	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	2924	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.7158	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	6871.68	kw
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	236	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	88.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	86.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	87.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	172	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	49.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	485	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	485	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	109.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	102.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	98.0	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	2	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 11:44	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	1	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	25.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	168	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	168	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	13.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	41.0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 11:47	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	176	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	176	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	79.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	92.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	64.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	192	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	192	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments	counter still showing 192 ops, so either the counter isnt working or it wasnt recorded correctly	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	100.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	100.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	65.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AF	109	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AL	109	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	9 Month Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps A Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Unknown Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Switching Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Operations Counter AL	213	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Operations Counter AF	213	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Maintenance Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	9 Month Operations	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Amps C Ø	48.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Amps B Ø	53.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Amps A Ø	45.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BK001815	BreakerVacuum	438-1713	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments	AL-124.1Vac	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Unknown Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Switching Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AL	99	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AF	99	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Maintenance Operations	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps C Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps B Ø	0.0	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	9 Month Operations	1	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps A Ø	0.0	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	5564	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	5560	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	897	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2565.12	kw
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.8016	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:22	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 13:28	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	140.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	180.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations VCB New	7	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	7	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	200.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	527	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	527	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	111	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	11	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	160.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	120.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations VCB New	11	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	180.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	111	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	9	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations VCB New	9	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	175.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	140.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	150.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	259	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	259	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations VCB New	14	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	14	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	60.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	30.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	30.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	483	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	483	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	100.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	120.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	100.0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations VCB New	14	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	14	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	431	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	431	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	548	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	3R	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	120076	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	120076	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	4950.00	kw
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.8250	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	676	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	7L	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	3R	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	1L	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	81990	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	81982	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	13686	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	13686	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	583	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	All Connections OK?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	LTCC000890	LTCControl	080-5	LTC Control Insp	VRR Time Delay	60	Seconds
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.2540	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	47	°C
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	2438.40	kw
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	5256.00	kw
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.6570	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	239	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	239	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	17.0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	2	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	21.0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	23.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BCH001562	Charger	808-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.4	VDC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	2	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps A Ø	102.0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps B Ø	94.0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps C Ø	95.0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations A Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations B Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations C Ø	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations Ground	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	242	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	242	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations This Read Vac	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	0	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 11:02	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 11:11	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Tank Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	PT Free of Leaks?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	355	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	355	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments	verified fault operations	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	27	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	27	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	301.87	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	301.87	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	165.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	170.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	180.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	54	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	183	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	183	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations This Read Vac	54	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	50.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	55.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	54.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	267	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	267	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	45.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	24.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	16.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	383	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	383	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	623	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	623	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	33	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations VCB New	33	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments	open with DNO card	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	0.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	416	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	416	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	170.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	180.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	190.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	129	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps B Ø	39.0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	51	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	65	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	2	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	623	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	623	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	188.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	190.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17651	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	390	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	390	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	89.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	118.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	110.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	487060	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Month Ops New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	100.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	84.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	90.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Month Ops New	2	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	2	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	135.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	150.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	136.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	48	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	48	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	435	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	130.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	120.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	148.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	78.26	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	78.26	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	7	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	7	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	435	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	23	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	14	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Month Ops New	9	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Month Ops New	5	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	5	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	108.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	110.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	120.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	625	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	625	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Month Ops New	1	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	1	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	76.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	79.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	82.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	52	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	52	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	577	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	577	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Month Ops New	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	530.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	560.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	540.0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122082	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2184	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	524.16	kw
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	85759	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	85759	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2R	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1054	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	20	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	20	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	20	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	50	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	Barbed wire is very rusty	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 10:13	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	42	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	110	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	43	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	110	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	41	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	98	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	90	°C
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.6	VDC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	26344	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	26344	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	9L	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	7R	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	1398	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	12397	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	574	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	12401	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.2754	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	58	°C
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	1321.92	kw
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 10:37	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	1	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	1	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	224	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	224	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments	8-5-23 B-G Inst Op	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	1	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	1.66	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	23.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	22.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	22.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	179	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	179	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	38.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	42.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	33.0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	2	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	148.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	150.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	148.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	1	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations VCB New	1	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations This Read Vac	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AL	71	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AF	71	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 9:53	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	8	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations VCB New	8	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	127	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	127	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	30.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	31.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	32.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	11	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations VCB New	5	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	116.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	121.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	81.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	81.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	3	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	6	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	113	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	113	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments	A and B phase TOC	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	3	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments	B phase IOC	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	125	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	3	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	125	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	6	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations VCB New	3	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	3	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	31.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	30.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	30.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	34.55	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	9 Month Operations VCB New	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps A Ø	40.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps B Ø	41.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps C Ø	41.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	9 Month Operations	4	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	4	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AF	120	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AL	120	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations This Read Vac	4	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	71	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	71.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	71.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	70.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	71	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BAT001667	Battery	082-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37365	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38028	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	40896	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	35	°C
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	35	°C
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments	Nitro prress gauge needs replacing or new face cover	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	320	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	43.0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments	Storm/Broke pole 9-23 w/15 ops	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99992	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99992	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	9 Months Operations OCB New	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-10-12 00:00:00.000000	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments	poison ok. Swept floor and removed bunches of cobwebs	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
10/12/2023 9:23	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	366	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	56852	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	56852	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC oil near the low mark.	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	145	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments	5 fuses blown	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations VCB New	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	14	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments	open	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	324	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	324	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	14	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	14	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	142	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations VCB New	1	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	142	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	1	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	°F
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.6	VDC
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments	AL float range	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63963	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	121.6	volts
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments	lower arm will not reset	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	53385	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	11R	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	74279	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	121.8	volts
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/25/2023 6:33	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1082.88	kw
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4512	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments	Pressure gauge does not work at all. temp gauge needs replacing	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	266	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.2	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	4.6	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.2	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	10.0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	10.0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	10.0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	2	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	0	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	163	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	163	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 9:05	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	164	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	164	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	89.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	88.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	90.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations VCB New	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	96	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	96	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	3	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations VCB New	3	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	479.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	458.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	517.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	240215	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	240215	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	12L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	3R	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	14L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1504	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	55	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1318	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	6R	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	77292	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	77292	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	60	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	145.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Present	60	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Max	75	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1697	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	35272	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	35272	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AL	66	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AF	66	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps C Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	9 Month Operations	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	9 Month Operations VCB New	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps A Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps B Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Vacuum Monitor Antenna Paint	NA	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Vacuum Monitor Self-Check OK?	na	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps A Ø	150.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps B Ø	145.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps C Ø	173.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations A Ø	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations B Ø	3	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	General Comments	AB IOC	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations Counter AF	110	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations Counter AL	110	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	9 Month Operations VCB New	11	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	9 Month Operations	18	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations This Read Vac	7	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations B Ø	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations A Ø	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Operations This Read Vac	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	9 Month Operations	6	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	9 Month Operations VCB New	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps A Ø	256.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	General Comments	AB IOC	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Operations Counter AF	81	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Operations Counter AL	81	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps B Ø	226.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps C Ø	248.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	58	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	58	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	524.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	528.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	505.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	113	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations This Read Vac	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	113	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments	AB IOC	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	216.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	190.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	193.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations VCB New	16	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	18	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations VCB New	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	215.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	270.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	225.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	126	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	126	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	166	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	166	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations	5	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations VCB New	5	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	89.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	72.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	86.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	142	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	142	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps C Ø	686.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps B Ø	620.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations Counter AL	75	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations Counter AF	75	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	9 Month Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps A Ø	616.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	9 Month Operations VCB New	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Amps C Ø	300.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations Counter AF	87	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations Counter AL	87	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Amps B Ø	290.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Amps A Ø	266.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	9 Month Operations VCB New	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	9 Month Operations	4	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations Counter AF	63	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations Counter AL	63	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps C Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps B Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps A Ø	0.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	9 Month Operations VCB New	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	9 Month Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations C Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations A Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Amps C Ø	260.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Amps B Ø	221.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Amps A Ø	235.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	9 Month Operations VCB New	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	9 Month Operations	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations Counter AF	72	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations Counter AL	72	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations This Read Vac	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations Ground	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	General Comments	A IOC	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Maintenance Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations Counter AF	77	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations Counter AL	77	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations B Ø	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations A Ø	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Amps C Ø	134.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Amps B Ø	140.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Amps A Ø	142.0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	9 Month Operations VCB New	2	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	9 Month Operations	3	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations This Read Vac	1	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Switching Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Unknown Operations	0	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	General Comments		
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2023 17:05	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	520	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	520	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	12	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations VCB New	12	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	60.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	95.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	65.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	25.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	30.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	50.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	510	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	510	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	50.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	40.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	45.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations VCB New	3	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	3	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	605	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	605	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	532	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	532	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	44	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations VCB New	44	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	40.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	30.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	45.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	255.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	260.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	245.0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	396	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	396	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	76619	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	76619	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	740	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	75	°C
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.5880	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	70	°C
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	14112.00	kw
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BCH001509	Charger	532-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.1	VDC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 7:26	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	165	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	165	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps C Ø	85.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps B Ø	100.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps A Ø	90.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations VCB New	13	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations	13	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	1	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	5.86	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations VCB New	7	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	8	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations This Read Vac	1	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	208	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	208	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	726	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	4R	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	15296	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	15296	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	25	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	45	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.4260	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	25	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	40	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	6134.40	kw
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	All Connections OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	11260.80	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	25	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	.7820	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	35	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	686	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	64298	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	64298	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations This Read SF6	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AL	75	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Operations Counter AF	75	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Num Operations Last 9 Months	2	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	Fault Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Readings	9 Month Operations GCB New	2	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	65	°F
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	General Comments	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	3	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	70	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	70	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations This Read SF6	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	9 Month Operations GCB New	3	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	65	°F
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	90.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	100.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	85.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	209	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	209	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations VCB New	7	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	7	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AL	173	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	173	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	85.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	90.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	90.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	19	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations VCB New	19	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations VCB New	7	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	193	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	193	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	7	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	168	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	168	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	140.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	130.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	140.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations VCB New	8	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	8	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	9	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations VCB New	9	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	70.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	65.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	75.0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	201	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	201	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations This Read Vac	0	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	127.6	VDC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/12/2023 7:15	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Switching Operations	3	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations This Read Vac	3	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AL	116	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AF	116	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations C Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	3	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	300.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	300.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	300.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	5	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations This Read Vac	5	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	366	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	366	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps C Ø	80.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps B Ø	85.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps A Ø	100.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations	9	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Switching Operations	3	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations This Read Vac	3	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AL	428	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AF	428	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	60.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	70.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	60.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations VCB New	6	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	9	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	7	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations This Read Vac	7	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	444	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	444	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	110.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	110.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	115.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	11	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Amps A Ø	30.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	9 Month Operations VCB New	9	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	9 Month Operations	15	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Amps B Ø	32.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Amps C Ø	31.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Operations C Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Fault Operations Ground	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Operations Counter AF	201	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Operations Counter AL	201	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Operations This Read Vac	6	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Switching Operations	6	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BK001612	BreakerVacuum	582-0161	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	5	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations This Read Vac	5	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	340	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	340	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	155.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	9	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	90.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	150.0	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	97074	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	97074	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	6L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	13L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	260	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	All Connections OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	LTCC000972	LTCControl	582-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	61	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.3438	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	48	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	6188.40	kw
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	62	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10101	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9925	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11549	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1084.80	kw
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Oil Temp Max	51	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Oil Temp Present	44	°C
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3390	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.6	VDC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.6	VDC
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments	Signs need to be updated	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 16:14	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Regulator As Left Counter	138397	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77822	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Regulator As Left Counter	471053	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	15098	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	15098	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	6L	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	3L	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	510	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	11L	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Present	35	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	LTC Totalizer Reading	15609.60	kw
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Max	60	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Present	30	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Max	70	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Reading	1.0840	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Maintenance Operations	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	9 Month Operations	1	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps A Ø	0.0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps B Ø	0.0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps C Ø	1.0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps B Phase V	1.75	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations B Ø	1	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations Counter AF	177	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations Counter AL	177	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations This Read Vac	1	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Switching Operations	0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5964	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	477.12	kw
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps A Ø	6.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps B Ø	9.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps C Ø	6.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	224	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	224	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations This Read Vac	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AF	177	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AL	177	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations This Read Vac	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Switching Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations VCB New	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps A Ø	315.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps B Ø	335.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps C Ø	300.0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations This Read Vac	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	208	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	208	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps C Ø	70.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	90.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	95.0	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 15:23	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	225.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	250.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	235.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	225	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	225	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations This Read Vac	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps A Ø	85.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps B Ø	95.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps C Ø	95.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Switching Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations This Read Vac	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AL	226	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AF	226	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AF	220	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AL	220	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations	2	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations VCB New	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps A Ø	10.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps B Ø	20.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Switching Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations This Read Vac	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps C Ø	10.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	3	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	145.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	155.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	145.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AF	174	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AL	174	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations This Read Vac	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Switching Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations	3	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps A Ø	0.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps B Ø	0.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps C Ø	0.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Switching Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations This Read Vac	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Maintenance Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AL	192	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AF	192	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	5	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	257	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	257	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations	6	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	50.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	1	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations This Read Vac	6	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	50.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	50.0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	All Connections OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Time Delay	330	Seconds
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	721	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	47897	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	7L	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	47897	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	0	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	30	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	65	°C
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments	METER REMOVED	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 15:21	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations This Read Vac	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	207	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	207	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	7	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations VCB New	7	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	25.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	20.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	25.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	7	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations VCB New	7	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	120.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	85.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	85.0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations This Read Vac	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	211	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	211	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	60722	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments	WILL NOT RAISE OR LOWER IN AUTO OR MANUAL	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	119.0	volts
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54727	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61149	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1087.56	kw
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9063	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Left Counter	267928	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Found Counter	267928	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Operations Since Last Insp	715	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.7000	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	20	°C
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	40	°C
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	6720.00	kw
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 14:53	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	9 Month Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Maintenance Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations Counter AF	180	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations Counter AL	180	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations This Read Vac	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Switching Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Unknown Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps A Ø	155.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations Ground	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations C Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations B Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations A Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps B Ø	130.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps C Ø	150.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	387	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	147.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	175.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations A Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations B Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations C Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	142.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations This Read Vac	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	387	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Maintenance Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations Ground	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations This Read Vac	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations	2	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	281	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations C Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations B Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations A Ø	0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	281	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps A Ø	71.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps C Ø	75.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps B Ø	95.0	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	258	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	85399	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	85397	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Output Voltage Level	125.6	VAC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	4674.00	kw
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	52	°C
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	.7790	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 14:30	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	432	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	General Comments	LTC has no station supply open per mine inspector	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	29	°C
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	46	°C
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments	VARMIT GUARD ON LOW SIDE HAS BLOWN OFF	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 14:00	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations This Read Vac	3	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	232	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	232	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	3	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	83.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	81.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	75.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	1.66	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	1.66	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	1.66	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	1	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	1	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	3	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	57.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	57.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	3160	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	3167	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	1R	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	7R	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	648	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	1.3308	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	42	°C
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	42	°C
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	3193.92	kw
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.4	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.6	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.5	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.3	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.3	VDC
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	13.000	millivolts
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Unknown Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Switching Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations This Read Vac	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AL	172	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AF	172	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Maintenance Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	9 Month Operations	4	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations Ground	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations C Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations B Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations A Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps C Ø	101.0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps A Ø	98.0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps B Ø	93.0	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/11/2023 13:24	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Maintenance Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations Ground	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations C Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations B Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations A Ø	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AF	184	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AL	184	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations This Read Vac	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Switching Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Unknown Operations	0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps C Ø	95.0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps B Ø	102.0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps A Ø	95.0	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	9 Month Operations VCB New	3	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	9 Month Operations	3	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	17267	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	17274	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	893	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	1746.00	kw
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Max	57	°C
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Present	36	°C
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.2910	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 13:18	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	41	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	71	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	236.0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	233.0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	235.0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	41	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments	Installed SEL. 41 OPS	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	41	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	71	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	115.0	VAC
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	115.0	VAC
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	115.7	VAC
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	1L	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	258	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	77789	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	11R	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	5R	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	77781	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	262668	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	262660	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	958	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	1744.32	kw
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	45	°C
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	30	°C
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.5451	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	1895.04	kw
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Max	48	°C
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	.5922	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 12:36	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations B Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	225	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	131.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	130.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	137.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	2	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	225	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations This Read Vac	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	84.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	80.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	367	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	367	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations This Read Vac	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	77.0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	2	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BCH001557	Charger	842-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 12:28	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	8	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations VCB New	8	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	11.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	6.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	5.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	180	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	180	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	12	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7460	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44398	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45448	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7360	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1766.40	kw
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 12:20	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.2036	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	53	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	977.28	kw
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	19	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	90	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 11:37	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	4	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	120.0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	125.0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	207	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations This Read Vac	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	130.0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	207	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	281	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	281	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	55.0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	40.0	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations VCB New	1	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	1	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	44568	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	190297	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.4	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.7	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	128.4	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87617	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	390.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	410.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	400.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	3	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	4	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	3	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	11	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	11	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	11	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations VCB New	11	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	5.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	5.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	5.0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	7R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	2R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	133647	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	133646	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	7L	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	847	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5304.96	kw
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	56	°C
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5526	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	58	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	72	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	50	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	38	°C
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.3	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	714	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	8R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	2R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	42913	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	42908	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 10:44	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	37	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	47	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	34	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	60	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	113.8	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	113.7	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	113.6	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	279791	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	279796	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	2R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	9R	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	672	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	49	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	62	°C
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	9 Month Operations GCB New	2	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	2	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	55	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	55	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Unknown Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	66	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	58	°F
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Unknown Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Switching Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations This Read SF6	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AL	86	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AF	86	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Num Operations Last 9 Months	1	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Maintenance Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Fault Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	9 Month Operations GCB New	1	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	64	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Ambient Temperature	58	°F
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	9 Month Operations GCB New	1	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	1	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	74	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	74	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	58	°F
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	65	psi
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments	Poison already out	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments	Bad Washout under 2nd gate, and several weeds in Sub	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 10:39	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	9 Month Operations VCB New	4	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	9 Month Operations	4	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps A Ø	0.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps B Ø	0.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps C Ø	0.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations A Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations B Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations C Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations Ground	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Unknown Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Switching Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations This Read Vac	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Maintenance Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AF	184	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AL	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations A Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps B Ø	35.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps A Ø	30.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps C Ø	35.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations B Ø	1	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations C Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Unknown Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations Ground	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	9 Month Operations	8	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	9 Month Operations VCB New	6	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Switching Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations This Read Vac	2	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AL	228	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AF	228	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Maintenance Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	60.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations VCB New	2	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	2	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	60.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	60.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	228	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	228	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations	6	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations VCB New	5	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps A Ø	80.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps B Ø	75.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps C Ø	62.0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	1	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	168	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	168	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	1	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	0	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	204094	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33745	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	214148	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4560.00	kw
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4750	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.0	VDC
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 9:40	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	191717	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	191717	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	619	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1495	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	99252	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	99252	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	57641	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	57641	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	7L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2212	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	282159	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	282159	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2096	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	120174	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2R	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	12R	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1088	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	120174	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	206874	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	206874	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1279	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	64.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	137	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	41.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Operations Since Last Insp	626	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Max Tap Position	2R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Left Counter	30205	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	30203	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	2731.20	kw
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	30	°C
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	.5690	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 8:30	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	37	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	5	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	5	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	138	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	138	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	41	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	41	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	429	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	429	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	94	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	94	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	381.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	388.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	305.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	1	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Month Ops New	1	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	245.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	255.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	251.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	338	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	338	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	176	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	176	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations This Read Vac	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations VCB New	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
10/11/2023 8:58	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	4	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	4	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	6	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	6	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	30.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	35.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	30.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	171	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	171	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	12	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Month Ops New	12	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Month Ops New	23	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	23	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	341	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	341	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	65.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	70.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	60.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	6	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Month Ops New	6	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	75.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	60.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	80.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	165	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	165	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	125	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	125	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	275.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	280.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	310.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	200.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	200.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	200.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	12	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Month Ops New	12	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	915	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	915	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	50.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	65.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	50.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	985	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	985	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Month Ops New	2	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	200.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	225.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	200.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	863	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	863	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	0.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	67	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	67	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	687	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	687	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	375.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	390.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	365.0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Month Ops New	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	55	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	62	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	47	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	52	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	56	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	60	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	69	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	75	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/11/2023 8:50	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	9.0	amps
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	315	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	315	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations VCB New	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	203.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	218.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	210.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	235	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	235	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	305	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	305	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	52.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	64.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	54.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations VCB New	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	285.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	293.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	289.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	332	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	332	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	7	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations VCB New	7	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	367	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	367	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	91.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	83.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	107.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations VCB New	3	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	3	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	133	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	133	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps C Ø	650.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	675.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	650.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	1	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	140.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	162.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	144.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	1241	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	1241	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Month Ops New	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	724	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	724	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Month Ops New	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	32.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	30.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	30.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	1000	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	1000	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	165.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	150.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	178.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Month Ops New	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	2	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	80.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	705	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	705	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	70.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	75.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Month Ops New	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	415.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	410.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Month Ops New	1	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	587	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	587	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	430.0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2023 8:57	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations This Read Vac	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	280	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	280	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	90.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	110.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	70.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	14.16	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	20.99	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	14.64	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations VCB New	2	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	2	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations This Read Vac	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	194	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	194	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	1	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	113.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	117.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	81.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	.49	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AF	356	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AL	356	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations This Read Vac	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	20.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	20.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	20.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Switching Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Unknown Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	54.65	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	60.2	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	52.28	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	474	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	474	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations This Read Vac	2	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations VCB New	5	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Maintenance Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	7	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations VCB New	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	43.99	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	43.99	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	43.99	%
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps A Ø	0.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps B Ø	0.0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps C Ø	0.0	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6228	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1992.96	kw
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	335.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	352.50	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2540	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	50.80	kw
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments	ok	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.8	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BAT001686	Battery	782-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments	AF AL float voltage range	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Regulator As Left Counter	170457	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Regulator As Left Counter	72220	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 1 Load Test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 1 Post-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 2 Load Test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 2 Post-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 2 Pre-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 3 Load Test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 3 Post-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 1 Pre-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.2	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2022-05-10 00:00:00.000000	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	133.7	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	2.8	AMPS
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 4 Pre-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 4 Post-test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 4 Load Test Volts	0.0	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery 3 Pre-test Volts	0.0	VDC
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	102328	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9R	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	100052	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	100052	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3050	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	°C
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	66	°C
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	41.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	874	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	874	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	15	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	17.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	42.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	44.72	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments	Counter doesn't work.	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	15	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	77.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	62.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	61.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	44.72	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	44.72	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	8	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	951	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	951	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	FE000900	Fence	782-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 14:11	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1329	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1329	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	153.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	147.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	139.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	21.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	23.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	905	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	905	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	4	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	44.72	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	16.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	7	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	243.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	261.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	267.0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	540	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	540	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments	Counter doesnt work.	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	145493	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	145505	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	8L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	6L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	11L	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	407	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Time Delay	60	Seconds
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Operation Checked?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	All Connections OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	1261.44	kw
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Max	35	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Present	35	°C
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Reading	.1314	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	9 Month Operations GCB New	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Fault Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Maintenance Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Num Operations Last 9 Months	1	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Operations Counter AF	95	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Operations Counter AL	95	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Operations This Read SF6	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Switching Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Readings	Unknown Operations	0	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	SF6 Pressure	68	psi
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	General Comments	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	BK001718	BreakerSF6	032-618	GCB Patrol Inspection	Ambient Temperature	50	°F
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments	ok	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments	Structure could use upgraded wildlife protection.	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments	ok	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 13:56	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BCH001609	Charger	453-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BAT001663	Battery	453-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.4	VDC
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Regulator As Left Counter	192966	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27835	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32286	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments	Meter has been removed.	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	107	°C
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	300.00	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments	One fan is not working.	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	324.17	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.8	VDC
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.5	VDC
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BAT001668	Battery	498-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments	AF and AL float voltage ranges in cascade wont accept 55	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2023 7:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50681	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27296	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44675	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8676	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2082.24	kw
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	25.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	25.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	20.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations This Read Vac	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	195	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	195	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	1	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	6	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	34.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	24.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	31.0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	1.31	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	6.57	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	1	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	5	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	0	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	235	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	236	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations This Read Vac	6	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 12:39	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	180	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	88.0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	82.0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	101.0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations VCB New	2	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	2	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations This Read Vac	0	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	180	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments	Bus needs wildlife protection.	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments	ok	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments	Washout is developing in back left corner and along back fence of lot.	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 13:03	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000294	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000293	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000292	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000257	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	875	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	Bushing oil on A and C phases turning red	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil temp is cracked	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil temp is cracked	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.4	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Cracked Glass	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Cracked Glass	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 12:11	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BCH001571	Charger	616-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	55.1	VDC
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	BAT001653	Battery	616-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70662	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	120268	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	119500	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments	No meter in station.	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	60	°C
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations	1	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations This Read Vac	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	141	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	141	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps C Ø	180.0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps B Ø	156.0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps A Ø	136.0	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments	Xfmr fuse barrels and spare are starting to fray and deteriorate	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments	ok	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 11:48	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1484	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	427339	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	427339	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	149	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	77413	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	77413	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	220.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	60.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	6.41	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	220.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Month Ops New	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	5.34	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34896	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34896	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Month Ops New	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Months Operations	23	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps A Ø	208.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AF	579	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AL	579	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations This Read AM	23	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Switching Operations	23	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps C Ø	220.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps B Ø	195.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	17	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	16	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	16	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	825	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	825	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	1	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Heater not working needes replaced.	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	327	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	327	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	150.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	140.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	150.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Month Ops New	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	1	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations	35	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations VCB New	7	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps A Ø	137.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps B Ø	142.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps C Ø	132.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AF	503	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AL	503	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Switching Operations	28	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations This Read Vac	28	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations	25	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations VCB New	3	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps A Ø	57.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps B Ø	60.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AF	181	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AL	181	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations This Read Vac	22	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Switching Operations	22	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps C Ø	67.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	120.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	100.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1303	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1303	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	180.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Month Ops New	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	9 Month Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Amps A Ø	495.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Amps B Ø	440.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Amps C Ø	504.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Operations Counter AL	13	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Operations Counter AF	13	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Operations Counter AF	28	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Operations Counter AL	28	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Amps A Ø	92.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	9 Month Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Amps B Ø	66.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Amps C Ø	77.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Operations This Read Vac	3	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Operations Counter AL	24	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Operations Counter AF	24	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	General Comments	A B C IOC	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Operations C Ø	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Operations B Ø	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Operations A Ø	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Amps C Ø	132.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Amps B Ø	116.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Amps A Ø	144.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Readings	9 Month Operations	3	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Switching Operations	20	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations This Read Vac	20	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AL	276	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AF	276	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps C Ø	253.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps B Ø	264.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps A Ø	256.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations	20	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	9 Month Operations VCB New	3	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Operations Counter AL	22	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Operations Counter AF	22	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Amps A Ø	59.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Amps B Ø	66.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Readings	Amps C Ø	69.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	411	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	411	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	40.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	40.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Month Ops New	2	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	2	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	40.0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.14	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	9.61	%
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations	37	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations VCB New	29	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps A Ø	433.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps B Ø	442.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps C Ø	446.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Switching Operations	8	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations This Read Vac	8	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AL	213	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AF	213	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	9 Month Operations VCB New	9	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Operations This Read Vac	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Operations Counter AL	60	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Operations Counter AF	60	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	General Comments	A phase TOC	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	9 Month Operations	10	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Amps A Ø	59.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Amps B Ø	56.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Amps C Ø	63.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Operations A Ø	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	9 Month Operations	3	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	9 Month Operations VCB New	3	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Amps A Ø	169.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Amps B Ø	162.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Amps C Ø	184.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Operations Counter AL	40	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Operations Counter AF	40	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps C Ø	222.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps B Ø	241.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps A Ø	234.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	9 Month Operations	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations Counter AL	50	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations Counter AF	50	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	9 Month Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations Counter AL	32	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations Counter AF	32	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	23	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations VCB New	7	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	52.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	50.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	48.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	198.25	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	198.25	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	8	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	8	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	16	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	277	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	277	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments	A and B phase IOC	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Operations This Read Vac	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Operations Counter AL	57	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Operations Counter AF	57	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	General Comments	B phase TOC	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Operations B Ø	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	9 Month Operations	5	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	9 Month Operations VCB New	4	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Amps A Ø	52.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Amps B Ø	54.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Amps C Ø	50.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Adjusted Amps B Phase V	24.78	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Operations Counter AL	35	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Operations Counter AF	35	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Amps C Ø	53.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Amps B Ø	54.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Amps A Ø	53.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Readings	9 Month Operations	1	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations Counter AF	54	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations Counter AL	54	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps C Ø	9.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	9 Month Operations	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps B Ø	16.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps A Ø	8.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps A Ø	80.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	9 Month Operations	2	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	9 Month Operations VCB New	2	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Maintenance Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations Counter AF	30	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps B Ø	82.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps C Ø	81.0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Unknown Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Switching Operations	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations Counter AL	30	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.7	amps
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	60	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments	x2 gauge seems high. It has the fans running in auto.	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments	T/C oil level low.	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	76053	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	12R	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	76053	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	879	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Oil level low.	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments	flange on tank has small drip, T/C oil level low.	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:09	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.4	psi
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR nitro bottle empty	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	95	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	100	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	100	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1891	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	109311	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	109311	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4874	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2339.52	kw
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments	gauge will reset with two magnets	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.4	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	35.0	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	41.0	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	527	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	X0079	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	13.6	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.7	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	892	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments	hole that needs to be filled by the front gate from AMI pole installation	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Regulator As Left Counter	647	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000167	Regulator	827-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	General Comments		
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Regulator As Left Counter	1508	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000168	Regulator	827-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	General Comments	door installation was on RG167 but shown on the wrong order	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Regulator As Left Counter	647	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:45	Distribution	St Charles KU Quarterly Inspection	RG000169	Regulator	827-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Found Counter	52843	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Left Counter	52843	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	5	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Month Ops New	6	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Months Operations	6	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AF	454	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AL	454	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations This Read AM	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Switching Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps A Ø	97.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps B Ø	88.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps C Ø	107.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	General Comments	VC entered worng on last inspection	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps A Ø	4.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps B Ø	1.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Months Operations	26	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Switching Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations This Read AM	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps C Ø	3.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Month Ops New	26	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AF	862	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AL	862	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Month Ops New	24	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Switching Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations This Read AM	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AL	818	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AF	818	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Maintenance Operations	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations Ground	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Months Operations	24	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps C Ø	133.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps B Ø	132.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps A Ø	125.0	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	95	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.6	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	40613	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments	unable to reset gauge, needs new	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	235.92	kw
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	155.00	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	90	°C
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0983	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	170.00	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 9:44	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1676	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	32602	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	32602	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	27	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	76	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	27	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	79	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	27	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	79	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	26	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Found Counter	129443	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Left Counter	129443	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	12R	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1521	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Max	100	°C
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	7.5	amps
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 11:02	Distribution	Collins Quarterly Inspection	BCH001599	Charger	CO-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Negative DC Ground	69.0	VDC
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.8	VDC
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.4	VDC
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.6	VDC
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.6	VDC
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	65	°C
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	65	°C
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	35	°C
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	107.50	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments	new bottle installed	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations This Read Vac	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	0.0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	0.0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	0.0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	3	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations VCB New	3	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	198	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	198	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	0	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments	no fuses used at this station,has hi and low side breaker	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 8:28	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001982	BreakerVacuum	HC-1433	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002201	BreakerVacuum	HC-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002202	BreakerVacuum	HC-1291	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002203	BreakerVacuum	HC-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002204	BreakerVacuum	HC-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002205	BreakerVacuum	HC-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Patrol Inspection	General Comments		
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:57	Distribution	Hillcrest Quarterly Inspection	BK002207	BreakerVacuum	HC-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations Ground	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Switching Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	50.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations This Read AM	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AL	413	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AF	413	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	35.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	40.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Maintenance Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Month Ops New	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	90.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	40.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Month Ops New	1	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	9	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	691	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	50.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	691	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	8	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	8	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	463	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	50.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	463	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	9	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	9	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	40.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	40.0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	9	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Month Ops New	0	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	339136	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	339136	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	755	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	36	°C
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	48	°C
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	10.84	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	27.7	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	15.66	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Month Ops New	3	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	18.07	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	31.32	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	1	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	22.89	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Month Ops New	7	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	38.54	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	19.27	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	53	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	31.32	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Month Ops New	0	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Month Ops New	1	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Month Ops New	11	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BAT001649	Battery	HL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/11/2023 5:47	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Unknown Operations	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Switching Operations	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations This Read Vac	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AL	197	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AF	197	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Maintenance Operations	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps C Ø	70.0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps A Ø	65.0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps B Ø	65.0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations C Ø	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations B Ø	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations A Ø	0	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	279247	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	279247	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	601	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.2090	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	668.80	kw
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2023 14:59	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	All Connections OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Fault Pressure Relay Info	0	Model

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	FCP Block Raise AF	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	FCP Block Raise AL	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	FCP Lower AF	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	FCP Lower AL	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Megger Trans Annun Neg.	0.0	Meg Ohms
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Megger Trans Annun Pos.	0.0	Meg Ohms
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	Reset Tap Drag Hands	Reset	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Bandwidth AF	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Bandwidth AL	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Base Voltage AF	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Base Voltage AL	0.0	VAC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Counter AF	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Counter AL	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR R Compensation AF	0	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR R Compensation AL	0	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR Time Delay	0	Seconds
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR X Compensation AF	0	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PS000007	PortableSubstation	P-Yard	Portable Sub LTC Control Inspection	VRR X Compensation AL	0	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC001005	LTCControl	P-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC001005	LTCControl	P-TRANS 5	LTC Control Insp	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC001005	LTCControl	P-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC001005	LTCControl	P-TRANS 5	LTC Control Insp	All Connections OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Found Counter	85046	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Left Counter	85046	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Current Tap Position	5	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Max Tap Position	5	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Min Tap Position	5	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	557	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Max	60	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Present	60	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	All Connections OK?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Left Counter	303733	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Found Counter	303733	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AL	97	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AF	97	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	9 Month Operations	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	152.50	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0184	NonLTC	P-Yard	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	1	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	60.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	20.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	20.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	15	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	15	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	1	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	60.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	60.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	60.0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	1	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations VCB New	3	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	5	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	2	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	0	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	1	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	2	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	2	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	37180	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	37192	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	185	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	2020.80	kw
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.4210	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	33	°C
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	52	°C
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arrestors blown on cir 414 and one blown on cir 414, center insulator on transfer buss has chipped skirt	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2023 15:17	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.9	VDC
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.3	VDC
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	13.0	VDC
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12581	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12472	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	2472.00	kw
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	.5150	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	579	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	6L	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	9L	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	287956	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	287944	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10962	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	18	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	15.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	13	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	82.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	52.0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	54	°C
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	31	°C
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	11	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	11	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	62.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	72.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	68.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	11	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations VCB New	2	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	52.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	56.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	45.0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	8.81	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	17.61	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	3	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	6	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments	3-AG, 4-BG, 2-BG T ops	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	9	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	264	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	264	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments	ok	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2023 12:29	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	General Comments	needs nitro	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AL	163	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AF	163	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps A Ø	5.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps B Ø	4.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps C Ø	5.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AF	136	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AL	136	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations	7	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations VCB New	7	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps A Ø	75.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps B Ø	80.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps C Ø	55.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AL	117	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AF	117	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	9 Month Operations	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AF	47	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AL	47	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Switching Operations	0	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments	large tree growing over top of fence to the right of the station. tree in customer yard.	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments	small wash out to the left of entrance gate washing gravel into customer yard	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 13:21	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	General Comments	needs nitro	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations VCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AL	99970	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AF	99970	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations VCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Follow-up Action Required?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	General Comments	can't read VC numbers falling off	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AF	1178	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AL	1178	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AF	23	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AL	23	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AL	585	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AF	585	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations VCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AF	1146	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AL	1146	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001283	PowerFuse	P-1392 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001283	PowerFuse	P-1392 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AL	846	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps A Ø	23.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps B Ø	24.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps C Ø	25.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AF	846	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps A Ø	11.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps B Ø	10.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps C Ø	11.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations VCB New	3	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations	3	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AL	99955	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AF	99955	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps A Ø	94.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps B Ø	94.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps C Ø	95.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AF	682	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AL	682	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps A Ø	243.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps B Ø	249.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps C Ø	220.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AL	141	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AF	141	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations A Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations B Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations C Ø	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations Ground	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AF	748	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AL	748	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations This Read Vac	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	65577	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	12L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71719	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	13L	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	68615	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	297650	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	297660	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	1R	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	1R	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	3L	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	685	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.5040	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	56	°C
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	3628.80	kw
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments	open	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	88	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	33	°C
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	38	°C
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 11:50	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments	1-AB, 1-BC, 1-AB op	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	7	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	7	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations This Read Vac	3	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	10.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	15.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	17.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	3	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations VCB New	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	79.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	75.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	65.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	219	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	219	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	4	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	171	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	171	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments	1-BG T, 1-BG, 1-ABG T, 1-AG op	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	2	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	2	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	5.66	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	11.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	10.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	8.0	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations VCB New	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	5	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AF	995	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AL	995	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AF	646	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AL	646	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Unknown Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AL	1173	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AF	1173	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	9 Months Operations OCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AL	1187	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AF	1187	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	9 Months Operations OCB New	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments	No spare fuses. Whole distribution bay needs additional wildlife protection.	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AL	1172	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AF	1172	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AL	829	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AF	829	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	Light	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	Vegetation is growing on outside of fence in front ride side of station and along right side of station. SPR no longerin service.	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AL	1507	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AF	1507	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	General Comments	BREAKERS OPEN	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AF	1945	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AL	1945	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations This Read Oil	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Switching Operations	1	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments	ok	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2023 11:24	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AL	6240	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AF	6240	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AF	1260	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AL	1260	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AL	1064	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AF	1064	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AF	5495	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AL	5495	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Switching Operations	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations This Read Oil	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AL	3258	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AF	3258	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AF	1846	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AL	1846	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AL	725	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AF	725	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	9 Months Operations OCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AF	133	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AL	133	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Number of Ops last 9 Months	10	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AF	132	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AL	132	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	9 Months Operations OCB New	10	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AL	1332	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AF	1332	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	9 Months Operations OCB New	12	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Number of Ops last 9 Months	12	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps B Ø	25.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps A Ø	25.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	9 Months Operations OCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AF	852	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps C Ø	25.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AL	852	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AF	1180	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AL	1180	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	9 Months Operations OCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AF	1346	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AL	1346	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	9 Months Operations OCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AL	3860	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AF	3860	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Number of Ops last 9 Months	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	9 Months Operations OCB New	3	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps A Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps B Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AL	1177	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AF	1177	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Number of Ops last 9 Months	3	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps C Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	9 Months Operations OCB New	2	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps A Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps B Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps C Ø	50.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AF	1199	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AL	1199	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	9 Months Operations OCB New	4	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Number of Ops last 9 Months	4	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AF	1641	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AL	1641	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Switching Operations	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations This Read Oil	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AL	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	9 Months Operations OCB New	4	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Number of Ops last 9 Months	10	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AF	2090	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	9 Months Operations OCB New	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps A Ø	13.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps B Ø	13.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps C Ø	13.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Number of Ops last 9 Months	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AF	1291	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AL	1291	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Number of Ops last 9 Months	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AF	1716	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AL	1716	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	9 Months Operations OCB New	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	9 Months Operations OCB New	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps A Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps B Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Number of Ops last 9 Months	1	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AF	917	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AL	917	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AL	2001	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AF	2001	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Number of Ops last 9 Months	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps C Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps B Ø	9.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps A Ø	9.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	9 Months Operations OCB New	6	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	9 Months Operations OCB New	9	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps A Ø	5.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AL	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AF	1504	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Number of Ops last 9 Months	9	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps C Ø	0.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps B Ø	5.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Fault Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps C Ø	101.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps B Ø	102.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps A Ø	98.0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	9 Months Operations OCB New	4	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Maintenance Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Number of Ops last 9 Months	4	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AF	1103	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Switching Operations	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations This Read Oil	0	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AL	1103	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001284	PowerFuse	P-14KV GEN 13 AUX POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001284	PowerFuse	P-14KV GEN 13 AUX POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	General Comments	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Grounds in Place?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Foundation Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Leaks	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Overall Condition	Good	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	All Connections OK?	y	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Ground Lights	None	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	General Comments		
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
10/10/2023 10:21	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations Counter AF	170	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations Counter AL	170	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps C Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	9 Month Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps A Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps B Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations Counter AL	1183	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations Counter AF	183	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps C Ø	200.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps B Ø	215.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps A Ø	210.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	9 Month Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	10	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	214	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	214	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	5	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	66.26	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	66.26	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	90.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	90.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	100.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations VCB New	5	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	15	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	4	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	4	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	56.60	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	56.60	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	247	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	247	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	8	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations VCB New	5	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	13	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	200.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	185.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	190.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	181	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	181	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	350.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	390.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	390.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations VCB New	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	210.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	150.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	323	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	323	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	200.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	260	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	9	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	260	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	39.76	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	39.76	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	39.76	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	75.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	70.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	60.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations VCB New	3	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	12	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	345	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	345	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	140.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	100.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	120.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	38	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	58.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	54.0	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	44	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	103400	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54688	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	270135	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2124.00	kw
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2950	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 22:30	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Unknown Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Switching Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations This Read AM	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations Ground	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Month Ops New	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Months Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AL	536	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AF	536	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Maintenance Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps C Ø	75.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps B Ø	25.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps A Ø	25.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	26072	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	26072	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	17	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	667	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	47	°C
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations This Read AM	15	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	511	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AF	511	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Maintenance Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations Ground	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations C Ø	5	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations B Ø	5	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations A Ø	5	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	47.73	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	47.73	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	47.73	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps C Ø	160.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps B Ø	210.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps A Ø	170.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	9 Months Operations	17	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	9 Month Ops New	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Maintenance Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AF	295	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AL	295	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations This Read AM	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Switching Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Unknown Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations Ground	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps C Ø	75.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps B Ø	75.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps A Ø	50.0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	9 Months Operations	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	9 Month Ops New	0	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	EI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	EI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/6/2023 14:15	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments	2 Yard lights out need bucket truck to change them.	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	23	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	6.0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	53	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	64000	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	64009	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	651	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	131	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	131	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	712.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	729.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	678.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	.0660	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	36	°C
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	633.60	kw
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	35668	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	35668	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5R	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	1L	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1155	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 13:51	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	958	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	33914	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	33914	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	76	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	70	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	70	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	196.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	186.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	195.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments	AB IOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	6	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	6	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	67.08	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	211.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	234.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	218.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	14	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	229	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	229	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	12	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments	ABC Phase TOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	212	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	11	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations VCB New	5	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	142.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	147.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	138.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	212	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	6	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	264	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	264	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments	BC Phase IOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	153.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	146.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	117.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations VCB New	5	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	7	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	3	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations VCB New	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	25.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	26.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	23.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments	A Phase IOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	181	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	181	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	167	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	167	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	General Comments	A Phase IOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations A Ø	13	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps A Phase V	145.34	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Amps C Ø	95.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Amps B Ø	112.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Amps A Ø	125.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	9 Month Operations	15	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations Counter AF	43	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations Counter AL	43	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations This Read Vac	13	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Operations Counter AL	12	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Operations Counter AF	12	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps C Ø	93.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps B Ø	97.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps A Ø	91.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Operations This Read Vac	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	9 Month Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Switching Operations	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations This Read Vac	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations Counter AL	32	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations Counter AF	32	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Amps C Ø	190.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Amps B Ø	184.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Amps A Ø	180.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	9 Month Operations VCB New	9	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	9 Month Operations	10	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps B Ø	188.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps C Ø	191.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations Counter AF	24	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations Counter AL	24	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations This Read Vac	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps A Ø	194.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	9 Month Operations VCB New	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	9 Month Operations	11	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	9 Month Operations	18	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	9 Month Operations VCB New	16	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps A Ø	112.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps B Ø	125.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps C Ø	119.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations B Ø	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations C Ø	1	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	General Comments	BC Phase IOC	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations Counter AF	47	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations Counter AL	47	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations This Read Vac	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps A Ø	692.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps B Ø	683.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps C Ø	678.0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations Counter AF	15	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations Counter AL	15	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Switching Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Unknown Operations	0	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	9 Month Operations	2	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	General Comments		
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:58	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	612.00	kw
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.2550	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	157178	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	153544	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	3L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	164836	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	43	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	39	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	corner of foundation next to house is crumbling, multiple insulators are crakced and chipped in the steel	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 13:04	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	1	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations This Read Vac	1	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	203	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	203	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	1.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	5.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	1.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	3	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	28.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	223	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	223	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	4	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	4	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	29.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	30.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations VCB New	11	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	15	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	46	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments	27.6/22.8	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	633	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	16899	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	16889	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	597.60	kw
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.0830	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	42	°C
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BCH001555	Charger	841-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments	House needs new heater.	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments		
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire rusty and top rail is rusty back left corner posts need replaaced, multiple bayonets loose on fence	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments	Boom is exposed and needs covered in some spots.	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 12:17	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations This Read Vac	2	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	84	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	84	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C Ø	0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B Ø	1	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A Ø	1	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	3.95	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C Ø	74.0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B Ø	36.0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	4	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A Ø	56.0	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	57027	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	57027	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	533	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	All Connections OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	LTCC000984	LTCControl	583-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	.2850	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	42	°C
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	42	°C
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	2052.00	kw
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 11:10	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	463	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	93	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	83	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	1R	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	15L	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Present	33	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1148	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Max	44	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	68.88	kw
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments	Multiple insulators have chipped and broken skirts above transformers	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 10:43	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	14	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	20	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	16	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	462	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	21.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.0	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	578	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Regulator As Left Counter	197502	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77896	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	360234	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	353.52	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	49	°C
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2946	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 10:28	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	106	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	106	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	123	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	123	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	78.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	59.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	190	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	95.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	190	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	150.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	141.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	145.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	1	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	370	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	1	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	370	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	85.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	85.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	90.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	212	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	212	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	61	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	61	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Month Ops New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	304.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	299.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	271.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	260	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	260	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	97.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	124.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	110.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	2	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations VCB New	2	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	191	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	191	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	92.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	83.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	79.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	200	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	200	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	99.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	89.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	90.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations VCB New	8	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	8	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	199	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	199	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	280.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	295.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	276.0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7R	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252991	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252991	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments	LTC VC not working	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Needs nitro added	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	91207	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	91207	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16L	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1847	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments		
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2023 9:58	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	All Connections OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	80	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	13L	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	1L	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	7L	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	131982	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	131982	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	14400.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	65	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	50	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	75	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	.8000	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	214	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	214	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	490.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	480.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	500.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations VCB New	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	872	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	12L	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	7L	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	164416	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	164416	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	18576.00	kw
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	75	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Present	50	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	1.0320	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	90	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Present	50	°C
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	9 Month Operations	-1	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Operations Counter AL	365	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Operations Counter AF	365	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	9 Month Operations VCB New	-1	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Amps A Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Amps B Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Amps C Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002021	BreakerVacuum	060-608	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Amps B Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Amps C Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Maintenance Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Operations Counter AF	1623	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Operations Counter AL	1623	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Operations This Read Vac	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Switching Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Unknown Operations	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Operations Ground	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Operations C Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Operations B Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Operations A Ø	0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	Amps A Ø	0.0	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	9 Month Operations VCB New	-1	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Readings	9 Month Operations	-1	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	General Comments		
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2023 7:19	Distribution	Lansdowne Quarterly Inspection	BK002022	BreakerVacuum	060-618	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	72	°F
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	2	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	73	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	73	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations This Read SF6	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	9 Month Operations GCB New	2	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	1063	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	4R	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	2L	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	30254	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	30254	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	33	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	33	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	55	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	.4310	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	32	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	10344.00	kw
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	210	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	210	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations VCB New	12	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	12	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations VCB New	8	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	8	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	300.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	300.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	290.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	179	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	179	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	231	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	23	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	110.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	100.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	100.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations VCB New	7	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	7	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	236	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	236	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	60.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	60.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	85.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations VCB New	8	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	8	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	211	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations VCB New	12	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	160.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	160.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	150.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	211	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Operations B Ø	2	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	9 Month Operations	2	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Amps A Ø	140.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Amps B Ø	130.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Amps C Ø	140.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Fault Adjusted Amps B Phase V	24.06	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Operations Counter AF	109	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Operations Counter AL	109	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Operations This Read Vac	2	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps A Ø	420	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps B Ø	420	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps C Ø	400	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AF	183	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AL	183	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002314	BreakerVacuum	853-0135	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	9 Month Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Amps C Ø	170.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Amps B Ø	150.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Amps A Ø	155.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Operations Counter AF	105	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Operations Counter AL	105	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	227	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	227	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps C Ø	150	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps B Ø	240	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps A Ø	240	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	6.98	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	4.49	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	4.99	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	388	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	80	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	95	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	100	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	4721.99	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	4721.99	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	4721.99	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	387	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	387	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations This Read Vac	388	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	387	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002313	BreakerVacuum	853-0134	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Switching Operations	1	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Operations This Read Vac	11	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Operations Counter AL	148	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Operations Counter AF	148	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Maintenance Operations	10	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	9 Month Operations VCB New	47	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	9 Month Operations	58	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Amps C Ø	350.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Amps B Ø	310.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Amps A Ø	330.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	199	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	199	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps C Ø	60	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps B Ø	60	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps A Ø	60	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty C Ph V	1.82	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty B Ph V	6.37	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty A Ph V	4.55	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	9 Month Operations	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps A Ø	650	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps B Ø	684	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	204	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	204	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps C Ø	597	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Present	60	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Max	85	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.579	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	13896	kw
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	All Connections OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	LTC Output Voltage Level	125	VAC
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	57416	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	57416	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	3R	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	764	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002042	BreakerVacuum	853-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	891	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	7R	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	55075	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	55075	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AL	870	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AF	870	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations	2	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty A Ph V	3.64	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty B Ph V	3.64	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps A Ø	400	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps B Ø	400	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps C Ø	370	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Switching Operations	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations This Read Vac	2	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AL	670	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AF	670	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Maintenance Operations	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	744	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	744	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AL	0	VAC
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	All Connections OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Output Voltage Level	0	VAC
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AF	0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Present	20	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Max	35	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Reading	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Max	40	°C
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	LTC Totalizer Reading	0	kw
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	14005	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	14005	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	12798.00	kw
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	.7110	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Present	45	°C
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations This Read SF6	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	53	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	53	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	9 Month Operations GCB New	1	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 15:07	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	72	°F
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	130.4	VDC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Amps C Ø	70.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Operations A Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Operations B Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Operations C Ø	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Fault Operations Ground	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	General Comments		
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Unknown Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Switching Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Operations This Read Vac	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Amps B Ø	40.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Amps A Ø	55.0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	9 Month Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Operations Counter AL	118	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Operations Counter AF	118	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Readings	Maintenance Operations	0	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 15:11	Distribution	Lakeshore Quarterly Inspection	BK002312	BreakerVacuum	853-0133	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps A Ø	160	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps B Ø	140	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps C Ø	130	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	9 Month Operations	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AF	163	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AL	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Switching Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Switching Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AL	146	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AF	146	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	9 Month Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps B Ø	130	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps C Ø	130	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Switching Operations	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations This Read Vac	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps A Ø	125	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AL	185	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	9 Month Operations	8	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	9 Month Operations VCB New	7	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty A Ph V	2.87	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty B Ph V	2.87	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty C Ph V	2.87	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AF	185	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	520	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	520	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	20	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	20	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	20	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	3.83	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	2	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	515	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	515	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	200	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	180	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	180	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	3.83	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	2	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	294	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	294	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	4	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations VCB New	4	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	6.69	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	3.82	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	150	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps B Ø	170	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps C Ø	160	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	420	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	435	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	425	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	1	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	198	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	198	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	205380	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	205380	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	707	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	155	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.448	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	3584	kw
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	123	VAC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	760	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	10L	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	49030	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	49030	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	12240	kw
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.85	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	55	°C
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	430.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	455.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	515.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	194	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	194	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0	VDC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	BCH001569	Charger	898-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	4	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	425	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	425	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	2	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	190.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	140.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	150.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations VCB New	25	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	29	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	229	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	229	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 14:38	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	405.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	460.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	450.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	1	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	176	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	176	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	160.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	145.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	155.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	241	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	241	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	2 fans not working, repaced capacitors both working now. Needs nitrgen	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments	Bus needs additional wildlife protection.	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments	AL 124.2V	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	124319	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	General Comments	AL 124.1V	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Regulator As Left Counter	118205	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments	AL 124.2V	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	135828	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.3	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	27.7	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.1	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	314	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	41	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	400.32	kw
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3336	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments	needs new gauges	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	46	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	needs new gauges	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments	ok	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 13:54	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.600	millivolts
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Unknown Operations	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Switching Operations	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Operations This Read SF6	13	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Operations Counter AL	74	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Operations Counter AF	74	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Num Operations Last 9 Months	24	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Maintenance Operations	13	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	General Comments	Counter reading was wrong from BRKR 608 Change out	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Fault Operations	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Amps C Ø	0.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Amps B Ø	0.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	Amps A Ø	0.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Readings	9 Month Operations GCB New	11	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.6	VDC
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	65.5	VDC
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	68.5	VDC
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Ambient Temperature	67	°F
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	SF6 Pressure Pole 3	68	psi
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	SF6 Pressure Pole 2	68	psi
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	SF6 Pressure Pole 1	68	psi
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	General Comments	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK001076	BreakerSF6	113-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	8	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations VCB New	3	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Amps A Ø	20.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Amps B Ø	18.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Amps C Ø	20.0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	2.12	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	1	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments	1-BC, 3-Replaced 608 BRKR	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	251	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	251	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations This Read Vac	5	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	4	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments	Could not reset liquid temp	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	92	°C
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	45	°C
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	38	°C
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments	insulation board flaking all over batteries and house	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:24	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Regulator As Left Counter	34238	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	General Comments	AL 124V	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37843	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments	AL 124.1V	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22521	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments	AL 124.5V	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3477.60	kw
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	41	°C
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4830	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	369	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	369	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations This Read Vac	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	70.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	80.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	55.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations VCB New	3	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	3	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations This Read Vac	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	7	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	7	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	2	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	15.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	55.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	25.0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.9	VDC
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments	ok	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 12:48	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51855	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38304	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Regulator As Left Counter	59714	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6312	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2272.32	kw
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	159.17	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	194	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	194	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	0.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	0.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	0.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Maintenance Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations Ground	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations C Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations B Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations A Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps C Ø	31.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps B Ø	28.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps A Ø	30.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	9 Month Operations VCB New	5	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	9 Month Operations	5	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Unknown Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AF	202	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AL	202	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations This Read Vac	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Switching Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Amps A Ø	43.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	9 Month Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Amps B Ø	53.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Amps C Ø	40.0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Operations A Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Operations B Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Unknown Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Switching Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Operations This Read Vac	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Operations Counter AL	184	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Operations Counter AF	184	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Maintenance Operations	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Operations C Ø	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Fault Operations Ground	0	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Readings	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001808	BreakerVacuum	764-1529	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 12:20	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	65325	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	219.90	kw
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	63	°C
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	46	°C
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7330	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.4	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Operations Counter	43	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	302	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 11:57	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	1	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	131.0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	99.0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	141.0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	184	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	184	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	419461	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	419461	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	443	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	11R	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	102016	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35296	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	11R	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	0	°C
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	0	°C
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33050	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	2	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Month Ops New	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	50.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Unknown Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	50.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	60.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Switching Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AF	547	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AL	547	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Month Ops New	1	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	1	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	130.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	125.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	120.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	17	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	17	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1597.44	kw
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4992	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments	outside fuse barrel in terrible condition	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	595	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	595	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	30.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	30.0	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Month Ops New	4	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	4	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	30.0	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.7	VDC
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.5	VDC
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.1	VDC
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.1	VDC
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	67	°F
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	Light	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments	Washout at fence towards Recloser side . vines growing on XO ground/Fence fabric	
10/5/2023 11:38	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	75	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 11:38	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments	ok	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	30592	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	30592	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1082	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations Counter AL	73	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations Counter AF	73	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Maintenance Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps C Ø	139.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps B Ø	120.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps A Ø	103.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	9 Month Operations	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	9 Month Operations	7	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	9 Month Operations VCB New	7	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps A Ø	188.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps B Ø	196.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps C Ø	192.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations Counter AL	66	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations Counter AF	66	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Maintenance Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps C Ø	109.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Maintenance Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations Counter AF	77	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps B Ø	99.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps A Ø	96.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	9 Month Operations	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations Counter AL	77	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps A Ø	167.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps B Ø	170.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps C Ø	167.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations B Ø	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	9 Month Operations VCB New	11	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	9 Month Operations	13	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	General Comments	B phase IOC	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Maintenance Operations	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations Counter AF	82	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations Counter AL	82	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations This Read Vac	2	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	9 Month Operations	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps C Ø	598.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps B Ø	570.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps A Ø	540.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations Counter AF	48	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations Counter AL	48	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Amps A Ø	0.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Amps B Ø	0.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	9 Month Operations	21	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Maintenance Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Operations Counter AF	42	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Operations Counter AL	42	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Unknown Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Switching Operations	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	9 Month Operations VCB New	21	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Readings	Amps C Ø	0.0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	BK002182	BreakerVacuum	DX-1224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LTCC001008	LTCControl	DX-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LTCC001008	LTCControl	DX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LTCC001008	LTCControl	DX-TRANS 1	LTC Control Insp	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LTCC001008	LTCControl	DX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.3	VDC
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BAT001658	Battery	437-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	4.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	2.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	2.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations VCB New	4	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	4	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations This Read Vac	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	212	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	212	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations This Read Vac	3	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps C Ø	17.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps B Ø	11.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps A Ø	9.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations VCB New	10	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	13	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps B Phase V	3.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations A Ø	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations B Ø	3	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations C Ø	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations Ground	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments	3 B 51 ops	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	201	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	201	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	General Comments	AL 123.6V	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Max Tap Position	11R	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Regulator As Left Counter	3173	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000232	Regulator	437-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	General Comments	AL 124.1V	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2996	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000231	Regulator	437-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Regulator As Left Counter	3118	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	General Comments	AL 124.5V	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	RG000230	Regulator	437-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments	ltc counter not working	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	7457	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	7457	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Oil Temp Max	46	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Oil Temp Present	37	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	3768.0000	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	4521600.00	kw
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000295	NonLTC	437-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	120.00	
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	85	°C
10/5/2023 14:12	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Operations Counter AL	96	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Operations Counter AF	96	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	Oil Temp Present	37	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	Oil Temp Max	46	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000296	NonLTC	437-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Operations Counter AF	86	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Operations Counter AL	86	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Unknown Operations	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	Oil Temp Present	34	°C
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	TX000297	NonLTC	437-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Operations Counter AL	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Operations Counter AF	101	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Operations Ground	0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Operations Counter AL	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Operations Counter AF	76	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Operations Counter AF	106	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Operations Counter AL	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Amps A Ø	0.0	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments	ok	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 10:53	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Amps B Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Operations Counter AL	121	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Operations Counter AF	121	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Operation Checked?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Time Delay	0	Seconds
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	2	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	22	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	22	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments	A,C ioc	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	150.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	150.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	100.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	6	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	279	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	279	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	300.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	330.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	300.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	200.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	240.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	280.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	386	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	386	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	2	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	4	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	99994	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	99994	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments	A,B ioc	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	2	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	44.72	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	220.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	100.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	200.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	9	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	240.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	106	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	240.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	240.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	106	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	600.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	600.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	600.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99785	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99785	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	775.0	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	371	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	371	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	140.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	140.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	100.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations VCB New	5	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	5	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	200.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	220.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	220.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AF	363	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AL	363	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	3	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations VCB New	3	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	140.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	160.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	130.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations VCB New	14	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	14	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	399	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	399	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	30	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	30	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	105.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	95.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	75.0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	52568	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	52568	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	1R	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	5R	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	6L	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	504	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	131	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Left Counter	3036	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Found Counter	3036	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	All Connections OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	9468.00	kw
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.5260	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	70	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Present	60	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Present	50	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	0	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	.6640	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	9561.60	kw
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	2.22	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	46.0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	47.0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	37.0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	2	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	1	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments	1-CAG	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	253	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	253	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	1	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	0	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	940	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	8R	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	2R	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	71994	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	71994	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments		
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments		
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Fault Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps C Ø	54.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps B Ø	55.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps A Ø	52.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AF	121	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AL	121	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Switching Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 3	92	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 2	92	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 1	92	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Ambient Temperature	80	°F
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments	Winding temp max arm not working	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	56	°C
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	56	°C
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	0	°C
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	60	°C
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps A Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps C Ø	0.0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Fault Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Maintenance Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AF	195	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AL	195	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Unknown Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Switching Operations	0	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 10:14	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.6	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 3	90	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 2	91	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 1	91	psi
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Ambient Temperature	80	°F
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 14:26	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	15.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	34.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	18.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	2	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	186	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	186	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	2	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	28.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	28.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	43.0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	223	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	223	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6236	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	General Comments	AL 123.9V	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Max Tap Position	13R	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000210	Regulator	770-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6329	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000208	Regulator	770-1 A	Regulator Patrol Inspection	General Comments	AL 123.9V	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	General Comments	AL 124V	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6121	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	RG000207	Regulator	770-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Winding Temp Present	36	°C
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Winding Temp Max	54	°C
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3108	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1491.84	kw
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Min Tap Position	1L	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Max Tap Position	16R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	General Comments	AL 124.3Vac	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Current Tap Position	4R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Regulator As Left Counter	29378	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.3	VDC
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BAT001607	Battery	770-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Max Tap Position	16R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Min Tap Position	4R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Current Tap Position	10R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	181280	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	BCH001574	Charger	770-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	80939	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	4R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments	AL 124Vac	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	16R	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	1L	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=15 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	2	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	General Comments	ok	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	FE000896	Fence	770-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 9:41	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments	chipped high side bushing	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	323.64	kw
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Max	65	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5394	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	204	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C Ø	9.5	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.6	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.1	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	236	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments	Entrance Rd needs gravel or clear path down to sub. Drive no longer visible due to grass overgrowth.	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 9:36	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	NEW	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=18 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	NEW	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	3	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=15 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	NEW	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=11 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	11	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	34	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	11	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	11	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	23	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	NEW BKR	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=17 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	NEW BKR=31 NEEDS NEW INFO	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	31	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	31	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	31	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	31	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	31	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	NEW	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	488168	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments	AL-123.9 Vac	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	411.84	kw
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6864	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Unreadable	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Bad gauges	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 8:38	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.7	VDC
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	38338	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments	AL 124.4V	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments	AL 124.2V	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	39069	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38554	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments	AL 124.2V	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	108	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments	1 AG op	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	0.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	12.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	7.55	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	32.0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	300	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	7	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	300	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	1	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations VCB New	6	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6552	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	48	°C
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2358.72	kw
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments	ok	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	A small washout is developing close to back right corner of station.	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 8:33	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	360.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	385.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	350.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	168	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	168	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	203	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	203	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	203	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	203	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	130.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	80.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	130.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations VCB New	3	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	3	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AL	233	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AF	233	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	310.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	290.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	305.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations VCB New	5	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	5	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations	14	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations VCB New	14	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps A Ø	40.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps B Ø	60.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps C Ø	440.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	218	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	218	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	202	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	202	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	165.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	175.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	140.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps C Ø	100.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps B Ø	110.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps A Ø	90.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations VCB New	5	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations	5	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AL	214	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Operations Counter AF	214	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	165	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	165	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	420.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	440.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	440.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations This Read Vac	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	214	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	214	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	105.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	105.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	95.0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations VCB New	15	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	15	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	548	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	12751	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	12751	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	All Connections OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000983	LTCControl	509-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments	55	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Max	70	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Reading	.4794	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Present	42	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	LTC Totalizer Reading	11505.60	kw
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Present	42	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	216766	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	216766	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	1224	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Present	45	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	65	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.5330	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	12792.00	kw
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 2	65	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	70	°F
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	9 Month Operations GCB New	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Fault Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Num Operations Last 9 Months	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AF	83	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AL	83	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations This Read SF6	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Unknown Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Switching Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations This Read SF6	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AL	115	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AF	115	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Num Operations Last 9 Months	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Maintenance Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Fault Operations	0	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	9 Month Operations GCB New	1	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	70	°F
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.9	amps
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.2	VDC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 7:39	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	10.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	10.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	10.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	2	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations This Read Vac	8	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	159	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	159	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	6	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	9	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	2	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations This Read Vac	13	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	273	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	273	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	11	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	120.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	120.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	120.0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	14	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	34664	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	34664	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	135	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	All Connections OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000978	LTCControl	413-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	3265.92	kw
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.3402	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT001629	Battery	413-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH001577	Charger	413-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments	no spill kit , SPR not in use	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/4/2023 16:24	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps A Ø	57.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	14	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	4	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations VCB New	4	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	336	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	336	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	40.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	60.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	30.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	4	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations VCB New	4	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	60.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	60.0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	19	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	19	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	All Connections OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	1986	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	1986	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	250	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	5587.20	kw
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	1.1640	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BAT001631	Battery	587-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	BCH001579	Charger	587-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/4/2023 15:37	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Bearings lubricated?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	All Connections OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Ground Connections Intact?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Rosettes Clean and Lubed?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000037	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Vacuum and Clean Breaker?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Vacuum and Clean Breaker?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Rosettes Clean and Lubed?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Ground Connections Intact?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Bearings lubricated?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	All Connections OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	GND000045	BreakerGroundDevice	516-Offline Distribution	Breaker Ground Device Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AF	100	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AL	100	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AF	81	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AL	81	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations Counter AL	195	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations Counter AF	195	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	9 Month Operations	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps A Ø	15	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps B Ø	15	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps C Ø	20	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Operations Counter AF	100	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Operations Counter AL	100	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps C Ø	205	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps B Ø	200	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps A Ø	200	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	9 Month Operations	2	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty B Ph V	.27	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations Counter AL	108	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations Counter AF	108	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps C Ø	60	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps B Ø	60	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps A Ø	60	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations Counter AF	98	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations Counter AL	98	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Amps C Ø	90	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Amps B Ø	80	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Amps A Ø	80	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Operations Counter AF	112	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Operations Counter AL	112	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps A Ø	40	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps B Ø	40	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps C Ø	40	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations Counter AF	32	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations Counter AL	32	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	9 Month Operations	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Amps A Ø	360	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Amps B Ø	365	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Amps C Ø	375	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Operations Counter AF	243	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Operations Counter AL	243	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations Counter AL	210	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations Counter AF	210	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	9 Month Operations	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Operations Counter AL	109	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Operations Counter AF	109	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Amps C Ø	100	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Amps B Ø	95	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Amps A Ø	95	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001555	BreakerVacuum	516-1105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Amps A Ø	60	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Amps B Ø	60	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Amps C Ø	60	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Operations Counter AF	117	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Readings	Operations Counter AL	117	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001554	BreakerVacuum	516-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	9 Month Operations	3	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	9 Month Operations VCB New	3	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty B Ph V	.73	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps A Ø	145	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps B Ø	165	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps C Ø	165	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations Counter AL	130	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations Counter AF	130	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	9 Month Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Operations Counter AL	106	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Operations Counter AF	106	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Amps A Ø	75	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Amps B Ø	70	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Amps C Ø	80	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001552	BreakerVacuum	516-0029	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations Counter AF	127	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations Counter AL	127	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps B Ø	20	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps A Ø	20	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	9 Month Operations	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps C Ø	20	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	9 Month Operations	2	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps A Ø	320	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps B Ø	330	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps C Ø	340	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations Ground	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations C Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations Counter AF	229	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations Counter AL	223	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations B Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations A Ø	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations This Read Vac	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	All Connections OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Operations Since Last Insp	407	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC As Left Counter	6462	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC As Found Counter	6462	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	LTC Totalizer Reading	8150.4	kw
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Totalizer Meter Reading	.3396	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X1 Winding Temp Present	47	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Oil Temp Present	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X3 Winding Temp Present	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	LTC Output Voltage Level	123	VAC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCC000881	LTCControl	516-2	LTC Control Insp	All Connections OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Max Tap Position	3R	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Current Tap Position	1L	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Min Tap Position	5L	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Operations Since Last Insp	494	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC As Left Counter	2627	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC As Found Counter	6727	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X1 Winding Temp Present	47	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Totalizer Meter Reading	.3456	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Oil Temp Present	46	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Oil Temp Max	51	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	LTC Totalizer Reading	8294.4	kw
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X2 Winding Temp Present	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X3 Winding Temp Present	48	°C
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Fault Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Num Operations Last 9 Months	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	9 Month Operations GCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations Counter AF	111	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations Counter AL	111	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations This Read SF6	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	SF6 Pressure	65	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	General Comments	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Ambient Temperature	85	°F
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations This Read SF6	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Switching Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Unknown Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	9 Month Operations GCB New	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Fault Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Maintenance Operations	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Num Operations Last 9 Months	1	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations Counter AF	182	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations Counter AL	0	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Ambient Temperature	85	°F
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	SF6 Pressure	65	psi
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	General Comments	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129	VDC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.1	amps
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	41.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	67	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	87	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72858	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments	counter entered wrong last quarter	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments		
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/4/2023 15:22	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments	counter entered wrong last quarter	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	78580	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	214276	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8598	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2063.52	kw
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments	there is not a spill kit	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	PF001352	PowerFuse	627-1F	Disconnect Powerfuse Inspection	General Comments	good	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	PF001352	PowerFuse	627-1F	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 14:54	Distribution	Shakertown Quarterly Inspection	PF001352	PowerFuse	627-1F	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	2	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Switching Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	321.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	339.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	317.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations This Read Vac	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AL	42	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AF	42	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Maintenance Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations A Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations B Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations C Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations Ground	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	1.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	2.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	4.0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	227	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	227	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations This Read Vac	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	0	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	415	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	184737	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	184737	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	All Connections OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	6806.40	kw
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.7090	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.3	VDC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
10/4/2023 13:50	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	53.16	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	49.17	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	50.5	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Month Ops New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	27.91	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	26.58	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	15.95	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Month Ops New	4	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	37.21	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	35.88	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Month Ops New	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	23.92	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	2.66	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	37.21	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	17.28	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	22.59	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Month Ops New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Month Ops New	5	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	13.29	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Readings	9 Month Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Readings	9 Month Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Readings	9 Month Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	9 Month Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Operations This Read Vac	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	9 Month Operations VCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Readings	9 Month Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	9 Month Operations GCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Num Operations Last 9 Months	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations This Read SF6	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations This Read SF6	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	9 Month Operations GCB New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Month Ops New	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001878	BreakerVacuum	CF-1208	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001877	BreakerVacuum	CF-1207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001880	BreakerVacuum	CF-1210	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001879	BreakerVacuum	CF-1209	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001882	BreakerVacuum	CF-BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001876	BreakerVacuum	CF-1206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	General Comments	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	General Comments	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Foundation Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Grounds in Place?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/5/2023 11:26	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	53.0	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	30	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37382	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	92927	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	35948	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3600	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1728.00	kw
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 13:12	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	9 Month Operations	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps A Ø	24.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps B Ø	8.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Switching Operations	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps C Ø	16.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations Counter AF	217	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations Counter AL	217	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations This Read Vac	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	71	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	-29437	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	16	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Left Counter	6769	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Found Counter	6769	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	General Comments	VC numbers falling off need to be replaced	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	60	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	45	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	310519	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	310519	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1507	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps A Ø	329.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps B Ø	333.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps C Ø	330.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	9 Month Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	General Comments	1 animal gurad has fell off the bushing	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AF	391	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AL	391	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Switching Operations	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations This Read Vac	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AL	335	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AF	335	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps C Ø	226.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps B Ø	220.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps A Ø	222.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	9 Month Operations	3	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AF	355	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AL	355	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations This Read Vac	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps C Ø	132.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps B Ø	139.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps A Ø	140.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AL	366	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AF	366	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps C Ø	106.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps B Ø	114.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps A Ø	109.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AF	412	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AL	412	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations This Read Vac	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LTCC001009	LTCControl	GR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LTCC001009	LTCControl	GR-TRANS 2	LTC Control Insp	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LTCC001009	LTCControl	GR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LTCC001009	LTCControl	GR-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	9 Months Operations OCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Fault Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AF	2777	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AL	2777	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations This Read Oil	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	107212	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	107212	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	378	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	50	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	75	°C
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AF	386	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AL	386	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Switching Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps A Ø	442.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps B Ø	447.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps C Ø	436.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations This Read Vac	3	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Switching Operations	3	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AL	394	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AF	394	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	9 Month Operations	9	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	9 Month Operations VCB New	6	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps A Ø	206.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps B Ø	216.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps C Ø	210.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	9 Month Operations	11	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	9 Month Operations VCB New	10	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps A Ø	105.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps B Ø	105.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Unknown Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Switching Operations	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations This Read Vac	1	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AL	378	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AF	378	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Maintenance Operations	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations Ground	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations C Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations B Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations A Ø	0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps C Ø	97.0	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	General Comments		
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 12:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	12	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations VCB New	12	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	3.86	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	175	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	200	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	200	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	102	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	262	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	125	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	150	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations VCB New	8	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	8	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	11.58	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	9.65	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	140	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty C Ph V	5.69	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps A Ø	100	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps B Ø	110	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps C Ø	100	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	9 Month Operations	7	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	9 Month Operations VCB New	7	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Unknown Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty A Ph V	5.69	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations Counter AL	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations Counter AF	185	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	573	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	200	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	225	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	200	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	5.79	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	5.79	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations VCB New	22	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	22	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Unknown Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations	14	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations VCB New	14	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AF	359	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AL	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	9 Month Operations	8	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	9 Month Operations VCB New	8	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps A Ø	135	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps B Ø	150	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps C Ø	130	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Switching Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations Counter AL	218	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations Counter AF	218	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Maintenance Operations	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	434176	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	434176	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1687	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	All Connections OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	2R	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	4L	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	32958	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	32958	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	434	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	7L	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Present	40	°C
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	50	°C
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	3952	kw
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.494	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	40.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	120.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	50.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Month Ops New	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	280	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	280	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	123	VAC
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	123	VAC
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	123	VAC
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	320	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	320	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	200.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	180.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	160.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Month Ops New	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	491	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	8L	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	3R	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	4L	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	19453	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	19453	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	50.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	90.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	80.0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	330	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	330	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	4	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Month Ops New	4	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	3856	kw
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	65	°C
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Present	40	°C
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	.482	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 10:18	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:08	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Amps A Ø	176.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Operations This Read Vac	1	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Operations Counter AL	21	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Operations Counter AF	21	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Maintenance Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Operations C Ø	1	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Amps C Ø	172.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	9 Month Operations	16	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	9 Month Operations VCB New	15	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Readings	Amps B Ø	182.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002177	BreakerVacuum	DA-1237	VCB Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Operations This Read Vac	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Operations Counter AL	52	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Operations Counter AF	52	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Amps C Ø	84.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Amps B Ø	80.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Amps A Ø	75.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	9 Month Operations	36	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	9 Month Operations VCB New	36	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002179	BreakerVacuum	DA-1239	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Operations Counter AF	49	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Operations Counter AL	49	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	9 Month Operations	21	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	9 Month Operations VCB New	21	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Amps A Ø	541.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Amps B Ø	523.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Amps C Ø	563.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002181	BreakerVacuum	DA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Operations This Read Vac	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Operations Counter AL	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Operations Counter AF	17	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Maintenance Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Operations Ground	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Operations C Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Operations B Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Amps C Ø	174.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Amps B Ø	123.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	9 Month Operations VCB New	1	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	9 Month Operations	1	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Readings	Amps A Ø	135.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002178	BreakerVacuum	DA-1238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Operations B Ø	1	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Operations C Ø	2	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Operations A Ø	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Amps C Ø	160.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Amps B Ø	164.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Maintenance Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Operations Counter AF	24	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Amps A Ø	168.0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	9 Month Operations VCB New	2	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	9 Month Operations	5	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Operations This Read Vac	3	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Switching Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Unknown Operations	0	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Readings	Operations Counter AL	24	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	90	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	95	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Left Counter	11509	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Found Counter	11509	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1255	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/10/2023 7:51	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	80269	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	80269	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	11R	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1442	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.6	amps
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BK002180	BreakerVacuum	DA-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	132.6	VDC
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2023 13:18	Distribution	Dahlia Quarterly Inspection	BAT001690	Battery	DA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations This Read Vac	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	179	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	179	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	202.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	172.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	182.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	160.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	160.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	180.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations This Read Vac	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	223	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	223	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	31.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	33.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	39.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations VCB New	1	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	1	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	10.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	10.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	10.0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	5	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	5	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations This Read Vac	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	88940	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	887	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	88940	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	122.9	VAC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	6166.80	kw
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	30	°C
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	50	°C
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.3426	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	°F
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments	no spill kit in the sub	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 15:27	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps B Ø	63.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps C Ø	61.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Maintenance Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AF	185	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AL	185	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations This Read Vac	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Switching Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	9 Month Operations VCB New	3	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps A Ø	49.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Maintenance Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AF	171	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AL	171	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations This Read Vac	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Switching Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Unknown Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps C Ø	28.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps B Ø	34.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps A Ø	30.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	9 Month Operations VCB New	3	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	9 Month Operations	3	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Maintenance Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AF	191	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations C Ø	1	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AL	191	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations B Ø	1	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Switching Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Unknown Operations	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps C Phase V	3.95	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps B Phase V	3.95	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps C Ø	146.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps B Ø	127.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps A Ø	153.0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	9 Month Operations	2	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	1173	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	62296	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	62296	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.5459	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	5240.64	kw
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	°F
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments	tree limbs need to be trimmed	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 14:17	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	302	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	302	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	120.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	110.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	120.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	2	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations VCB New	2	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	40.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	50.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	40.0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	231	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	231	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	123875	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments	counter entered wrong last qtr	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128875	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments	counter entered wrong last time	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	123551	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3764	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3613.44	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	°F
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 13:35	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	17841	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	17841	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	22	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	27	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	19	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	357	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Present	55	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Max	65	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Present	70	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Max	68	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	55	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	70	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	9 Month Operations	4	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	9 Month Operations VCB New	4	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AL	390	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AF	390	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps C Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps B Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps A Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	2	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	175	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	175	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations VCB New	13	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps A Ø	47.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps B Ø	46.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations	13	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AL	673	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AF	673	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps C Ø	44.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps A Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations VCB New	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps B Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps C Ø	0.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AF	878	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AL	87	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	255	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	255	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	268.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	268.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	276.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	60799	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	354	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	60799	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	255.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load Y2 Max	70	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load X2 Max	70	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Present	55	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Max	92	°C
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	3	psi
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1650.0	psi
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps B Ø	445.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps C Ø	454.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps A Ø	425.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	9 Month Operations VCB New	3	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	9 Month Operations	3	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AF	357	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AL	357	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AF	363	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AL	363	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps C Ø	26.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps B Ø	26.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps A Ø	27.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	9 Month Operations	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AF	383	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AL	383	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps C Ø	277.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps B Ø	269.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps A Ø	242.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	9 Month Operations	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Operations Counter AL	186	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Operations Counter AF	186	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Amps A Ø	69.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Amps B Ø	67.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Amps C Ø	67.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	9 Month Operations	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001034	BreakerVacuum	AS-1415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Tank Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Operations Counter AL	397	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	9 Month Operations	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	9 Month Operations VCB New	1	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Amps A Ø	84.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Amps B Ø	83.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Amps C Ø	81.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Operations Counter AF	397	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	BK001039	BreakerVacuum	AS-1414	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AF	175	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AL	175	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	9 Month Operations	2	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	9 Month Operations VCB New	2	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps A Ø	319.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps B Ø	311.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps C Ø	308.0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Switching Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Unknown Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Maintenance Operations	0	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	General Comments		
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
10/4/2023 10:10	Distribution	Ashbottom Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 12:35	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/3/2023 12:35	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 12:35	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Maintenance Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AF	185	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AL	185	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations This Read Vac	1	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Switching Operations	1	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Unknown Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps C Ø	20.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps B Ø	15.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps A Ø	15.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	9 Month Operations	4	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	9 Month Operations VCB New	3	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	9 Month Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps A Ø	32.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps B Ø	49.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps C Ø	45.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Unknown Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Switching Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AL	159	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AF	159	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Maintenance Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	228	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	228	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	152.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	155.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	160.0	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations VCB New	1	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	1	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	223978	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	223978	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	9R	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	963	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.5671	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	5444.16	kw
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.9	VDC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 11:53	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Found Counter	39983	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1651	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Left Counter	39983	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	354	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	354	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	247.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	244.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	249.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	1	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations VCB New	1	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	58.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	49.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	54.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	278	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	278	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	40.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	60.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	50.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	674	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	674	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	711	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	711	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	20.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	20.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	30.0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	58752	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	55866	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46365	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	All Connections OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Time Delay	30	Seconds
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54476	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	36271	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	56887	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	45	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	70	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8520	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	8179.20	kw
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2433.60	kw
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3380	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BCH001544	Charger	642-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.4	VDC
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.4	VDC
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	196	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	196	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations This Read Vac	2	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	2	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	75.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	56.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	33.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations VCB New	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	3	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations This Read Vac	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	156	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AF	156	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps C Ø	515.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps B Ø	500.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps A Ø	520.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations This Read Vac	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	161	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	161	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 11:05	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations	3	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps A Ø	38.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps B Ø	38.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps C Ø	30.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments	i o c	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	156	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	156	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations This Read Vac	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps C Ø	103.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps B Ø	82.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps A Ø	103.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Switching Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations This Read Vac	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations A Ø	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AL	196	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AF	196	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Switching Operations	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations This Read Vac	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AL	290	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AF	290	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations Ground	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations C Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations B Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	143.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	157.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	151.0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	1	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	73	°F
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	1 fan needs cap.	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	63	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	36	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	66	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	36	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	56	°C
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations This Read SF6	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	65	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	65	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	4	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	9 Month Operations GCB New	4	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 14:25	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AL	1493	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations This Read AM	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Switching Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Unknown Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AF	1493	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Maintenance Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Month Ops New	12	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Months Operations	12	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps A Ø	45.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps B Ø	55.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps C Ø	69.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations A Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations B Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations C Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations Ground	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Month Ops New	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations This Read AM	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1644	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	26460	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	26460	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	General Comments	needs ladder	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	60	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	40	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	36471	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	36471	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	6R	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	6L	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	918	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments	need ladder	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	35	°C
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.200	millivolts
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments	added water	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Switching Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AF	199	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Maintenance Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AL	199	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Unknown Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations This Read Vac	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations Ground	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations C Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations B Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations A Ø	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps A Ø	100.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps C Ø	90.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps B Ø	80.0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	9 Month Operations	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	PT Free of Leaks?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Oil Level	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	PT Free of Leaks?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	General Comments		
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:53	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	43.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	112	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	944	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1843	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	139598	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	132554	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	132569	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6645.60	kw
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9230	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments	there is not a oil stop valve in the sub	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Oil stop valve operational?	n	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
10/3/2023 9:08	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AF	149	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AL	149	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps C Ø	103.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps B Ø	106.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps A Ø	11.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	9 Month Operations VCB New	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	9 Month Operations	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	9 Month Operations	12	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	9 Month Operations VCB New	10	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps A Ø	132.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps B Ø	116.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps C Ø	123.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations A Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations B Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AF	65	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AL	65	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations This Read Vac	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations This Read Vac	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AL	148	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AF	148	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations C Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations B Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps C Ø	133.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps B Ø	102.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps A Ø	116.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	9 Month Operations VCB New	10	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	9 Month Operations	12	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	9 Month Operations	28	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	9 Month Operations VCB New	28	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps A Ø	338.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps B Ø	323.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps C Ø	361.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AF	88	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AL	88	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	14	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	105	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	105	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	13	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	9 Month Operations	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps A Ø	81.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps B Ø	100.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps C Ø	114.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations A Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations Counter AF	60	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations Counter AL	60	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations This Read Vac	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	9 Month Operations	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps A Ø	89.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps B Ø	100.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps C Ø	114.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations B Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations A Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AL	62	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations This Read Vac	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AF	62	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	9 Month Operations VCB New	5	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AL	20	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AF	20	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	9 Month Operations	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	9 Month Operations VCB New	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps A Ø	11.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps B Ø	7.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps C Ø	13.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AF	54	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AL	54	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	9 Month Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps A Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps B Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps C Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AF	75	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AL	75	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	9 Month Operations	19	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	9 Month Operations VCB New	19	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps A Ø	180.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps B Ø	195.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps C Ø	211.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AL	25	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AF	25	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	9 Month Operations	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	9 Month Operations VCB New	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps A Ø	286.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps B Ø	290.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps C Ø	291.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	9 Month Operations	9	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	9 Month Operations VCB New	9	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps A Ø	66.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps B Ø	67.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps C Ø	65.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AL	33	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AF	33	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	9 Month Operations	9	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	9 Month Operations VCB New	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps A Ø	65.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps B Ø	66.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps C Ø	65.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations This Read Vac	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AL	84	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AF	84	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations C Ø	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations B Ø	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations A Ø	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AL	90	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AF	90	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps C Ø	65.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps B Ø	66.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps A Ø	65.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	9 Month Operations VCB New	8	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	9 Month Operations	8	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AF	54	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AL	54	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	9 Month Operations	25	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	9 Month Operations VCB New	25	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps A Ø	481.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps B Ø	475.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps C Ø	483.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	48	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	48	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations VCB New	5	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	5	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	190856	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	190858	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	5L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	13R	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	1L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	2868	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	59	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	52	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	54	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	179737	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	179737	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	10R	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	7L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1278	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	85	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	85	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	85	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	9R	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1275	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	3L	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	190314	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	190314	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	85	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	47	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	80	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	47	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	47	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	70	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	198	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	104465	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	104465	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC shows a little low on oil could be from cool temps	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	98803	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	98803	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	5206	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments	Needs Two screw on type desiccant	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations VCB New	9	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	9	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	189	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	189	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	145.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	146.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	140.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	264	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	156.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	152.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	156.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations VCB New	19	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	20	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	1	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	264	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	66.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	68.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	69.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations VCB New	14	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	14	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	249	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	249	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	234	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	234	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	6	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations VCB New	6	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	91.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	89.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	81.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AL	147	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AF	147	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	216.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	206.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	215.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations VCB New	4	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	4	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	187	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations VCB New	7	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	213.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	206.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	211.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	187	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	11.7	amps
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.100	millivolts
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations Counter AF	366	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations Counter AL	366	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps C Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps B Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps A Ø	0.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	9 Month Operations VCB New	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	9 Month Operations	2	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps A Ø	25.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	9 Month Operations VCB New	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	9 Month Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps B Ø	25.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps C Ø	25.0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Switching Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations Counter AL	337	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations Counter AF	337	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/3/2023 8:39	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1085	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9R	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	107216	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	107216	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	258	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	16	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations VCB New	16	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments	VC wrote down wrong on last inspection.	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	258	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	152	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	152	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	78.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	74.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	76.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	151	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	151	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	228.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	219.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	225.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	590	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	590	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations VCB New	2	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	2	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	9	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations VCB New	9	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	139.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	141.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	137.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	271	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	271	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	1	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	295	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	418.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	430.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	451.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	295	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	216979	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	216979	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1R	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15R	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1425	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	497	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	497	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	98.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	77.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	75.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	c phase winding temp probe seeping oil.	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	568	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	568	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	9	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations VCB New	9	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations VCB New	59	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	59	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	396	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	396	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	114.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	111.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	105.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations VCB New	24	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	25	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	67.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	66.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	70.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	1	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	721	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	721	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations This Read Vac	1	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	331.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	349.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	369.0	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	892	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9R	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1R	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	64028	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	64028	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	32	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs nitro added to bottle.	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 11:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	9 Month Operations	4	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	9 Month Operations VCB New	4	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Operations Counter AF	28	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Operations Counter AL	28	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Amps A Ø	50.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Amps B Ø	39.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Amps C Ø	50.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Amps C Ø	11.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Amps B Ø	10.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Amps A Ø	11.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	9 Month Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Operations Counter AF	106	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Operations Counter AL	106	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Amps C Ø	76.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Operations Counter AF	19	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Operations Counter AL	19	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Operations This Read Vac	3	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Operations C Ø	3	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Amps B Ø	80.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Amps A Ø	79.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	9 Month Operations VCB New	11	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	9 Month Operations	14	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Operations Counter AF	118	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Operations Counter AL	118	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Amps C Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Amps A Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	9 Month Operations VCB New	1	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Readings	9 Month Operations	1	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	5	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	5	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	44	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	44	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	9 Month Operations	3	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	9 Month Operations VCB New	3	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Amps C Ø	140.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Amps B Ø	138.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Amps A Ø	137.0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Unknown Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Switching Operations	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Operations Counter AL	27	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Readings	Operations Counter AF	27	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	42	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	46	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	42	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	46	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	46	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	42	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	46	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations This Read AM	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Month Ops New	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations This Read AM	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Month Ops New	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	184	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations VCB New	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	184	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	87.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	82.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	76.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations VCB New	4	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	4	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	74.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	77.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	77.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	415	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	415	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments	Needs nitro added	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	22598	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	22598	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1021	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	64.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	64.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	8	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	8	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments	BC IOC	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	320	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	320	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	16	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	98	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations VCB New	82	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	143.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	142.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	140.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	18.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	19.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	19.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations VCB New	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	206	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	206	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	10	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations VCB New	10	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	111.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	106.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	106.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	201	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	201	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	95.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	97.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	90.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations VCB New	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	371	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	371	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	70	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Needs Nitro added	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	618	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	260825	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	260825	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro added to bottle.	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002137	BreakerVacuum	OX-1280	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002136	BreakerVacuum	OX-1279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002135	BreakerVacuum	OX-1278	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002134	BreakerVacuum	OX-1277	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Amps C Ø	152.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Amps B Ø	161.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Amps A Ø	167.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	9 Month Operations VCB New	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	9 Month Operations	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Operations Counter AF	51	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Readings	Operations Counter AL	51	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001978	BreakerVacuum	CY-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	9 Month Operations VCB New	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	9 Month Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Operations Counter AF	84	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Readings	Operations Counter AL	84	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001979	BreakerVacuum	CY-SPARE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Operations Counter AL	44	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Operations Counter AF	44	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	9 Month Operations VCB New	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Readings	9 Month Operations	2	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001977	BreakerVacuum	CY-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	9 Month Operations VCB New	3	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	9 Month Operations	3	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Operations Counter AL	31	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Operations Counter AF	31	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001962	BreakerVacuum	CY-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Operations Counter AF	16	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Operations Counter AL	16	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Amps C Ø	335.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	9 Month Operations	3	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	9 Month Operations VCB New	3	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Amps A Ø	341.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Readings	Amps B Ø	338.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001963	BreakerVacuum	CY-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	9 Month Operations	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	9 Month Operations VCB New	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Operations Counter AF	44	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Operations Counter AL	44	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001960	BreakerVacuum	CY-14KV TFR SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	62	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	62	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 10:08	Distribution	Clay LGE Quarterly Inspection	BK001961	BreakerVacuum	CY-14KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002133	BreakerVacuum	OX-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	General Comments		
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2023 12:23	Distribution	Oxmoor Quarterly Inspection	BK002132	BreakerVacuum	OX-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Operations Counter	467	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.2	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.4	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.3	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4266	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	170.64	kw
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	304065	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79893	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments	bad counter/drag hands not working	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	177360	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
9/29/2023 11:02	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	2	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations VCB New	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	56.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	67.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	55.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	224	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	224	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	2	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	2	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	147.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	151.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations VCB New	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	183	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	183	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	140.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	2	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	205	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	205	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	2	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations VCB New	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	54.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	49.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	46.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	1	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	17705	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	9L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	9L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	19997	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	11L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	17831	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5616.00	kw
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	80	°C
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5850	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	63.33	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	573	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	17400	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	17400	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	All Connections OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Operation Checked?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	4598.40	kw
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.4790	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	64	°F
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Operations Counter	80	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	General Comments	Recloser is open and disconnects are open	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2023 10:40	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments	Grounds have been cut on gates going up to barbed wire on top of gates. W/O created	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2023 10:09	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	9 Month Operations	6	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	9 Month Operations VCB New	1	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps A Ø	89.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AL	174	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AF	174	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Maintenance Operations	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations Ground	1	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations C Ø	2	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations B Ø	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations A Ø	2	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps C Ø	74.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps B Ø	56.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations This Read Vac	5	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Switching Operations	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Unknown Operations	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations Ground	1	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations C Ø	1	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations B Ø	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations A Ø	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps C Ø	65.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps B Ø	87.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps A Ø	57.0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Maintenance Operations	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	9 Month Operations VCB New	12	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	9 Month Operations	14	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AF	163	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AL	163	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations This Read Vac	2	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Unknown Operations	0	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	25107	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	25118	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	7R	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	9R	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	1R	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	849	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	48	°C
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	58	°C
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	5729.76	kw
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	.7958	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.620	millivolts
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/29/2023 14:55	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	9 Month Operations VCB New	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations Ground	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations C Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations B Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations A Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps A Ø	60.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps B Ø	45.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps C Ø	50.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	9 Month Operations	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Maintenance Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AF	190	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AL	190	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations This Read Vac	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Switching Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Unknown Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations VCB New	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	180.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	225.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	200.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	239	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	239	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	335.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	350.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	325.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations VCB New	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	170	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	170	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1072	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1072	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	100.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	95.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	105.0	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations VCB New	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	2	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	2547	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	2547	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	6L	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	6R	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	1140	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	11869.20	kw
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	80	°C
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.6594	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	40	°C
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.7	VDC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2023 12:05	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-04-24 00:00:00.000000	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/27/2023 15:51	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations VCB New	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	320.0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	320.0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	320.0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	137266	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	6L	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	1601	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	137266	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	1R	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Current Tap Position	6L	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	All Connections OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Min Tap Position	11L	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Max Tap Position	1R	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Bandwidth AL	123.0	VAC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Base Voltage AL	123.0	VAC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Counter AF	137266	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Counter AL	137266	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	KRC000349	RegulatorControl	619-2	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	9541.80	kw
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.5301	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	65	°C
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	45	°C
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/27/2023 15:43	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	491	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	491	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations VCB New	4	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	4	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	4	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations VCB New	4	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	498	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	110.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	110.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	110.0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	498	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	9 Months Operations OCB New	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	352	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	352	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-03-27 00:00:00.000000	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	820	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	14476	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	14476	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	2851.20	kw
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.5940	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.0	VDC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations VCB New	3	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	3	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps A Ø	241.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps B Ø	248.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps C Ø	238.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Maintenance Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Unknown Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AF	222	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AL	222	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Switching Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C Ø	142.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps B Ø	140.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps A Ø	122.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	203	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	203	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations VCB New	7	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations	7	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 14:55	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Maintenance Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AF	151	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AL	151	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Switching Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Unknown Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps C Ø	379.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps B Ø	390.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations VCB New	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps A Ø	368.0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Operations Since Last Insp	1183	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Max Tap Position	8R	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Left Counter	12915	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Found Counter	12915	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	LTC Totalizer Reading	8452.80	kw
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Reading	.5870	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Max	55	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Present	45	°C
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	9 Month Operations GCB New	1	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Unknown Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	1	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	96	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	96	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	76	°F
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure	68	psi
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.9	VDC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.4	VDC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.3	VDC
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 14:53	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps A Phase V	17.52	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps C Ø	280.0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps B Ø	326.0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps A Ø	253.0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations A Ø	2	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	9 Month Operations VCB New	3	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	9 Month Operations	5	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Maintenance Operations	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AF	180	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AL	180	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations This Read Vac	2	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Switching Operations	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Unknown Operations	0	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	26976	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24636	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29469	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	13R	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9700	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6304.00	kw
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 14:44	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	40.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	40.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	40.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	291	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	291	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations VCB New	4	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	4	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	60.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	60.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	60.0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	4	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	247	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	247	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations VCB New	4	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	79870	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	817	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	79870	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.2410	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	2313.60	kw
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BCH001560	Charger	569-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	72	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 14:19	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations VCB New	3	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	3	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	137.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	30	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	30	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	145.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	171.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	307.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	316.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	321.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	4	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	6.83	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	3	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	6.83	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	287	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	287	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	6.83	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	85.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	89.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	84.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	322	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	322	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	917	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	7.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	6.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	7.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	917	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	3	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations VCB New	3	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	58.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	36.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	54.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	6	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	6	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AL	152	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AF	152	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps C Ø	181.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps B Ø	216.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps A Ø	208.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	205	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	137.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	147.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	148.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	205	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	590.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	480.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	470.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations VCB New	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	340.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	340.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	340.0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	67	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	67	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	122.9	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	127104	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	127104	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	7R	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	6L	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	1301	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	50	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	75	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.9366	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	70	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	16858.80	kw
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	1011	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	17827	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	17827	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	10789.20	kw
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	50	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	75	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.5994	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.3	VDC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.3	amps
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments	SPR system is gone	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 13:14	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	16	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	167.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	145.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	148.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	243	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1984	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	167.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	192.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	171.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	34	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	34	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	1	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	168.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	170.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	173.0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	26	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	26	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	1	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations VCB New	1	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	92585	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	85375	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	42728	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9516	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6851.52	kw
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	720	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	3L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	88489	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	88489	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	3385.60	kw
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	1.0580	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 11:22	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations A Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations B Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps C Ø	100.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps B Ø	100.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps A Ø	99.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations C Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations Ground	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Maintenance Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AF	178	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	9 Month Operations VCB New	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	9 Month Operations	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Unknown Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Switching Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations This Read Vac	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AL	178	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	9 Month Operations	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	9 Month Operations VCB New	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps A Ø	6.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps B Ø	9.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Amps C Ø	6.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations A Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations B Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Fault Operations Ground	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Maintenance Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AF	171	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AL	171	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations This Read Vac	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Switching Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Unknown Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Switching Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps C Ø	74.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations A Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations B Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations C Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations Ground	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Unknown Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps B Ø	73.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Amps A Ø	65.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	9 Month Operations VCB New	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	9 Month Operations	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Maintenance Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations Counter AF	177	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations Counter AL	177	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Operations This Read Vac	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps B Ø	95.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps C Ø	112.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations A Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations B Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations C Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations Ground	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps A Ø	144.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	9 Month Operations VCB New	2	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Unknown Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Switching Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations This Read Vac	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AL	173	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AF	173	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Maintenance Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Maintenance Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations Counter AF	193	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations Counter AL	193	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Operations This Read Vac	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Switching Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Unknown Operations	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	9 Month Operations	8	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	9 Month Operations VCB New	8	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations Ground	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations C Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps A Ø	101.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps B Ø	47.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps C Ø	67.0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations B Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Fault Operations A Ø	0	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15692	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	20486	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26158	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6714	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2148.48	kw
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	8793	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	538	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	5L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	6R	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	4L	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	8793	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.5676	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	5448.96	kw
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	45	°C
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	60	°C
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 10:43	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Unknown Operations	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Switching Operations	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations This Read Vac	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations B Ø	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations A Ø	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	9 Month Operations	2	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps C Ø	6.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps B Ø	6.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps A Ø	6.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations C Ø	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations Ground	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	9 Month Operations VCB New	2	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AL	187	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AF	187	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Maintenance Operations	0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	429	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations VCB New	4	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	180.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	5	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	180.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	4.07	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	1	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	120.0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	279	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	279	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	1	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	0	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45219	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	3L	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	14L	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	12L	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	24721	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	24721	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	489	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33385	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	44659	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2894.40	kw
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6080	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	3119.04	kw
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.4332	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 9:59	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments	there ia not a spill kit . Tree limbs growing over the fence.	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	255.00	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 9:59	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	172761	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	172761	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	608	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps A Ø	50.0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations VCB New	13	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Unknown Operations	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations	13	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps B Ø	57.0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps C Ø	50.0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations A Ø	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations B Ø	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations C Ø	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations Ground	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Maintenance Operations	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AF	253	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AL	253	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations This Read Vac	0	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Switching Operations	0	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	218140	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	218140	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	608	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations VCB New	0	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	5	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	1	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	1	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/26/2023 16:52	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	12.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	13.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	17.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations VCB New	2	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	4	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	1.84	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	2	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	1	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	1	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	190	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	190	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	41.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	189	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	189	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	1	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	1	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	39.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	36.0	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations VCB New	2	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	3	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	70075	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	68048	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	73956	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	35	°C
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.2034	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	976.32	kw
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/26/2023 13:41	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/26/2023 7:59	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	48.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	57.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	72.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations VCB New	4	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	4	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	179	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	179	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	4	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations VCB New	4	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	187	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	187	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	78.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	78.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	80.0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-03-28 00:00:00.000000	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	427	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	427	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	9 Months Operations OCB New	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	5193.60	kw
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.0820	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	30	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	17221	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	17221	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	648	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
9/26/2023 7:20	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	General Comments		
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/27/2023 5:06	Distribution	Muldraugh Quarterly Inspection	ST000862	Structure	MU-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	.8	AMPS
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.4	VDC
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushing Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Foundation Condition	Good	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	General Comments		
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Grounds in Place?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/27/2023 5:08	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	67.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	61.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	45.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	233	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	233	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations B Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations A Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations C Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations Ground	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Maintenance Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AF	216	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps C Ø	37.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps B Ø	43.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations This Read Vac	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AL	216	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps A Ø	35.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Switching Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Unknown Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	9 Month Operations VCB New	4	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	9 Month Operations	4	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	9 Month Operations	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps A Ø	36.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps B Ø	32.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps C Ø	42.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations A Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations B Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations C Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations Ground	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Maintenance Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AF	200	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AL	200	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations This Read Vac	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Switching Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Unknown Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	365	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	365	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	225.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	220.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	222.0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	2	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	94795	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	52604	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	118050	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6846	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	821.52	kw
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	9L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	999	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	3L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	13L	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	15164	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	15164	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	302	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	54.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Operations Counter	95	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps B Ø	53.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	8	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	237764	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	237764	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	751	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	.8838	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	4242.24	kw
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments	LTC does not have nitrogen it has desicant filter	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.5502	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	3961.44	kw
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2023 15:06	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 15:02	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	291	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	271	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	74	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	85	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments	no amp gauge	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	9498	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	10R	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	127390	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	124611	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	All Temp Gauges MAX Reset	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1728.00	kw
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7200	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	55	°C
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 14:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	123.0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	115.0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	110.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	381	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	381	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	3	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations VCB New	3	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	2	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	5.87	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	37.0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	49.0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	54.0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	4	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	1	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	287	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	287	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	3	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	1151	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	30323	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	30323	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments	there is not a nitrogen gauge on the LTC	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	1.0649	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments	there is not a winding temperature gauge	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	5111.52	kw
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments	wooden fence is touching at 2 places	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 12:36	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	4	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations VCB New	4	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	60	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	60	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations VCB New	4	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	321	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	321	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	40.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	1014	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	1014	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	50.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	40.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	20.0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations VCB New	4	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	4	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	9 Months Operations OCB New	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-03-28 00:00:00.000000	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	3R	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments	counter not working	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	401	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	401	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	3124.80	kw
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.6510	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	BCH001570	Charger	696-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2023 12:01	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	182	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	182	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	14.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	0.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	0.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	287	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	287	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	340.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	350.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	350.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	273	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	273	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations VCB New	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	700.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	712.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	699.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	213	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	213	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations VCB New	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	620.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	640.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	640.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99947	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99947	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	3	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	342.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	344.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	331.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	276	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	276	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	350.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	376.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	351.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	1	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	256	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	256	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	340.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	350.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	330.0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	99957	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	99957	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	3197	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	12R	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	3R	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	145814	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	145814	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	65	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments	the LTC has desicant filter does not have nitrogen	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	70	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	75	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	16146.00	kw
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.8970	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	80	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	65	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	9R	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	61349	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	61349	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1204	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	All Connections OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments	does not have nitrogen on LTC it has desicant filter. there is not a temperature gauge on LTC	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	45	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	65	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.8532	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	15357.60	kw
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	23.6	VDC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	29.6	VDC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments	signs need to be updated	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2023 11:29	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Maintenance Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations Ground	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations C Ø	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations B Ø	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations A Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps C Ø	155.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps B Ø	179.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	9 Month Operations	3	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps A Ø	160.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Unknown Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Switching Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations This Read Vac	2	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AL	192	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AF	192	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations C Ø	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations Ground	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations B Ø	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations A Ø	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps C Ø	40.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps B Ø	34.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps A Ø	42.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	9 Month Operations	4	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Maintenance Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AF	174	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AL	174	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations This Read Vac	3	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Switching Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Unknown Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	46	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	188.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	89.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	185	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	185	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations VCB New	1	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	34.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	31.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	32.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	186	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	186	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	101.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	96.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	96.0	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations VCB New	2	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	2	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	139682	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	1070	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	139682	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments	does not have a temperature gauge on the LTC. Does not have nitrogen on the LTC it has desicant filter	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	39566	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	39566	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	3R	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	9L	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	1292	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	7536.00	kw
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Max	70	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Present	50	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.7850	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments	does not have a temperature gauge for LTC	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	5690.88	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.5928	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.3	VDC
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments	SPR system has been removed	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2023 10:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	227.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	217.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	211.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations VCB New	1	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	190	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	190	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	159	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	159	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	141.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	124.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	147.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations VCB New	1	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	1	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	200	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	200	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	152.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	197.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	214.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations VCB New	3	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	3	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	1	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations VCB New	1	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	191	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	191	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	86.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	92.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	66.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Unknown Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Switching Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations This Read Vac	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations Counter AL	174	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Operations Counter AF	174	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Maintenance Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations Ground	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations C Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations B Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Operations A Ø	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps C Ø	592.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps B Ø	568.0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Amps A Ø	614.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	9 Month Operations VCB New	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BK002039	BreakerVacuum	811-1	VCB Readings	9 Month Operations	0	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	563	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	2L	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	4032	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	4032	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCControl	811-1	LTC Control Insp	All Connections OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	14450.40	kw
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	50	°C
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	65	°C
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.8028	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Blockages	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments	several fans locked up not working	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	°F
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2023 14:42	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	3	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	25.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	20.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	1	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	1	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	272	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	272	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	40.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	396	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	396	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	1	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	1	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	221	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	221	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	8	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations VCB New	6	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	105.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	125.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	125.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	90.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	105.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	80.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	216	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	216	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations	6	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations VCB New	6	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AF	176	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AL	176	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations This Read Vac	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Switching Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Unknown Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps A Ø	105.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps B Ø	110.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps C Ø	100.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations B Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations C Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations Ground	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	197	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	197	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	135.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	130.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	130.0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	All Connections OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	621	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	7L	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	8L	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	76775	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	76775	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	45	°C
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.7678	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	7370.88	kw
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	All Connections OK?	y	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	42672	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	42672	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	8L	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	9L	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	754	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.7002	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	40	°C
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	6721.92	kw
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 15:19	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	214	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	214	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	245.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	230.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	190.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	207	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	207	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	65.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	55.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	75.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	40.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	40.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	40.0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	203	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	203	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	432	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	10L	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	6L	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	84353	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	84353	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2280.00	kw
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.3800	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.7	VDC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:51	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	2	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	142	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	142	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	20.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	20.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	20.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	52	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	52	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	5	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations VCB New	5	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	100.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	90.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	60.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	2	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations VCB New	2	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	132	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	132	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	60.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	80.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	90.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	179	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	179	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	40.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	100.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	100.0	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	3	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations VCB New	3	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	182534	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	182534	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	572	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	2385.60	kw
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.2982	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.0	VDC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 14:44	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	4	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations VCB New	4	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	177	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	177	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	10.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	20.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	568	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	568	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations VCB New	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	10.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	10.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	10.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments	COUNTER NOT WORKING	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	430	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	428	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations VCB New	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	100.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	100.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	100.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	105.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	115.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	85.0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	122	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	124	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations VCB New	0	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	2	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	555	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	5L	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	88655	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	88655	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	2721.60	kw
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.3402	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.2	VDC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 14:38	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	170	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	170	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	78.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	75.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	78.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	152	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	152	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	67.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	66.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	61.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	214	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	40.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	214	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	34.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	36.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations VCB New	17	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	17	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	1	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	77.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	69.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	73.0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	172	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	172	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	796	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	206873	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	206873	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	9123.84	kw
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.9504	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 14:14	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	90	psi
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	79	°F
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	57	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	57	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	9 Month Operations GCB New	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	2	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	5	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	199	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	199	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	2	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	460.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	452.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	449.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	6	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	187	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	187	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	203.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	202.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	198.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	1	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	270	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	270	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	62.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	75.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	54.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations VCB New	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	708.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	722.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	713.0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	156	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	156	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	50	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	15655.68	kw
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	68	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	49	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	68	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	1.0872	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	1919	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	51271	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	51271	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.5	VDC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.4	VDC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.5	VDC
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 12:56	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	3	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations VCB New	3	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	264.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	258.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	270.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	289	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	289	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	1	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	399	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	399	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	214.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	218.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	217.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	287	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	287	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	171.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	173.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	1	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	159.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations VCB New	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	640.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	640.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	640.0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	208	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	208	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	835	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	322576	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	322576	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	70	°C
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	70	°C
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	65	°C
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	80	°C
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	15768.00	kw
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.8760	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.9	VDC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments	signs nee to be updated	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments	there is no berm in sub	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	n	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2023 11:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments	open	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	493	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	493	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	1	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	1	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	2	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations VCB New	1	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	5	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations VCB New	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	12.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	12.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	12.0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	8.76	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	8.76	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	1	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	1	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	82	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	82	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	2	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	253371	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	253364	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	906	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0582	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	186.24	kw
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	44	°C
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.260	millivolts
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.3	VDC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 11:39	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	50.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	50.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	424	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	424	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	50.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	50.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	50.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	190.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	200.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	180.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	250.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	250.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	180.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	491	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	491	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	430	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	430	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	150.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	130.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	170.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	21.00	MegaWatts
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	12.00	MegaWatts
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.80	MegaVars
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	253783	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	253783	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	1.80	MegaWatts
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.50	MegaWatts
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.25	MegaVars
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	35138	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	35138	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	984	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	380.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	380.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	380.0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	552	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	552	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Month Ops New	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	43.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	14	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	8	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6674	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8126	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6659	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 14:59	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A Ø	37.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	18	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations VCB New	18	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	245	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	245	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C Ø	40.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B Ø	30.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations VCB New	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations	8	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps A Ø	28.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps B Ø	26.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps C Ø	28.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations A Ø	1	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations C Ø	1	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Maintenance Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AF	186	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AL	186	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations This Read Vac	2	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Switching Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Unknown Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Maintenance Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AF	187	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations B Ø	1	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps C Ø	95.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps B Ø	83.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps A Ø	77.0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AL	187	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations This Read Vac	1	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Switching Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Unknown Operations	0	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations VCB New	1	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations	2	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	All Connections OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	16526	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	16526	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	4L	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	3R	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	5L	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	1007	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	5258.88	kw
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	50	°C
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	50	°C
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.5478	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 14:51	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	8	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations VCB New	4	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	110.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	95.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	105.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	8.38	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	2	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	2	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	215	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	215	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	4	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	415	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	415	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	3	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	3	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	45.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	35.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	35.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations VCB New	2	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	5	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	277	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	277	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	2	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations VCB New	2	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	75.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	75.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	80.0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57307	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	58294	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54001	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5850	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5616.00	kw
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	70	°F
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.2	VDC
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-06-14 00:00:00.000000	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 14:42	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	30.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	30.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	316	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	316	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	1	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	15	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations VCB New	14	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	30.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	1	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	192	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	192	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	400.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	410.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	375.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations VCB New	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	3	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations VCB New	2	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	25.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	75.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	75.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	1	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	256	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	1	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	256	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	237	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	237	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	3	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	15.20	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	50.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	50.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	50.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations VCB New	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	3	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	3	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations VCB New	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	300.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	305.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	305.0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	225	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	225	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	721	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	10L	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	2L	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	6L	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	25731	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	25731	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	40	°C
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	60	°C
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.7800	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	40	°C
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	40	°C
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	11232.00	kw
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 14:34	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2024-04-12 00:00:00.000000	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 13:59	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	1	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations VCB New	1	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	458.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	478.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	458.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	216	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	216	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	1809	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	6R	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	1L	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	83453	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	83453	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	50	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.6186	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	45	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	65	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	55	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	11134.80	kw
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	1	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations VCB New	1	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	174	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	174	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	300.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	320.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	320.0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	1148	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	171682	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	171682	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	40	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	60	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.4545	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	8181.00	kw
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BAT001633	Battery	593-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	BCH001582	Charger	593-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments	signs need updating	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 13:46	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2059	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	55	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	58.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	53.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	52.0	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	32621	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	32621	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	3L	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	774	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	4129.92	kw
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.4302	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/20/2023 10:15	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	60	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	60	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	55	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations VCB New	3	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	3	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	1	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	1	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	199	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	199	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	18.07	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	184	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	184	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	490.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	18.07	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	16.94	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	75.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	75.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	75.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations VCB New	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	1	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	490.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	490.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	6.77	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	120.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	120.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	120.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	203	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	203	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations VCB New	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	784.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	791.0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	782.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
6/23/2023 12:18	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	200	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	200	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	6.77	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	140.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	142.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	142.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	19	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	19	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	204	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	204	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	2	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	892.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	77.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	89.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	75.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	914.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	885.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations VCB New	20	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	20	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2023 5:34	Distribution	Western Quarterly Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	857	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	433445	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	433445	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	9 Month Operations	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps A Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps B Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Amps C Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations Counter AL	241	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001616	BreakerVacuum	663-0799	VCB Readings	Operations Counter AF	241	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations Counter AL	169	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Operations Counter AF	169	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps C Ø	140.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps B Ø	135.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	9 Month Operations	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Amps A Ø	135.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001615	BreakerVacuum	663-0798	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	9 Month Operations	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps A Ø	130.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps B Ø	135.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Amps C Ø	140.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations Counter AF	165	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations Counter AL	165	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001614	BreakerVacuum	663-0797	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	9 Month Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	9 Month Operations VCB New	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps A Ø	275.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps B Ø	265.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Amps C Ø	280.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AF	176	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AL	176	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	General Comments	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Pressure	66	psi
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Ambient Temperature	70	°F
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps C Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps B Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations Counter AF	178	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations Counter AL	178	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps A Ø	0.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	9 Month Operations	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	9 Month Operations	3	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps A Ø	190.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps B Ø	175.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Amps C Ø	210.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations This Read Vac	1	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations Counter AL	175	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Operations Counter AF	175	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001613	BreakerVacuum	663-0651	VCB Readings	Fault Operations B Ø	1	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	9 Month Operations	4	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	9 Month Operations VCB New	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps A Ø	450.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps B Ø	450.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Amps C Ø	485.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations Counter AF	190	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations Counter AL	190	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001608	BreakerVacuum	663-0648	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations Counter AF	173	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations Counter AL	173	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	9 Month Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	9 Month Operations VCB New	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps A Ø	640.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps B Ø	630.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Amps C Ø	695.0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001617	BreakerVacuum	663-1	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Ambient Temperature	70	°F
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	General Comments	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	9 Month Operations GCB New	1	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Maintenance Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Num Operations Last 9 Months	1	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AF	185	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AL	185	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations This Read SF6	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Switching Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Unknown Operations	0	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Present	41	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Max	67	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	LTC Totalizer Reading	16440.00	kw
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Reading	.6850	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Max	69	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Present	42	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Operation Checked?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	All Connections OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Operations Since Last Insp	1453	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Max Tap Position	10R	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Left Counter	13796	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Found Counter	13796	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	140439	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	140439	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	4L	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	8R	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	1006	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	120.00	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	45	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	50	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	.4566	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	35	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	50	°C
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	4383.36	kw
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.1	VDC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:57	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	190.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	210.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	303	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations VCB New	5	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	303	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	5	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	180.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations VCB New	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	450.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	160	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	160	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	2	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	225.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	200.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	250.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	304	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	304	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	9 Month Operations	2	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps A Ø	85.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps B Ø	90.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Amps C Ø	100.0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Maintenance Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations Counter AF	195	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations Counter AL	195	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Switching Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Unknown Operations	0	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	1164	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	88999	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	88999	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	285.00	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	60	°C
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	80	°C
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.7570	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Present	55	°C
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Max	80	°C
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	10900.80	kw
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments	SPR OU OF SERVICE	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/19/2023 14:34	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Unknown Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations	2	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations VCB New	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps A Ø	35.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps B Ø	15.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps C Ø	15.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Switching Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AL	179	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AF	179	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Maintenance Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	1	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations VCB New	1	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	50.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	65.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	364	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	364	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	50.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	382	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	382	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	175.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	185.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	180.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	2	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	234	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	234	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations VCB New	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	225.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	250.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	245.0	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Operation Checked?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	All Connections OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	870	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	122360	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	122360	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	7747.20	kw
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.5380	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	60	°C
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	35	°C
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 14:28	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	3	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations VCB New	3	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	0.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	0.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	0.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	399	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	399	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	2	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	11.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	2.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	10.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	201	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	201	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	306	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	306	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	100.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	125.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	120.0	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations VCB New	2	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	2	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	21341	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	22988	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	26291	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1580.16	kw
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4938	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 14:22	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.2	psi
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Needs nitrogen.	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	445.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	42	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	57	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	33	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	58	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	36	°C
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	466.67	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 12:21	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Operations Counter	404	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BX1057	RecloserHydraulic	433-0625	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Maintenance Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AF	189	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AL	189	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations This Read Vac	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Switching Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Unknown Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations Ground	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations C Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations B Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations A Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps C Ø	240.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps B Ø	255.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps A Ø	220.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	9 Month Operations VCB New	3	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	9 Month Operations	3	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps C Ø	40.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations A Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations B Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations C Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations Ground	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Maintenance Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AF	176	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps B Ø	65.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Unknown Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AL	176	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations This Read Vac	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Switching Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps A Ø	50.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations VCB New	1	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations	1	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps C Ø	195.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations VCB New	5	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations	5	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps B Ø	200.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps A Ø	185.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations B Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations C Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations Ground	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Maintenance Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AF	180	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AL	180	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations This Read Vac	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations A Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	148	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	148	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	455.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	510.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations VCB New	0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	450.0	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Operations Since Last Insp	1568	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Min Tap Position	12L	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Max Tap Position	8R	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Current Tap Position	4L	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Left Counter	63969	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Found Counter	63969	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	779	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	5716	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	5716	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Present	50	°C
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Max	85	°C
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Reading	.9660	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Present	50	°C
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Max	70	°C
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	LTC Totalizer Reading	17388.00	kw
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Month Ops New	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	50.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	50.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	50.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	180.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	150.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Month Ops New	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	150.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Month Ops New	0	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/19/2023 7:13	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/19/2023 7:09	Distribution	Southern Baptist Seminary Quarterly Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	230.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	65	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	50	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	50	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	65	°C
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	476	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	476	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Month Ops New	1	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	1	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	90.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	50.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	80.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Month Ops New	10	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	10	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	479	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	20.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	20.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	20.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	479	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	423	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	423	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Month Ops New	6	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	6	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	100.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	100.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	90.0	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/20/2023 5:03	Distribution	Vermont Quarterly Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Unknown Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Switching Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations This Read Vac	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations Counter AL	142	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Operations Counter AF	142	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Maintenance Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations Ground	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations C Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations B Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Operations A Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps C Ø	130.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps B Ø	115.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Amps A Ø	115.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	9 Month Operations VCB New	10	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001830	BreakerVacuum	633-0639	VCB Readings	9 Month Operations	10	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Unknown Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Switching Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations This Read Vac	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations Counter AL	263	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Operations Counter AF	263	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps C Ø	20.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations A Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps B Ø	10.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Amps A Ø	15.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Maintenance Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations Ground	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations C Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Fault Operations B Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	9 Month Operations VCB New	4	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Readings	9 Month Operations	4	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001829	BreakerVacuum	633-0638	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	9 Month Operations	11	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	9 Month Operations VCB New	7	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps A Ø	85.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps B Ø	65.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Unknown Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Switching Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations This Read Vac	4	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations Counter AL	427	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Operations Counter AF	427	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Maintenance Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations Ground	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations C Ø	2	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations B Ø	2	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Operations A Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Readings	Amps C Ø	95.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001831	BreakerVacuum	633-0769	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations C Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations Ground	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	171	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	171	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations B Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations A Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps C Ø	30.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	30.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	35.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	5	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations VCB New	5	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations	2	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Maintenance Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Unknown Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations VCB New	2	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps A Ø	225.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps B Ø	215.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps C Ø	240.0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations A Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations B Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations C Ø	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations Ground	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Switching Operations	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations This Read Vac	0	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AL	204	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AF	204	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	866	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	20232	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	20232	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	15926.40	kw
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	1.1060	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	45	°C
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	45	°C
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 15:06	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	65.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	80.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	70.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	7	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations VCB New	7	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	215	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	215	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations VCB New	3	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	3	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	60.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	40.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	60.0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	347	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	347	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	940	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	231563	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	231563	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	2918.40	kw
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.9120	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.0	VDC
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 14:57	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	2	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations VCB New	2	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	100.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	85.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	95.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	209	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	209	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	1	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	1	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	195	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	195	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations VCB New	5	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	10.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	12.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	15.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	6	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	69	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	69	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations VCB New	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	240.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	240.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	240.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	4	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	234	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	234	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	2	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	2	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	6	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations VCB New	2	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	12.26	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	12.26	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	165.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	160.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	130.0	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	66108	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	66108	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	9L	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	2L	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	12L	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	905	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Operation Checked?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	All Connections OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	9861.12	kw
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	55	°C
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	1.0272	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	70	°C
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Present	50	°C
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 14:44	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	180.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	140.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations VCB New	1	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	1	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	120.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	731	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	731	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	1	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations VCB New	1	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	762	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	762	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	20.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	12.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	12.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	12.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	12.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	12.0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	1	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	326	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	326	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments	counter not working	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.6500	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	3900.00	kw
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	57	°C
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	posts and rails rusty, cudzu and growing up fence in back corner of station	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 12:45	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	241	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	241	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	50.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	50.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	50.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Month Ops New	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Month Ops New	7	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	8	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	75.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	75.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	80.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments	inst on c phase	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	455	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	455	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2487	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2487	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	75.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	75.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	75.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	5	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Month Ops New	5	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	20	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Month Ops New	18	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	2	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	25.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	25.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	30.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	123	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	123	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	151	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	151	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	5005.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	2	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	500.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	500.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Month Ops New	2	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	ok	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	235912	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	235912	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1426	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	34	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	68	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	34	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	71	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	34	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	20	°C
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	256.67	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	1	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	784	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	784	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	0.0	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations VCB New	34	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	35	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 9:24	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments	outriggers on trailer are sinking into pavement.	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Pumps Operational?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Pumps Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.1	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Fans Operational?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.1	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000244	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000089	WithLTC	LS-Yard-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	bottle needs filled	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000261	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	bottle is at 300	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	TX000260	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0100	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen. trransformer is leaning	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments	nitrogen	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2023 8:24	Distribution	South Service Center Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations VCB New	3	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	4.38	%
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	7.67	%
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	6.57	%
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	60.0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	40.0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	96.0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	27	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations VCB New	21	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	32.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	31.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	32.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	14.43	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	14.43	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	296	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	296	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	0	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	551	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	551	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	102.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	96.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	108.0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	38.58	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	64.04	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	54.78	%
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations VCB New	17	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	17	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations This Read Vac	6	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	432	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	432	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	3	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	3	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	3	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments	Someone has shot a fence post. 3/8" hole in corner post and strap is broken. Tree has fallen on right side of station and is touching fer	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	795	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.7	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.3	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.6	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	67	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.6	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	7	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	72	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4093	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	20409	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8134	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	825.84	kw
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6882	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2023 10:45	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments	multiple trees and vegetation overhanging fence	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.1	VDC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	491	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	91583	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	91579	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	All Connections OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.5688	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	51	°C
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	5460.48	kw
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.3	VDC
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	72859	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71071	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	69804	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	737.28	kw
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4608	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2023 7:43	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	53.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	52.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	53.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	9 Month Operations GCB New	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	111	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	111	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	824	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	824	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	31.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	33.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	30.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	9 Month Operations GCB New	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	9 Month Operations GCB New	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1469	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	302.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	305.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	318.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1469	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	91714	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	91714	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	983	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	61	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	33	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	64	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	33	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	62	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	33	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	64	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	33	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR in vacuum	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	570	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	6021	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	6021	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	9 Month Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps A Ø	308.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps B Ø	309.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Amps C Ø	298.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations Counter AF	87	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations Counter AL	87	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001932	BreakerVacuum	SH-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations Counter AL	81	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Operations Counter AF	81	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps C Ø	0.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps B Ø	0.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Amps A Ø	0.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	9 Month Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps C Ø	208.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps B Ø	219.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Amps A Ø	219.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	9 Month Operations	8	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations B Ø	2	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	General Comments	B phase TOC.	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations Counter AF	97	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations Counter AL	97	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations This Read Vac	2	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations Counter AL	74	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations Counter AF	74	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	9 Month Operations	1	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps A Ø	12.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps C Ø	14.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Amps B Ø	14.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	9 Month Operations	1	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations Counter AF	76	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations Counter AL	76	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps A Ø	10.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps B Ø	9.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Amps C Ø	9.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations Counter AF	94	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations Counter AL	94	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	9 Month Operations	13	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	9 Month Operations VCB New	13	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps C Ø	78.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps B Ø	77.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Amps A Ø	80.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	9 Month Operations GCB New	2	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	60.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	2	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	671	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	671	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	66.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	66.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	460	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	460	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	4	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	3	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	3	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	93.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	92.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	90.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	9 Month Operations GCB New	1	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	SF6 Pressure	0	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Ambient Temperature	58	°F
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	4	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	4	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	782	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	782	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	22	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	82.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	73.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	79.0	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	9 Month Operations GCB New	18	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	SF6 Pressure	0	psi
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:13	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Ambient Temperature	58	°F
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	27	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	11.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3030	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	37	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	242.40	kw
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	2L	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	212	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	212	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	2	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	164.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	175.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	164.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	1	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	1	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	189	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	189	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	156.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	144.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	132.0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	1	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	73587	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	22.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	19.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	9.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	242	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	242	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	9.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	19.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	22.0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	45	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	45	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	78354	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	73913	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	59	°C
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	79	°C
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2006	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	44	°C
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	84	°C
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	11525.76	kw
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	29	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	39	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.1176	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	31	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	41	°C
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2116.80	kw
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	large tree overhanging fence in front corner.	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 13:27	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	7	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	25.2	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	19.1	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	11.2	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	146.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	114.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	142.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	202	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	202	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	346	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	346	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	1	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	3	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	10.0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	11	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	11	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	0	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments	blown line arrester	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	85103	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	85114	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	946	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1850	psi
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 15:12	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	LTC Operation Checked?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000952	LTCControl	802-1	LTC Control Insp	All Connections OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	2670.72	kw
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.8346	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments	heater and cabinet lights not working	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.700	millivolts
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	two large birds nests in steel above transformer fuses	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	FE000897	Fence	802-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 13:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409613	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409613	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1032	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	427984	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	427984	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	572	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	572	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	250.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	250.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	180.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Month Ops New	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	100.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	100.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	180.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Month Ops New	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	1	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Month Ops New	1	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	175.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	180.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	225.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	393	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	393	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	399	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	399	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	250.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Month Ops New	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	240.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	290.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.5	VDC
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.5	VDC
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments	27.1/25	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	32	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	16.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments	27/24.9	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	55	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	81840	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	74206	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Regulator As Left Counter	153416	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	38	°C
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	51	°C
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1646	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2795.04	kw
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	fence fabric and posts rustY	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments	heavy vegitation on and through fence.	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 11:24	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	21.0	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	56	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	78	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57148	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	63419	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	65556	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2618.40	kw
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0910	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	53	°C
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	42	°C
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 10:42	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	167	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	167	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	4	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0801	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	21	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	21	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	30.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	30.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	30.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	277	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	277	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0800	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	2	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	69	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	6	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	69	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	30	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	36	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	1	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	335	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	335	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0798	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	4	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	3	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	a,c phase toc	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1089	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1089	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	6	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0797	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	380.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	380.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	380.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Month Ops New	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	181	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	181	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	All Connections OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	928	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	30337	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	30337	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AL	290	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AF	290	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps C Ø	160.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps B Ø	140.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps A Ø	140.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AL	176	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AF	176	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps C Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps B Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps A Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations	4	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps A Ø	107.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps B Ø	106.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps C Ø	120.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AF	109	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AL	109	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations	1	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps A Ø	40.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps B Ø	44.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps C Ø	45.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AF	114	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AL	114	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	167	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	167	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	All Connections OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	45	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Left Counter	7952	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Found Counter	7952	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	260	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	9 Month Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps A Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps B Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Amps C Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations Counter AF	115	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations Counter AL	115	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001455	BreakerVacuum	PL-1278	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Maintenance Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations Counter AF	114	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations Counter AL	114	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations Ground	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations C Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations B Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Operations A Ø	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Operations This Read Vac	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Switching Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Unknown Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps C Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps B Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Amps A Ø	0.0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Readings	9 Month Operations	0	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	General Comments		
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 9:00	Distribution	Pleasure Ridge Quarterly Inspection	BK001456	BreakerVacuum	PL-1279	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments	one 4 foot flourescent light not working.	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	96.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	84.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	151	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	151	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	87.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	150	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	150	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	28.94	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	28.94	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	28.94	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations VCB New	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	62	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	62	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	48	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	48	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	66	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	66	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	130	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	130	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	162	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	162	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	80	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	80	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations VCB New	9	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	9	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AL	197	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Operations Counter AF	197	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	191	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	191	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B Ø	99.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C Ø	96.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	111	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	111	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	102.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	80.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	80.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	77.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	133	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	133	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	85	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	85	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	105.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	103.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	106	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	106	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	97.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	93.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	561.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	566.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	194	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	194	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations VCB New	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	571.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	76	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	76	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations VCB New	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	62	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	62	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	56	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	56	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	transformer still leaking from temp gauges. known problem with transformer	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Month Ops New	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/14/2023 12:39	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	6.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1471	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1799	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	841	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	40737	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	40737	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	780	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.5800	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	25	°C
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	4176.00	kw
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	FE000898	Fence	738-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
9/13/2023 15:25	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	153	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	153	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	161	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	161	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	54	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	54	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	63	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	63	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	54	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	54	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	109	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	109	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	213	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	213	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	173	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	173	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	149	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	149	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	70	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	70	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	92	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	92	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	233	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	233	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	84	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	84	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	91	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	91	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	559.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	561.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	570.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	104	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	104	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	44.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	45.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	45.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	94	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	94	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	132.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	102	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	102	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	131.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	131.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	102	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	102	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	126.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	124.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	123.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	154	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	100.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	101.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	101.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	196	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	196	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	130.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	131.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	130.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	128.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	126	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	126	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	126.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	126.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AF	70	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations Counter AL	70	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	176	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	76	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	76	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	4	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps C Ø	4.0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps B Ø	4.0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps A Ø	5.0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	9 Month Operations VCB New	1	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations A Ø	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations B Ø	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations C Ø	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	9 Month Operations	1	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations Ground	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Maintenance Operations	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AF	197	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AL	197	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations This Read Vac	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Unknown Operations	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Switching Operations	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Output Voltage Level	120.2	VAC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Operation Checked?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	180	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	180	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	4	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	4701	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	4701	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	1172	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	16L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	182	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	182	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	1	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.2400	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1440.00	kw
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	179	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	179	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	551.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	559.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	568.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	106	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	106	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.3	VDC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	79	°F
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	198	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	42.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	40.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	42.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	198	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	9	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	145.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	141.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	140.0	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/13/2023 14:26	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	96	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	96	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	185.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	190.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	185.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps A Ø	56.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps B Ø	56.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Amps C Ø	56.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	92.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	89.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	90.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	170.12	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	170.12	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	170.12	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	66.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	66.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	67.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	18	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	310	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	310	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	75.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	73.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	76.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A Ø	72.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B Ø	74.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C Ø	73.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	262	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	262	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	188	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	188	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	1.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	202	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	202	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C Ø	92.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B Ø	84.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A Ø	82.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	345	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	345	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	119.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	126.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	109.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	293	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	293	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	202.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	222.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	201.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	199	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	199	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Switching Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations This Read Vac	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations Counter AL	48	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Operations Counter AF	48	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	9 Month Operations	4	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps A Ø	42.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps B Ø	47.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Amps C Ø	42.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations This Read Vac	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations Counter AL	36	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Operations Counter AF	36	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Switching Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps C Ø	63.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps B Ø	87.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Amps A Ø	70.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	9 Month Operations	7	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations Counter AL	18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations Counter AF	18	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps A Ø	85.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps B Ø	142.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Amps C Ø	122.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps A Ø	200.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps B Ø	270.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Amps C Ø	216.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations Counter AF	135	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations Counter AL	135	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps A Ø	51.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps B Ø	78.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations Counter AL	11	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Amps C Ø	74.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations Counter AF	11	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps C Ø	99.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps B Ø	81.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Amps A Ø	81.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	9 Month Operations	8	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations Counter AL	28	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Operations Counter AF	28	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	9 Month Operations	5	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps B Ø	173.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps A Ø	162.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Amps C Ø	144.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations B Ø	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	General Comments	B,C IOC	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations Counter AF	99978	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations Counter AL	99978	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Operations This Read Vac	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations Counter AF	16	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations Counter AL	16	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps C Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps B Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Amps A Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	13	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	13	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps A Ø	293.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps B Ø	329.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Amps C Ø	318.0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Unknown Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Switching Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations Counter AL	39	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations Counter AF	39	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	67197	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	67197	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1581	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	54	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	64	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	34	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	83061	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1145	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	83061	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	72	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	42	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1050	psi
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1875	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	30802	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	30802	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	95	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	84	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1474	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Found Counter	6018	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Left Counter	6018	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Operations Since Last Insp	1196	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	85.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	83.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	82.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	91.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	88.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	87.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	75.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	77.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	79.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	88.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	86.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	85.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	78.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	76.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	76.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.3500	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	3360.00	kw
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	567.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	560.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	558.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Operations Counter	6018	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 12:08	Distribution	Clarkson Quarterly Inspection	GX0290	RecloserElectronic	597-2404	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	2568	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	3L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	40725	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	40725	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	97.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	90.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	391	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	83.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	391	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations VCB New	1	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	1	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Unknown Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Switching Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations This Read Vac	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations	2	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps A Ø	96.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps B Ø	103.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps C Ø	95.0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations A Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations B Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations VCB New	2	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations Ground	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations C Ø	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Maintenance Operations	0	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AF	346	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AL	346	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Operation Checked?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	All Connections OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	106237	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	106237	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	1035	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	6048.00	kw
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.6300	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.7	VDC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/13/2023 11:15	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1514	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	895	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	99.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	109.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	10	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	1224	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	23209	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	23209	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	4608.00	kw
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.4800	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/13/2023 10:17	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	64	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	43	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	61	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	64	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	43	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	64	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	41	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	43	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	31600	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	899	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	31600	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	53	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	66	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	42	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	63	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	66	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	28018	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	28018	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	680	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	43	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	30418	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	30418	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	606	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	44	°C
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/13/2023 13:21	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 13:21	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	127	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	127	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	6.28	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	5.38	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	5.38	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	103	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	103	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AF	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations Counter AL	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	4.48	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	3.59	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	3.59	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	309	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	309	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations VCB New	13	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	8.97	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	8.07	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	4.48	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	5.38	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	10.76	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations VCB New	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations VCB New	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	100	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	100	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	24.21	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	10.76	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	30.48	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	32.28	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	10.76	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	3.59	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	117	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	117	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	4.48	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	7.17	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	4.48	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	187	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations VCB New	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	3.59	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	53	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	53	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	2.69	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	2.69	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	2.69	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations VCB New	9	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	7	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations VCB New	7	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	113	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	113	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	209	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	209	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	98	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	98	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations VCB New	8	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	1.79	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	.9	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	9.65	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	7.72	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	45871	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	45871	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1733	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	8R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	tap changer filter found tripped out on high pressure may need a new filter	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Month Ops New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Months Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	311	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	311	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	636	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	636	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	470.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	466.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	477.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Month Ops New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Month Ops New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	747	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	747	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	773	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	773	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Month Ops New	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	148.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	160.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	152.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Month Ops New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	600.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	600.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	600.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AF	609	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AL	609	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments	Vent Fan on roof not working. Extremely hot in side swgr.	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Month Ops New	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A Ø	280.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B Ø	240.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C Ø	214.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AF	893	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AL	893	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Month Ops New	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	908	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	908	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	61.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	48.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	56.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Month Ops New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	325	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	325	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AF	963	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AL	963	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps C Ø	129.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps B Ø	127.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps A Ø	120.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Month Ops New	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	330	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Month Ops New	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	330	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	380.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	398.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	397.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Tap changer filter was tripped out on high pressure, filter may need to be replaced.	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	64	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	64	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	59	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	59	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	65	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	65	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1796	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	10L	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	2R	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	16L	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	218596	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	218596	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments	Needs new screw on desiccant filter	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	45	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	80	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	55	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	60	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	50	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	75	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments	DCC not getting Loss of coolong alram, found two tripped fan breakers and no alarm was sent in.	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	205566	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	205566	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	12R	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1356	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	9 Months Operations OCB New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	30359	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	30359	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	406	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs two new screw on type dessicant filters, may need outage because of clearance issue	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations VCB New	6	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations	8	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations B Ø	2	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AF	101	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps A Ø	130.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps B Ø	180.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps C Ø	160.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AL	101	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations This Read Vac	2	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	96	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	96	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations VCB New	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations VCB New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	256	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	256	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments	N/O	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	7	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	9	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	4	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations VCB New	4	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments	DNO	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	210	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	210	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	4	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	435	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	186.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	207.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	435	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	200.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	227	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	227	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	40.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	28.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	50.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations VCB New	6	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	7	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	122.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	105.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	104.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	226	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	226	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	162	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	162	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	312.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	339.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	367.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	172	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	172	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	16	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations VCB New	16	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	185.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	190.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	178.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	636	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	636	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1811	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	68436	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	68436	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	63	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	37	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	37	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	37	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	66	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1896	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	128407	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	128407	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	90	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	85	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	80	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	92	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	34	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	75	°C
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments	voltage after 1 minute trip is 50.5	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments	Bathroom is out of order	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	130.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	140.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	160.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	3	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	1	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	47	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	47	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	60.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	110.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	100.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	77	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	77	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations VCB New	5	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	426.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	421.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	365.0	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 16:19	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	6	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations VCB New	4	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	103.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	102.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	106.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	103	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	103	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	2	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations VCB New	3	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	94	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	94	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations VCB New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	72	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	72	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	313.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	325.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	276.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations Counter AL	155	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Operations Counter AF	155	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	9 Month Operations	4	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	9 Month Operations VCB New	4	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001943	BreakerVacuum	CL-1401	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations Counter AL	97	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Operations Counter AF	97	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps C Ø	168.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps B Ø	172.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Amps A Ø	173.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	9 Month Operations VCB New	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Readings	9 Month Operations	1	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001944	BreakerVacuum	CL-1402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	9 Month Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	9 Month Operations VCB New	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps A Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps B Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Amps C Ø	0.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations Counter AF	88	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations Counter AL	88	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001945	BreakerVacuum	CL-1402/1404 TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Switching Operations	6	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations This Read Vac	6	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations Counter AL	104	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Operations Counter AF	104	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps C Ø	10.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps B Ø	11.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Amps A Ø	10.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	9 Month Operations VCB New	2	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Readings	9 Month Operations	8	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Tank Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001946	BreakerVacuum	CL-1403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	9 Month Operations VCB New	5	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	9 Month Operations	5	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps A Ø	86.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps B Ø	88.0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Amps C Ø	83.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations A Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations B Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations C Ø	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Fault Operations Ground	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Maintenance Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations Counter AF	105	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations Counter AL	105	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Operations This Read Vac	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Switching Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Readings	Unknown Operations	0	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Bushing Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Foundation Condition	Good	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	General Comments		
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Grounds in Place?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/13/2023 7:23	Distribution	Clifton Quarterly Inspection	BK001947	BreakerVacuum	CL-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.5790	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	290.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	100	°C
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	11368.80	kw
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1936	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	57741	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	57730	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	232	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	232	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	114.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	122.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	123.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations VCB New	4	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	4	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	7	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations VCB New	7	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	83.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	90.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	102.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	166	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	166	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations	6	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations VCB New	4	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps A Ø	170.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AF	229	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AL	229	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps B Ø	117.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps C Ø	128.0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Maintenance Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations This Read Vac	2	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Switching Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Unknown Operations	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations A Ø	1	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations B Ø	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations C Ø	1	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations Ground	0	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushing Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.640	millivolts
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	°F
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 15:25	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	62	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	44.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	9	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39278	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36132	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37971	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2592.00	kw
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5400	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 13:05	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2133	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	420116	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	420116	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	17646	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2061	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	17646	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations VCB New	10	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	10	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	2	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Readings	9 Month Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	3	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	11.96	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	9 Month Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Readings	9 Month Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Readings	9 Month Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	9 Month Operations VCB New	3	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Readings	9 Month Operations VCB New	8	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	9 Month Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BCH001598	Charger	NA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002108	BreakerVacuum	NA-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002107	BreakerVacuum	NA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002106	BreakerVacuum	NA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002105	BreakerVacuum	NA-1270	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002104	BreakerVacuum	NA-1269	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002103	BreakerVacuum	NA-1268	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002102	BreakerVacuum	NA-1267	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002101	BreakerVacuum	NA-1266	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002100	BreakerVacuum	NA-1265	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	BK002099	BreakerVacuum	NA-1264	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
9/14/2023 8:08	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	229	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	1	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	1	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	229	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	32.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	35.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	33.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	1	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	202.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	168.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	155	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	155	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	159.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	5	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	5	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	174	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	174	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	5	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	66.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	77.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	128.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	181.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	183.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	127	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	127	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	182.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	155	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	155	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	161	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	161	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	537.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	462.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	440.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	50389	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	50389	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	14R	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	3744	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	63	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	68	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	68	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	371	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	371	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	316.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	326.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	378.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	351	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	351	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	108.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	121.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	89.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	44.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	42.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	67.08	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	6	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	6	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	17.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	15	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations VCB New	3	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	12	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	480	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	480	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	3	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	3	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	3	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	416	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	416	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	123.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	156.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	172.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	372	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	372	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	230	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	230	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	576.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	649.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	630.0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3859	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	106836	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	106836	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	75	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	40	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	2 pieces of animal guard on the ground	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments	1 bulb on outside is bad	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments	1 yard ight out	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BCH001618	Charger	WO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	126.4	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	General Comments		
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 14:21	Distribution	Worthington Quarterly Inspection	BAT001691	Battery	WO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	65	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	30.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	28.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	32.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	42	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	42	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	361	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	361	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	100.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	100.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	100.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99857	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99857	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	90.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	90.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	90.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	60.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99967	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99967	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	55.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	50.0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	314	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	314	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	288.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	296.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	331.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	123	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	123	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Month Ops New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	52	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AF	52	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	44.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	45.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	45.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Month Ops New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Month Ops New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	132.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	137.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	131.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	10	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	361	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	361	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments	A Phase TOC	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	13	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	242.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	242.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	249.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	4740	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Month Ops New	4727	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations This Read AM	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	878	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	878	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Month Ops New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	147.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	123.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	134.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	52	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	52	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Month Ops New	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Month Ops New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99989	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99989	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Month Ops New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	152	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	152	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	849.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	829.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	889.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	19149	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	19149	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6R	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	16R	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	1R	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1171	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	34	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	62	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	51	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	120	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	51	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	118	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	120	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	51	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	44	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	100	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	290.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	265.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	445.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	460.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	512	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	512	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1878	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1878	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	488	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	488	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	748	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	748	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Month Ops New	6	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	6	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	93.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	92.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	83.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	278	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	278	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	219.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Month Ops New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	192.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	204.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	90.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	70.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	100.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	449	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	449	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	367	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	367	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Month Ops New	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	30.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	28.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	32.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	426	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	426	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	10.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	11.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	10.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	130.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	465	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	465	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Month Ops New	11	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	11	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	98.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	142.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001351	PowerFuse	MG-14KV TR 7 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001350	PowerFuse	MG-14KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF001349	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	245	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	245	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	229.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	238.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	239.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	605	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	605	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	120.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	139.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	98.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	6	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Month Ops New	6	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Month Ops New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	351	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	351	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	1.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	1.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	1.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	2.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	2.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	4.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Month Ops New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	380	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	380	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments	2-4ft 2pin lights	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Month Ops New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	125	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	125	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	111	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	111	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	120	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	120	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Max	36	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	All Connections OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Operation Checked?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Time Delay	0	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Operations Since Last Insp	4743	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Min Tap Position	4L	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Max Tap Position	6R	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Current Tap Position	1L	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Left Counter	20366	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Found Counter	20366	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	36	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Time Delay	0	Seconds
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Operation Checked?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	All Connections OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	2664	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Min Tap Position	3L	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Max Tap Position	8R	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Found Counter	17153	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Left Counter	17153	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Pumps Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	General Comments	no fans or pumps, remove from insp	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Fans Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000275	GroundTransformer	MG-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Fans Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Pumps Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	General Comments	no fans or pumps, remove from insp	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000276	GroundTransformer	MG-GND TR 7	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Fans Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Pumps Operational?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	General Comments	no pumps or fans, remove from insp	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	TX000300	GroundTransformer	MG-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	436	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	6	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	436	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	6	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	14	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations VCB New	8	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	58.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	51.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	104.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.1	VDC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.1	VDC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.4	amps
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	494	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	494	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	211.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	173.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	233.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.8	VDC
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	179.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations VCB New	9	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	9	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	132.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	129.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	442	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	442	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments	ok	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	379	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	379	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	97.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	149.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	153.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	69	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	69	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	7	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	7	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	68	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	68	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	10	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	10	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002326	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002325	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations Counter AF	136	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations Counter AL	136	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps A Ø	177.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps B Ø	174.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Amps C Ø	174.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001860	BreakerVacuum	MG-14KV TR 6	VCB Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations Counter AL	113	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Operations Counter AF	113	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001855	BreakerVacuum	MG-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Maintenance Operations	8	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations Counter AF	151	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations Counter AL	151	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Operations This Read Vac	9	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps C Ø	39.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps B Ø	39.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	Amps A Ø	39.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Readings	9 Month Operations	11	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001856	BreakerVacuum	MG-1332-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations Counter AL	128	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Operations Counter AF	128	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps C Ø	42.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps B Ø	42.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	Amps A Ø	43.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	560.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	504.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	601.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	283	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	263	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001857	BreakerVacuum	MG-1333-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations Counter AL	146	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Operations Counter AF	146	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps C Ø	36.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps B Ø	37.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	Amps A Ø	37.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001858	BreakerVacuum	MG-1334-A	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps C Ø	42.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations Counter AL	116	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps B Ø	42.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Operations Counter AF	116	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Amps A Ø	43.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001859	BreakerVacuum	MG-1335-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations Counter AL	130	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Operations Counter AF	130	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps A Ø	36.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps B Ø	37.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Amps C Ø	37.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001922	BreakerVacuum	MG-1336-A	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	9 Month Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations Counter AF	141	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations Counter AL	141	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps A Ø	31.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps B Ø	31.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Amps C Ø	32.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001924	BreakerVacuum	MG-14KV BUS TIE SEC 6-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations Counter AL	129	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Operations Counter AF	129	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps A Ø	158.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps B Ø	154.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Amps C Ø	155.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001862	BreakerVacuum	MG-14KV TR 7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	9 Month Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations Counter AL	112	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Operations Counter AF	112	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001863	BreakerVacuum	MG-GND TR 7	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	9 Month Operations	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps A Ø	29.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps B Ø	27.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Amps C Ø	29.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations Counter AL	176	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Operations Counter AF	176	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001861	BreakerVacuum	MG-14KV BUS TIE SEC 7-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments	ok	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations This Read Vac	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations Counter AL	123	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Operations Counter AF	123	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Maintenance Operations	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps C Ø	28.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps B Ø	30.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	Amps A Ø	30.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Readings	9 Month Operations	5	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001864	BreakerVacuum	MG-1332-B	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps A Ø	31.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps B Ø	29.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Amps C Ø	30.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations Counter AF	153	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations Counter AL	153	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001865	BreakerVacuum	MG-1333-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps A Ø	25.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps B Ø	24.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Amps C Ø	25.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations Counter AF	116	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Readings	Operations Counter AL	116	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations VCB New	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	145	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	145	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001866	BreakerVacuum	MG-1334-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps A Ø	25.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps B Ø	24.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Amps C Ø	23.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations Counter AF	109	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations Counter AL	109	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	172	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	172	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	2	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	38.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	54.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	39.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001867	BreakerVacuum	MG-1335-B	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps A Ø	21.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps B Ø	20.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Amps C Ø	20.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations Counter AF	113	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations Counter AL	113	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Operations This Read Vac	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Switching Operations	1	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	9 Month Operations VCB New	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps A Ø	325.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps B Ø	287.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Amps C Ø	294.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations Counter AF	129	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations Counter AL	129	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	9 Month Operations	3	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	137.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	152.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	239	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	239	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	132.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	243	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	243	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	102.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	36.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	60.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations VCB New	2	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	2	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	198	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	189	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	96.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	64.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	42.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	225	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	225	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations VCB New	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	151	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	366.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	303.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	151	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	274.0	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	1	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	28297	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1401	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	28297	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	51	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	53	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	64	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	61	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	37	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1775	psi
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	11802	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	11802	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1002	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 10:19	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001868	BreakerVacuum	MG-1336-B	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK001869	BreakerVacuum	MG-14KV BUS TIE SEC C-5	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	95	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	95	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	12	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations VCB New	12	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:10	Distribution	Magazine Quarterly Inspection	BK002350	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1094	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	94123	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	94123	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	189	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	189	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	6	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments	8" diameter tree on back fence, notified supervisor, RK called to repair	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	148.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	160.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	90	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	90	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	150.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations VCB New	28	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	28	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations VCB New	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	196.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	182.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	180.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	96	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	96	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations VCB New	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	30.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	94	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	0.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	94	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	66	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	66	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations VCB New	3	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	36.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	44.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	25.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	105	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	105	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	19.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	17.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	27.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	12	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations VCB New	12	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	91	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	91	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations VCB New	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	450.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	380.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	401.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	6	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	112	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	112	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps C Ø	137.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps B Ø	133.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Amps A Ø	161.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Switching Operations	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	9 Month Operations VCB New	12	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	9 Month Operations	13	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations This Read Vac	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations Counter AF	21	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Readings	Operations Counter AL	21	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	9 Month Operations	17	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	9 Month Operations VCB New	15	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps C Ø	101.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps B Ø	78.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Amps A Ø	94.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Switching Operations	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations This Read Vac	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations Counter AL	131	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Operations Counter AF	131	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	225	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	225	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations VCB New	2	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations Counter AL	18	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Operations Counter AF	18	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps C Ø	28.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps B Ø	30.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Amps A Ø	34.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Readings	9 Month Operations VCB New	10	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	9 Month Operations	15	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	9 Month Operations VCB New	14	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps A Ø	33.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps B Ø	25.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Switching Operations	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations This Read Vac	1	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations Counter AL	75	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Operations Counter AF	75	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations C Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Amps C Ø	35.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	156	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	156	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations VCB New	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	5	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps A Ø	28.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	9 Month Operations VCB New	16	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps B Ø	60.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Amps C Ø	55.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations Counter AL	30	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Operations Counter AF	30	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations VCB New	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	2	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	109	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	109	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	9 Month Operations	12	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	9 Month Operations VCB New	12	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps A Ø	341.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Unknown Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Switching Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations Counter AL	30	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Operations Counter AF	30	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps B Ø	310.0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Readings	Amps C Ø	347.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	37	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	36	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	42	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	37	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	43	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	18728	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	18728	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1299	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations VCB New	6	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	77	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	77	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	2730	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	2730	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1126	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations VCB New	4	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	165	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	165	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	1	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	188	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations VCB New	1	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	50	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	70	°F
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002195	BreakerVacuum	MK-1295	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002196	BreakerVacuum	MK-1296	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002197	BreakerVacuum	MK-1297	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002198	BreakerVacuum	MK-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	General Comments		
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002199	BreakerVacuum	MK-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 10:17	Distribution	Manslick Quarterly Inspection	BK002206	BreakerVacuum	MK-12KV TR 1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1239	BreakerVacuum	WS-1471-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2023 7:29	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/12/2023 12:09	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Month Ops New	12	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	12	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	9.71	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	20.63	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	12.13	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1325	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1325	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Month Ops New	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	869	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	869	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	100	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments	ok	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	585	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	585	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	9	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Month Ops New	9	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	219	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	219	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Month Ops New	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	49	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	54	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	530	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	530	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	61	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1012	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	94137	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	94137	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	NotOK	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/11/2023 14:23	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	5.58	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations VCB New	2	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	2	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	146	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	146	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	5	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	233	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	233	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	95	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	111	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	103	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	22.32	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	36.67	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	24.71	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations VCB New	5	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations VCB New	2	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	147	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	201	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	201	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	26.31	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	2	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	156	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	156	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	20.73	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	31.09	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations VCB New	7	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	7	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	31.09	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	42	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	12	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	14	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	216	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	216	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	254	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	275	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	297	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations VCB New	1	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	1	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	173	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	173	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1711	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	52423	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	52423	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	39	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	60	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	60	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	9 Month Operations GCB New	1	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	65	psi
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2023 14:31	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	80	°F
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments	2 fans not operational	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	1	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	1	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	139	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	139	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	1.15	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	1.15	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	1.15	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	2	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.6	VDC
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Negative DC Ground	69.5	VDC
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BAT001671	Battery	008-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	134.4	VDC
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments	update AF/AL float voltage	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.0	VDC
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.0	VDC
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments	update cascade. no fuses used at sub	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments	fence panel needs repair from vandalism	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 14:04	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	72122	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	316951	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments	upper arm stops resetting at R2	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128430	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9504	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2280.96	kw
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments	needs new gauge	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	120.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	156	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	156	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	12	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations VCB New	12	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	110.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	100.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	105.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	100.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	154	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	154	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	1	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	80.0	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.080	millivolts
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.3	VDC
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 13:54	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.4	VDC
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.000	millivolts
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	953	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	229387	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	229387	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	41986	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37490	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.80	MegaWatts
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	1.00	MegaWatts
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35221	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	324925	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	324925	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	744	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.10	MegaWatts
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.00	MegaWatts
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9590.40	kw
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	90	°C
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9990	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments	temp gauge needs new lense	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18563	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18563	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	2	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	347	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	240.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	180.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	160.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	347	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	2	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	9	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations VCB New	8	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	3.78	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	6.04	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	5.66	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	160.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	198.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	169.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	1	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments	A-G	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	1	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	206	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	206	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	451	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	130.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	451	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	115.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	235.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	180.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	100.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	120.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	317	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	317	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	5.07	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments	B-G inst, B-G T, C-G	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	210	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	210	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	10.13	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	3	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	108.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	98.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	88.0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	1.89	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	3.02	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	2	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	1	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	2.64	%
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations VCB New	9	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	12	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	437	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	437	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	140.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	120.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	130.0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	1	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Month Ops New	0	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Seventh Street Quarterly Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 13:45	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Switching Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations This Read Vac	6	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AL	181	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AF	181	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Maintenance Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations Ground	2	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations B Ø	2	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations A Ø	2	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps C Phase V	10.39	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps B Phase V	20.78	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps A Phase V	20.78	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps C Ø	172.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps B Ø	180.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps A Ø	168.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations	7	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Unknown Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	278	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	278	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	74.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	80.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	75.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	1	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	304	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	304	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	4	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations VCB New	4	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	41.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	45.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	60.0	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1292	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	208704	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	208691	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	Back up relay/ VRR alarm is in	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Replace Next Maint	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments	Gasket is cracking and LTC tank is seaping	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.8916	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	59	°C
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	8559.36	kw
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.870	millivolts
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 15:08	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	signs of oil leaks by the temp guages. Pressure relief alarm is in.	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Oil leak on low side throat of trans.	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AL	371	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AF	371	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps C Ø	64.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps B Ø	65.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps A Ø	60.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	9 Month Operations VCB New	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	9 Month Operations	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	58	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	58	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	43	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002218	BreakerVacuum	470-5038-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	7R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	81	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	81	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	4L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	67	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	328	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	17.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	18.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	328	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	18.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	2	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	95.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	105.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	100.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	2	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	318	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	318	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	284	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	284	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	40.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	40.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	40.0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations VCB New	4	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	4	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002219	BreakerVacuum	470-5038-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	457.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	427.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	447.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	346	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	346	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002220	BreakerVacuum	470-5037-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	44516	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	186	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	186	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1988	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002222	BreakerVacuum	470-5037-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50873	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations VCB New	8	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	83.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	80.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	85.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	8	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	96	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	96	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002226	BreakerVacuum	470-7-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7862.40	kw
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8190	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	125.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	124.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	122.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	529	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	529	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002225	BreakerVacuum	470-7-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	90.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	162	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	87.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	92.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	162	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	0	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments	C Phase IOC	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	8.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	9	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	136.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	137.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	190	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	190	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations VCB New	8	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	142.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002224	BreakerVacuum	470-5036-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 13:02	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002227	BreakerVacuum	470-5036-3	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	155	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	155	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	General Comments	Under Construction	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002223	BreakerVacuum	470-6-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002221	BreakerVacuum	470-6-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	280	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	10L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	49962	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	49962	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	OK	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002216	BreakerVacuum	470-5035-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	218	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	10	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	81579	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	81579	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002217	BreakerVacuum	470-5035-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	50	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	80	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	General Comments	ABC IOC	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations C Ø	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations Counter AF	62	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations B Ø	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations Counter AL	62	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations This Read Vac	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	9 Month Operations	17	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	9 Month Operations VCB New	11	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps A Ø	132.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps B Ø	101.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps C Ø	114.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Fault Operations A Ø	2	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002230	BreakerVacuum	470-5-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002215	BreakerVacuum	470-5-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	OK	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	70.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	70.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	70.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	237	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	237	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	226	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	226	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	60.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	35.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	55.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	210.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	210.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	220.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	218	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	218	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	6R	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2R	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	22160	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	22160	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	568	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	252	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	252	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	75.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	70.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	65.0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	1345	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	19408	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	10R	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	19408	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	15.0	psi
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	All Connections OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Operation Checked?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	10387.20	kw
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	1.0820	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	60032	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	60032	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	-2	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	85	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 12:49	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002229	BreakerVacuum	470-5014-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	General Comments	Under Constuction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002228	BreakerVacuum	470-5014-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002232	BreakerVacuum	470-4-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	242	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	242	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	548	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	5	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	245.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	245.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	245.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	548	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002231	BreakerVacuum	470-4-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	215	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	215	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	5	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	170.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	170.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	170.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002241	BreakerVacuum	470-5013-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	72.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	73.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	73.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	208	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	208	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002239	BreakerVacuum	470-5013-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	8	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	240.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	240.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	240.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	223	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	223	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002234	BreakerVacuum	470-3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	500.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	500.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	500.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	1	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	348	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	348	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002238	BreakerVacuum	470-3-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	2	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	243	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	243	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	465	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	465	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	55.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	55.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	55.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	13	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	511	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	511	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	450	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	3	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	450	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	218.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	218.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	218.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	367	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps A Ø	160.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps C Ø	160.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	367	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps B Ø	160.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	366	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	366	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	384	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	384	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AL	409	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AF	409	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps C Ø	5.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps B Ø	5.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps A Ø	5.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps C Ø	128.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps A Ø	130.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps B Ø	140.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AL	377	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AF	377	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AL	383	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AF	383	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps C Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps B Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps A Ø	90.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AL	376	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AF	376	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps C Ø	30.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps B Ø	30.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps A Ø	29.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AL	398	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AF	398	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps B Ø	0.0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002240	BreakerVacuum	470-5012-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002237	BreakerVacuum	470-5012-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002236	BreakerVacuum	470-2-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002242	BreakerVacuum	470-2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002233	BreakerVacuum	470-5011-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	BK002235	BreakerVacuum	470-5011-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	All Connections OK?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	LTC Operation Checked?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000997	LTCControl	470-6	LTC Control Insp	VRR Time Delay	0	Seconds
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	General Comments	Under Constuction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC As Found Counter	715	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC As Left Counter	715	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000139	LTCMechanism	470-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	264500	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	264500	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1082	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	General Comments	Under Constuction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000320	WithLTC	470-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Time Delay	0	Seconds
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	LTC Operation Checked?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000996	LTCControl	470-5	LTC Control Insp	All Connections OK?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.20	MegaWatts
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.20	MegaWatts
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC As Found Counter	786	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	General Comments	Under construction Being Built	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC As Left Counter	786	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Month Ops New	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	General Comments	Under Construction. Being Built	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000138	LTCMechanism	470-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Month Ops New	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	3.2	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	220.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	220.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	180.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	6	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	6	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	General Comments	Under Construction. Being Built	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000319	WithLTC	470-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	160.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	220.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	400.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Month Ops New	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	502	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	502	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Month Ops New	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	378	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	378	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	150.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	200.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	210.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Time Delay	30	Seconds
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Base Voltage AL	118.8	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	VRR Base Voltage AF	118.8	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	LTC Output Voltage Level	117.6	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	LTC Operation Checked?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000967	LTCControl	470-4	LTC Control Insp	All Connections OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	520	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.14	%
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	140.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	310.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	320.0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Month Ops New	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	520	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Current Tap Position	10L	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC As Left Counter	2008	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Min Tap Position	10L	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Max Tap Position	10L	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC Operations Since Last Insp	718	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	LTC As Found Counter	2001	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	9630	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	9630	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	494	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	27	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	27	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	General Comments	No Load	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCM000131	LTCMechanism	470-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	General Comments	No Load	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Oil Temp Max	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Oil Temp Present	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Totalizer Meter Multiplier	21000	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Winding Temp Max	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	Winding Temp Present	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X1 Winding Temp Max	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X1 Winding Temp Present	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X2 Winding Temp Max	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X2 Winding Temp Present	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X3 Winding Temp Max	41	°C
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Readings	X3 Winding Temp Present	41	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	58	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	42	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	165.00	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.20	MegaWatts
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.60	MegaWatts
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.40	MegaVars
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.30	MegaVars
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 11:56	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000312	WithLTC	470-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	All Connections OK?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	General Comments	Under Construction Not in Service.	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	LTC Operation Checked?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	LTCC000995	LTCControl	470-3	LTC Control Insp	VRR Time Delay	0	Seconds
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Pumps Operational?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	General Comments	Under Construction Not in Service	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	TX000318	WithLTC	470-3	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	CH000541	ControlHouse	470-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	All Identified and Legible?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Ground Connections Intact?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	ST000863	Structure	470-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	General Comments	Under construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	FE000901	Fence	470-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Ambient Temp	75	°F
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	General Comments	Under Construction	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Landscape Good Condition?	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	SPCC Strongwell Containment OK	n	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Trench Covers in Place	N/A	Need size info and qty
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
9/8/2023 15:52	Distribution	Glendale Industrial Quarterly Inspection	YD000972	Yard	470-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1371	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	213046	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	213036	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	22953	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	22953	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	212	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	5	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	195	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	195	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	103.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	112.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	103.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	1	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	191	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	191	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	1	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	4	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations VCB New	3	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	97.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	106.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	92.0	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	48	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.6180	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Present	43	°C
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	4449.60	kw
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.510	millivolts
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	Limbs growing over top of fence	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 13:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	189986	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	189986	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	12R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	45	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	75	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	55	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	155.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	85	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	85	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	80	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	50	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations This Read Oil	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	373	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	373	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	7	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	9 Months Operations OCB New	7	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	267605	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	267605	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	316	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AF	142	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AL	142	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	120.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	139.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	125.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	89	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	89	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	130.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	126.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	155.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	65	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	65	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations	9	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations VCB New	9	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AL	321	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AF	321	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps C Ø	59.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps B Ø	61.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps A Ø	60.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps C Ø	137.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps B Ø	160.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps A Ø	136.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AF	45	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AL	45	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations VCB New	4	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations	4	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps A Ø	137.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps B Ø	134.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps C Ø	120.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AL	28	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AF	28	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations This Read Vac	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AL	57	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AF	57	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	General Comments	B Phase IOC	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations	11	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps A Ø	137.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps B Ø	135.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps C Ø	121.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations B Ø	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AL	48	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AF	48	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations VCB New	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations	6	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps C Ø	124.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps B Ø	118.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps A Ø	118.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps C Ø	447.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AF	42	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AL	42	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps B Ø	530.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps A Ø	493.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations VCB New	3	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations	3	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	83	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	83	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps A Ø	141.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps B Ø	153.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps C Ø	148.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AF	81	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AL	81	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations	5	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AL	310	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations	9	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations VCB New	9	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps A Ø	388.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps B Ø	315.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps C Ø	320.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AF	310	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AL	346	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AF	346	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AF	334	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AL	332	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AL	326	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AF	326	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	9 Month Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps A Ø	90.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps B Ø	74.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps C Ø	70.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AF	29	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AL	29	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	9 Month Operations	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps A Ø	79.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps B Ø	78.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps C Ø	72.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AF	31	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AL	31	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AL	42	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps A Ø	87.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps B Ø	81.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps C Ø	89.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AF	42	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	9 Month Operations	2	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	9 Month Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations Counter AL	16	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Operations Counter AF	16	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps A Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps B Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps C Ø	0.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Unknown Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Switching Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	9 Month Operations	12	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations Counter AL	51	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations Counter AF	51	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	General Comments		
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	9 Month Operations VCB New	12	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps A Ø	385.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps B Ø	337.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps C Ø	330.0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/8/2023 13:18	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Maintenance Operations	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AF	223	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AL	223	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations This Read Vac	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Switching Operations	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Unknown Operations	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps C Ø	42.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps B Ø	32.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps A Ø	35.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	313	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	313	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	47.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	65.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	72.0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	1	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46786	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	46786.0	volts
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42622	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51817	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments	AL 124 Vac	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12674	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments	AL 123.9 Vac	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12403	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1100	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5328.00	kw
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	46	°C
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments	AL 123.8Vac	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12401	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 12:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments		
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1008.00	kw
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	180.00	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4200	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	204.17	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	62.0	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	86.0	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	67.0	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	maint op upodate AC/AMI	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	207	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 10:39	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Maintenance Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations Ground	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations C Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations B Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AF	168	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AL	168	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations This Read Vac	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Switching Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Unknown Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations A Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps C Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps B Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps A Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	9 Month Operations	1	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations Ground	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations C Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations B Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations A Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Maintenance Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AF	200	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AL	200	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations This Read Vac	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Switching Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Unknown Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps C Ø	47.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps B Ø	42.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps A Ø	42.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	9 Month Operations	2	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations Ground	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Maintenance Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AF	156	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AL	156	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations This Read Vac	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations C Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations B Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations A Ø	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps C Ø	48.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps B Ø	44.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps A Ø	44.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	9 Month Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Switching Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Unknown Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Operations Since Last Insp	576	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Min Tap Position	5L	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Current Tap Position	3L	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Left Counter	4803	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Found Counter	4803	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Present	35	°C
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Max	45	°C
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Reading	.0650	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Present	40	°C
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Max	50	°C
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	LTC Totalizer Reading	1170.00	kw
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Unknown Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Switching Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations This Read SF6	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	9 Month Operations GCB New	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AL	1026	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AF	1026	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Num Operations Last 9 Months	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Maintenance Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Fault Operations	0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps C Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps B Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps A Ø	0.0	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Pressure	67	psi
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Ambient Temperature	71	°F
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.8	VDC
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	115	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 10:22	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	48.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	63.0	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	47	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62884	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	16L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54122	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	56451	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7410	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1778.40	kw
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	Fence and barbed wire rusty, gaps under fence . Fence has hole in the back near transformer.	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/8/2023 10:53	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations	2	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AL	389	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AF	389	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Unknown Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AL	307	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AF	370	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AF	307	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AL	307	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Unknown Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations C Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations Ground	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations B Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations A Ø	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps C Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps B Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps A Ø	0.0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	9 Month Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Maintenance Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AF	332	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AL	332	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Switching Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Unknown Operations	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	276708	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	276708	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	448	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.80	MegaVars
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.10	MegaVars
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.90	MegaWatts
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.10	MegaWatts
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	80	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	80	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	80	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	2	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	482	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	19.09	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	482	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	2	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	180.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	180.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	180.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	20	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Month Ops New	18	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	316	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	316	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Month Ops New	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	386	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	386	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	20.0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Month Ops New	0	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2023 9:45	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	438	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	438	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	678	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	678	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	653	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	653	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	5	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	1	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	9 Month Operations GCB New	4	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 14:53	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	10.72	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	10.27	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	7.59	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	320	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	220	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	333	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	5.99	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	435	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	435	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	2	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	336	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	328	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	323	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	8.93	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	8.04	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	7.6	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations VCB New	22	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	22	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	435	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	435	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	427	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	427	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	340	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	240	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	308	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	6.4	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	7.68	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	6.4	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	92	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	89	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	98	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	1.28	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	242	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	242	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	1	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	202	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	202	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	148	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	131	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	151	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	1.71	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	2.13	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	155	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	155	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	548	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	480	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	520	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	1.03	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99988	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99988	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments	open	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations VCB New	5	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	5	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	640	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	600	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	661	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	262	
9/7/2023 18:50	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	262	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	2374	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	4L	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	12R	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	9R	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	143751	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	143740	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AL	125	VAC
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AF	125	VAC
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	All Connections OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	60	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	80	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.539	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	78	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	58	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	14774.4	kw
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	316801	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	316812	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	7R	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	11R	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	5L	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	1909	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	10756.8	kw
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	48	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	58	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.747	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	55	°C
9/7/2023 18:50	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	69	°C
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments	ok	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	108	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	108	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	246.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	223.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	220.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	131	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	131	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	4	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	151	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	151	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	14	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations VCB New	13	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	18.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	19.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	19.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	2	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	237.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	240.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	237.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	190	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	190	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	209	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	209	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	1	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments	ok	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	52	°C
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121533	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121533	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	5	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	5	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	5	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	55	°C
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptible	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 15:14	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	16.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	34	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	29	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	81.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	75.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	10	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	15.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	14.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	14.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	26	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	47.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations	5	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Unknown Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations C Ø	3	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AF	183	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AL	183	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations This Read Vac	3	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps C Ø	129.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps B Ø	121.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps A Ø	125.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Found Counter	14676	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Left Counter	14676	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Current Tap Position	1R	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Operations Since Last Insp	488	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	535.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	529.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	518.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	214	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	214	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Max	59	°C
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Reading	.6264	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Present	44	°C
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Max	53	°C
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	LTC Totalizer Reading	4510.08	kw
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Present	44	°C
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	10.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	11.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	13.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	1	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	269	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	269	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	316	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	411.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	402.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	384.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	316	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	45.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	47.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	74.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	202	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	202	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 14:41	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	4	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	321.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	305.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	348.0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	6.98	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	233	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	233	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	2	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	0	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	1986	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	8L	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	16R	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	4R	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	83491	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	83491	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	1138.50	kw
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	65	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	65	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	1500	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.7590	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	75	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	50	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	208512	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	208512	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	12R	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	1470	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.1772	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	55	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8475.84	kw
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	84	°F
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 14:39	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	9 Month Operations GCB New	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Fault Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Num Operations Last 9 Months	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations Counter AF	91	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations Counter AL	91	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Operations This Read SF6	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Pressure	68	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	General Comments	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Ambient Temperature	80	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000963	LTCControl	805-2	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	33	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Operations Since Last Insp	1344	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Min Tap Position	7L	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Max Tap Position	8R	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC Current Tap Position	4R	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC As Left Counter	3127	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	LTC As Found Counter	3127	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000127	LTCMechanism	805-2	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	LTC Totalizer Reading	7824.00	kw
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Oil Temp Max	40	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Oil Temp Present	37	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Totalizer Meter Reading	.3260	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Winding Temp Max	45	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	Winding Temp Present	42	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X2 Winding Temp Present	42	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000303	WithLTC	805-2	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations Counter AL	195	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	9 Month Operations	11	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	9 Month Operations VCB New	11	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps A Ø	315.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps B Ø	266.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Amps C Ø	307.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Readings	Operations Counter AF	195	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	1	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	36.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	36.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	42.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	274	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	274	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001920	BreakerVacuum	805-2	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps C Ø	133.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps B Ø	135.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Amps A Ø	127.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	9 Month Operations VCB New	7	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	9 Month Operations	7	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations Counter AF	169	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations Counter AL	169	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Readings	Unknown Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	9 Month Operations	5	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps A Ø	179.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps B Ø	169.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps C Ø	185.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps B Phase V	15.98	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations B Ø	3	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AF	204	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AL	204	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations This Read Vac	3	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Switching Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001916	BreakerVacuum	805-0659	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations Counter AL	274	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Operations Counter AF	274	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps C Ø	105.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps B Ø	61.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Amps A Ø	74.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	9 Month Operations VCB New	14	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Readings	9 Month Operations	14	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001913	BreakerVacuum	805-0604	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	9 Month Operations	1	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps A Ø	154.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps B Ø	155.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps C Ø	158.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AF	172	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AL	172	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Switching Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps C Ø	65.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations Counter AF	167	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations Counter AL	167	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps B Ø	67.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Amps A Ø	109.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	9 Month Operations VCB New	10	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Readings	9 Month Operations	10	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Unknown Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Switching Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AL	185	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AF	185	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps C Ø	1.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps B Ø	2.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps A Ø	1.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001915	BreakerVacuum	805-0658	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	9 Month Operations	9	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	9 Month Operations VCB New	9	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps A Ø	0.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps B Ø	0.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Amps C Ø	0.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations Counter AF	170	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations Counter AL	170	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Readings	Unknown Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	172	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	172	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	398.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	362.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	365.0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	3	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001921	BreakerVacuum	805-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Operations A Ø	2	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps C Ø	40.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations Counter AF	202	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations Counter AL	202	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Operations This Read Vac	2	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps B Ø	52.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Amps A Ø	41.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	9 Month Operations	11	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	9 Month Operations VCB New	9	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001918	BreakerVacuum	805-0664	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps A Ø	3.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps B Ø	4.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Amps C Ø	13.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations Counter AF	212	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations Counter AL	212	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	9 Month Operations VCB New	9	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	9 Month Operations	9	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Readings	Unknown Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	41300	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	41300	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	119	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	11R	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001912	BreakerVacuum	805-0603	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations Counter AL	167	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Operations Counter AF	167	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps C Ø	128.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps B Ø	120.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Amps A Ø	116.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	9 Month Operations VCB New	6	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Readings	9 Month Operations	6	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001917	BreakerVacuum	805-0663	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations Counter AL	189	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Operations Counter AF	189	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps C Ø	94.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps B Ø	135.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Amps A Ø	134.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	9 Month Operations VCB New	10	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Readings	9 Month Operations	10	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	9666.00	kw
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.5370	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	50	°C
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001914	BreakerVacuum	805-0605	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Unknown Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Switching Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations Counter AL	212	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Operations Counter AF	212	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	9 Month Operations	8	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	9 Month Operations VCB New	8	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps A Ø	301.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps B Ø	315.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Amps C Ø	278.0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Readings	Maintenance Operations	0	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001919	BreakerVacuum	805-1	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCC000959	LTCControl	805-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	81	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Operations Since Last Insp	1379	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Max Tap Position	9R	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC As Left Counter	4178	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	LTC As Found Counter	4178	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	81	°F
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	LTCM000126	LTCMechanism	805-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Winding Temp Present	35	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Winding Temp Max	35	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Totalizer Meter Reading	.3870	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Oil Temp Max	35	°C
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	LTC Totalizer Reading	9288.00	kw
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	TX000290	WithLTC	805-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 14:26	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations This Read SF6	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations Counter AL	142	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Operations Counter AF	142	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Num Operations Last 9 Months	6	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Maintenance Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	Fault Operations	0	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Readings	9 Month Operations GCB New	6	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Ambient Temperature	80	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	General Comments	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Pressure	67	psi
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.5	amps
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BCH001538	Charger	805-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	129.0	VDC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	BAT001614	Battery	805-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	80	°F
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
9/7/2023 14:30	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	129.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	111.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	95.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	191	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	191	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	196	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	196	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	25.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	28.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	25.0	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1741	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	9R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	5R	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	420623	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	420612	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.8376	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	4020.48	kw
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.730	millivolts
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BCH001554	Charger	843-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	207.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	205.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	185	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	191.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations VCB New	9	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	9	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	185	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	1	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	60.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	52.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	57.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	184	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	184	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	221.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	227.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	235.0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Not Good Replaced	check oil cup
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	34	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	8L	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	4L	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	873	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	61450	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	61450	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.6846	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	34	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	34	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	44	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	52	°C
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	6572.16	kw
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments	All positive posts had corrosion	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.1	VDC
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 13:01	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	9 Month Operations	128	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	9 Month Operations VCB New	127	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps A Ø	218.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps B Ø	219.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Amps C Ø	241.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations C Ø	1	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	General Comments	C Phase IOC	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations Counter AF	146	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations Counter AL	146	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Operations This Read Vac	1	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Readings	Unknown Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Month Ops New	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	3	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	1	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	1	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Month Ops New	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	130.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	121.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	140.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	977	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	977	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Month Ops New	4	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	662	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	662	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	4	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	40.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	43.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	40.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	585	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	585	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Month Ops New	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	13.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	9.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	11.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	18	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	18	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Month Ops New	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	78.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	75.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	74.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	240.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	225.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	240.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Month Ops New	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	420	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	420	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	2	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	186070	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	186070	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	801	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	300	psi
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	General Comments	none	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCC000097	LTCControl	BI-Yard	LTC Control Insp	All Connections OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC As Found Counter	15301	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC As Left Counter	15301	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Current Tap Position	2R	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Max Tap Position	8R	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	LTC Operations Since Last Insp	565	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	LTCM000021	LTCMechanism	BI-Yard	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Unknown Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations Counter AL	113	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Operations Counter AF	113	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps C Ø	690.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps B Ø	690.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Amps A Ø	650.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	General Comments	VC wrote down wrong on last inspection.	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	9 Month Operations	99	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Readings	9 Month Operations VCB New	99	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.5	amps
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002080	BreakerVacuum	BI-12KV TR 1	VCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	9 Month Operations	84	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	9 Month Operations VCB New	84	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps A Ø	87.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps B Ø	89.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Amps C Ø	96.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations Counter AF	104	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations Counter AL	104	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Operations This Read Vac	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Readings	Unknown Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002081	BreakerVacuum	BI-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations This Read Vac	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Unknown Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps A Ø	100.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps B Ø	106.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Amps C Ø	101.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	9 Month Operations VCB New	78	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	9 Month Operations	78	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations Counter AF	97	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Readings	Operations Counter AL	97	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002082	BreakerVacuum	BI-1218	VCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002083	BreakerVacuum	BI-1219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Switching Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Unknown Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations This Read Vac	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations Counter AL	108	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Operations Counter AF	108	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Maintenance Operations	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations Ground	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations C Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations B Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Operations A Ø	0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps C Ø	242.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps B Ø	265.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Amps A Ø	240.0	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	9 Month Operations VCB New	88	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Readings	9 Month Operations	88	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	General Comments		
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 12:18	Distribution	Bishop Quarterly Inspection	BK002084	BreakerVacuum	BI-1220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	169	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations This Read Vac	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	169	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	3	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	55.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	61.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	60.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	162	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	162	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations This Read Vac	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	52.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	48.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	51.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations VCB New	1	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	1	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	72.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	81.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	180	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	180	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	87.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	3	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	5	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations VCB New	4	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	312.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	300.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	325.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	1	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	180	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	180	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	1	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations VCB New	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	490.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	490.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	490.0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	226	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	226	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Left Counter	25660	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Found Counter	25660	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Operations Since Last Insp	585	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	13374.00	kw
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	58	°C
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	58	°C
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.7430	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	65	°C
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	65	°C
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 11:22	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	801	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	7736	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	7736	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	119.4	VAC
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	LTC Totalizer Reading	188.00	kw
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Max	42	°C
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Present	38	°C
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Reading	.0470	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments	Oil level gage seeping	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 10:14	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Operations Counter	181414	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	29.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	361	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	1382	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	139313	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	139313	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	All Connections OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	2601.60	kw
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.2710	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 7:25	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations VCB New	5	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	6	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	125.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	100.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	120.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	256	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	256	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	1	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	1	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Switching Operations	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations This Read Vac	3	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AL	176	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AF	176	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Maintenance Operations	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations Ground	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations C Ø	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations B Ø	3	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps B Phase V	13.31	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps C Ø	185.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps B Ø	220.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps A Ø	195.0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	9 Month Operations VCB New	2	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	9 Month Operations	5	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Unknown Operations	0	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9072	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Max Tap Position	12R	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Current Tap Position	9R	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10428	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Max Tap Position	15R	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Current Tap Position	11R	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10205	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0915	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7858.80	kw
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.5	VDC
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/7/2023 7:17	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	173	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	173	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	3	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	660.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	80.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	65.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	188	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	188	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A Ø	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	30.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	35.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	30.0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	3	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations VCB New	3	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	31807	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	31807	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	3R	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	6L	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	879	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	3071.52	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	60	°C
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	60	°C
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.4266	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/7/2023 7:04	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	1.48	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	1.26	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	1.19	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations VCB New	13	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	4.77	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	6.56	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	2.98	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	1.22	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	1.53	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	.31	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations VCB New	3	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	1.48	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	.85	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty A Ph V	3.05	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	.6	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	9.54	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	9.54	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	13.71	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	13.71	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations VCB New	8	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.4	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.4	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations VCB New	1	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	8.35	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	7.75	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	4.77	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations VCB New	5	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations VCB New	2	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	7.16	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	9 Month Operations VCB New	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty C Ph V	.85	%
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations This Read Vac	0	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	221	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	221	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	4	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	66.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	65.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	52.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations VCB New	4	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	231	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	231	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	1	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	1	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	76.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	86.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	67.0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations VCB New	3	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	4	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16084	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32483	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30242	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4934.40	kw
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	48	°C
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5140	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	76	°F
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	79	°F
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/6/2023 14:42	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Unknown Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Switching Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations This Read Vac	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AL	167	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AF	167	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Maintenance Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations Ground	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations B Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations A Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps C Ø	57.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps B Ø	75.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps A Ø	44.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations	1	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	9 Month Operations	14	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	9 Month Operations VCB New	14	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps A Ø	72.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps B Ø	81.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps C Ø	74.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations A Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations B Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations C Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations Ground	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Maintenance Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AF	186	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AL	186	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations This Read Vac	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Switching Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Unknown Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps C Ø	154.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps B Ø	126.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations A Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations B Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps A Ø	130.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations C Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations Ground	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Maintenance Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AF	178	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AL	178	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations This Read Vac	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Switching Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Unknown Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations	1	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations Counter AF	162	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations Counter AL	162	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Maintenance Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Operations This Read Vac	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Switching Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Unknown Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations Ground	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations C Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations B Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations A Ø	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	9 Month Operations	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps A Ø	282.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps B Ø	284.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps C Ø	275.0	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	1539	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	2L	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	262935	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	262935	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	51	°C
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	51	°C
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.4824	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	64	°C
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	8683.20	kw
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.6	VDC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 13:54	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	89991	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	89991	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	421	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	181	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	181	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	93.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	101.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	70.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations VCB New	5	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	5	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	1	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	18.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	21.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	8.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	173	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	173	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations VCB New	4	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	4	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	110.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	120.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	120.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	237	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	237	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	291	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	291	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	1	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	58.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	61.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	55.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps A Ø	246.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps B Ø	284.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Amps C Ø	259.0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations A Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Maintenance Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations Counter AF	158	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations Counter AL	158	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Switching Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	Unknown Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Readings	9 Month Operations	0	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BK002054	BreakerVacuum	605-1	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	All Connections OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	42	°C
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	8640.00	kw
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Max	61	°C
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Present	41	°C
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	64	°C
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.4800	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.9	VDC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.2	VDC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/6/2023 12:21	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Positive DC Ground	8.0	VDC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Negative DC Ground	8.8	VDC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	General Comments	Can not check Bat Volt. 1 min	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BAT001655	Battery	100-Battery Bank 2	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	1490	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	3L	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	1L	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	7L	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	410	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	1482	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	56	°C
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	60	°C
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	7091	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	7098	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	591	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	6L	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	2R	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	7L	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	2689.92	kw
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	61	°C
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	46	°C
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.2802	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	1	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	190	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	190	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	218	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	218	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	215.0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	210.0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	205.0	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	1	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments		
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 12:10	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations VCB New	6	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	6	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments	DNO	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	155	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	155	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	533.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	529.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations VCB New	28	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	28	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	209	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	209	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	532.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	3	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations VCB New	2	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	181.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	192.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	195.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	1	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	225	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	225	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	4	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	163	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	163	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	4	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations VCB New	9	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	13	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	ok	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	106268	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	106268	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	95664	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	62	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	72	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	60	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	62	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 11:46	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps A Ø	92.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps B Ø	88.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps C Ø	98.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AF	195	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AL	195	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Switching Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Unknown Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Maintenance Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps C Ø	144.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Unknown Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Switching Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AL	204	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AF	204	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps A Ø	131.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps B Ø	141.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	192	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	192	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	138.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	126.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	120.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	9.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	7.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	219	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	219	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	13.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	6	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	2	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	2	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	1	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	7.91	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	7.91	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	91.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	5	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	118.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	128.0	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	541	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	541	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Time Delay	45	Seconds
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	All Connections OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	17936	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	17945	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	1R	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	6R	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	8L	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	1834	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	6950.88	kw
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	70	°C
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	49	°C
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.9654	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	All Connections OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	49759	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	49770	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	2312	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.9426	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	46	°C
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	46	°C
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	9048.96	kw
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.3	VDC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.900	millivolts
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	Gap under fence in right hand corner. some posts show rust	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 11:26	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	1	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	468	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	123.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	115.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	72.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	468	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	507	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	507	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	1	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	1	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	2	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations VCB New	1	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	233.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	283.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	249.0	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	359263	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	359275	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	2L	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	16L	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	1733	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	3667.20	kw
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.7640	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 10:26	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2023 12:57	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	944	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	944	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	166.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	174.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	189.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	273.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	286.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	286.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	642	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	642	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	5	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1358	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1358	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	12	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments	A,B IOC	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	5	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	25.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	35.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	33.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	53.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	49.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	55.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	277	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	277	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	185.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	207.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	196.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	725	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	725	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	711.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	283	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	283	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	678.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	707.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	158	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	158	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	193	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	193	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	233.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	215.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	202.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	25	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	125	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	125	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	115.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	116.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	161.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	15	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	129.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	183	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	119.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	142.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	183	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	106	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	106	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	470.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	442.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	504.0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1367	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	183161	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	183161	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7R	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	68	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	52	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	78	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	48	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	48	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	90	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	48	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.9	psi
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1442	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	138984	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	138984	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	76	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	47	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	4776	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	77	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	47	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	77	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	47	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	76	°C
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Unknown Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations B Ø	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations A Ø	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Switching Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations C Ø	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations Ground	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Maintenance Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations This Read Vac	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AL	211	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AF	211	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps C Ø	165.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	9 Month Operations VCB New	5	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	9 Month Operations	5	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps A Ø	110.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps B Ø	130.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	7	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	90.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	95.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	115.0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	1	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	263	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	263	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	1	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations VCB New	6	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	27961	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	27961	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	1032	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	5412.96	kw
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	.7518	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	49.2	VDC
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	°F
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	90	°F
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
9/6/2023 7:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	42.35	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	42.35	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	42.35	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations VCB New	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations VCB New	15	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations VCB New	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations VCB New	23	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	13	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	9 Month Operations GCB New	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	9 Month Operations GCB New	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	2	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	9 Month Operations GCB New	13	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	9 Month Operations GCB New	7	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	9 Month Operations GCB New	0	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/6/2023 8:42	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	250.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	180.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	260.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations VCB New	5	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	5	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	249	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	249	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2050	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2050	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	4	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations VCB New	4	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	180.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	190.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	190.0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	260669	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	260669	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	603	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	1.1580	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Present	46	°C
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Max	62	°C
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	3705.60	kw
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	°F
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.0	VDC
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	87	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/5/2023 14:17	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps C Ø	235.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps B Ø	217.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Unknown Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Switching Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations This Read Vac	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AL	204	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AF	204	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps A Ø	300.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations A Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations B Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations C Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations Ground	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Maintenance Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations	2	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	80.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	98.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	81.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	195	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	195	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	1	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1282	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	106605	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	106596	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	.7580	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	7276.80	kw
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	4.94	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	248.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	214.0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations VCB New	5	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	6	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	1	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	262	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	262	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	1	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	All Connections OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	180457	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	180464	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	1407	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	58	°C
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	50	°C
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.8170	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	7843.20	kw
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	5	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations VCB New	4	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	148.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	95.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	122.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	1	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	1	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	316	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	316	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	1	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	1	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	304	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	304	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	50.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	50.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	50.0	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations VCB New	6	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	7	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	285	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	1R	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	236967	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	236967	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	4697.28	kw
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	72	°C
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	48	°C
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.9786	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	FE000895	Fence	566-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 15:18	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.8	VDC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 13:36	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	2	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	30.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	6.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	234	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	234	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	22.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	109	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	107289	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	100655	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	129581	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1261.44	kw
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7008	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210.00	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:18	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	4	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations VCB New	4	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	840.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	820.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	820.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	192	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	192	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	646	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	2	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	646	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	927	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	239714	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	239714	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	6012.00	kw
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	1.0020	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BCH001566	Charger	836-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	°F
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.4	VDC
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 13:06	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations B Ø	1	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Maintenance Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations	6	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations VCB New	4	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AF	178	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AL	178	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations This Read Vac	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Switching Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Unknown Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps A Ø	50.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps B Ø	48.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps C Ø	100.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations A Ø	1	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Switching Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AL	178	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AF	178	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Maintenance Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps C Ø	245.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps B Ø	285.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps A Ø	285.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Unknown Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Maintenance Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AF	165	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AL	165	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Switching Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Unknown Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations C Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps A Ø	130.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps B Ø	110.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps C Ø	145.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Unknown Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Switching Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations This Read Vac	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AL	174	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AF	174	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Maintenance Operations	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations VCB New	2	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps A Ø	130.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps B Ø	115.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps C Ø	100.0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations Ground	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations B Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations A Ø	0	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	943	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	943	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	612	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.2664	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1598.40	kw
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	All Connections OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	757	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	4R	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	13821	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	13821	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.8100	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	60	°C
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	7776.00	kw
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	°F
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	48.6	VDC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	90	°F
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 13:01	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	459	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	459	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	1	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	5	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations VCB New	5	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	332.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	342.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	333.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	256	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	256	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	1	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	227	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	227	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	1	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	78.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	80.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	89.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	2	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	409.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	428.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	422.0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations VCB New	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	9 Month Operations GCB New	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	51	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	51	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	87	psi
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	85	°F
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	0	Seconds
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments	Not in Service	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4320	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4320	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	30	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	30	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	30	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	38	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	76321	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	76321	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	846	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	58	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	42	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	64	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	.8920	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Present	44	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Max	62	°C
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	8563.20	kw
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #~'s
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments	No Fuses in sub	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 12:33	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps C Ø	377.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps B Ø	378.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Unknown Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps A Ø	378.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	9 Month Operations VCB New	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	9 Month Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations A Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations B Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations C Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations Ground	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Maintenance Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AF	209	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AL	209	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations This Read Vac	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Switching Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	295	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	295	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	0.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	0.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	0.0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations VCB New	0	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	7R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	120575	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	161218	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113837	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	74	°C
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	74	°C
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1088	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	54	°C
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	59	°C
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10644.48	kw
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 11:14	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	182	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	182	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	5.86	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	2	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	170.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	195.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	175.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	224	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	224	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	34.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	25.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	44.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	92.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	97.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	236	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	92.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	236	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	2	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	182	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	182	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	5.86	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C Ø	118.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B Ø	104.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A Ø	134.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A Ø	1	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	162	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	162	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations VCB New	0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	480.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	480.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	480.0	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	1572	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	15L	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	212804	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	212795	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	43	°C
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	70	°C
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.8500	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	12240.00	kw
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Max	80	°C
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Present	62	°C
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments	large gaps under fence	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 10:16	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	32342	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	4R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	11R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	123782	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	123782	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	123782	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	4R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	11R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	2R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments	No counter	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	1R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	1R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	6R	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	Neutral	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 9:52	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	194	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	194	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	13.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	13.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	24.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	3.04	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	.76	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations VCB New	3	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	5	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	3	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	196	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	196	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	20.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	19.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	17.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	4.56	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations VCB New	5	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	1 BC, 1 switching op for bus disconnect replacement.	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	261	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	261	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	16	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	1	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	13	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	1	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	1	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	12.96	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	12.96	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	12.04	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	17	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments	ok	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	187182	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	87997	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	109605	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	48	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7410	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	889.20	kw
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments	fence needs fixed in two spots from vandalism	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:57	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments	top fan not working	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Negative DC Ground	21.0	VDC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Positive DC Ground	19.0	VDC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.1	VDC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BAT001648	Battery	665-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.4	VDC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.4	VDC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments	AF AL float wrong in cascade	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	122.9	VAC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.6726	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	6456.96	kw
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments	ok	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	53	°C
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	64	°C
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	33	°C
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	41	°C
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2400	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments	Replaced nitro bottle.	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	no SPR	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/1/2023 14:56	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	General Comments	unable to get amp reading	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	WX0339	RecloserHydraulic	646-1693	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	54700	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	219002	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	164657	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	10R	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments	ok	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments	ok	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
9/1/2023 15:09	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4620	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	554.40	kw
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	bad gauge	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments	barbed wire broken in a spot	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:38	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77184	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56084	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55578	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	11R	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2574.72	kw
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0728	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	130.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	163	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	391	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	52.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	51.0	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:31	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps B Ø	41.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps A Ø	48.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps C Ø	35.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	9 Month Operations VCB New	4	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	9 Month Operations	6	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Switching Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps B Phase V	14.23	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations This Read Vac	2	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AL	193	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations B Ø	2	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AF	193	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Maintenance Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	9 Month Operations	2	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps A Ø	18.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps B Ø	18.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations A Ø	1	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps A Phase V	7.12	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps C Ø	21.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Unknown Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Maintenance Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AF	198	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AL	198	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations This Read Vac	1	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Switching Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Unknown Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Switching Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations This Read Vac	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AL	173	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AF	173	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Maintenance Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps C Ø	19.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps B Ø	21.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps A Ø	19.0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	9 Month Operations	0	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6313	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Max Tap Position	10R	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7056	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7335	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Max	57	°C
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4212	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Present	33	°C
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3032.64	kw
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.1	VDC
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.000	millivolts
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 14:24	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps A Ø	17.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps B Ø	8.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps C Ø	8.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations A Ø	2	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations	3	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Unknown Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Switching Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations This Read Vac	2	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AL	193	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AF	193	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Maintenance Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Unknown Operations	1	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps C Ø	1.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps B Ø	9.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps A Ø	2.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations	2	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Switching Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations This Read Vac	1	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AL	223	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AF	223	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Maintenance Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Unknown Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps A Ø	5.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps B Ø	6.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps C Ø	5.0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Switching Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations A Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations B Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations C Ø	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations Ground	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Maintenance Operations	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AF	194	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AL	194	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations This Read Vac	0	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10054	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9670	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9837	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1180.80	kw
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Present	32	°C
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4920	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Max	46	°C
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.2	VDC
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.800	millivolts
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 14:13	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	22.0	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	63	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82621	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	209977	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	214229	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1806	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	288.96	kw
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.9	VDC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001685	Battery	497-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	13847	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	655	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	13858	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.4758	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments	Knob is broken on temp reset	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	4567.68	kw
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	2	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	332	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	125.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	155.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	90.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	332	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	2	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	4	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments	Oil seep at DETC	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	211	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	211	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	20.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	5	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations VCB New	5	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	18.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	20.0	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 15:15	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	9 Month Operations	1	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps A Ø	0.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps B Ø	4.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps C Ø	26.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Unknown Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Switching Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Maintenance Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AF	194	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AL	194	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations This Read Vac	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	9 Month Operations	1	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps A Ø	16.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps B Ø	26.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps C Ø	24.0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Maintenance Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AF	162	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AL	162	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations This Read Vac	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Switching Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Unknown Operations	0	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Regulator As Left Counter	66535	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Min Tap Position	1L	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Current Tap Position	1R	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Regulator As Left Counter	170596	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Regulator As Left Counter	244896	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.4146	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	43	°C
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	54	°C
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	331.68	kw
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 13:12	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Unknown Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Switching Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations This Read Vac	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps B Ø	62.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps A Ø	70.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations	4	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps C Ø	92.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations VCB New	4	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Maintenance Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AF	204	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AL	204	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps C Ø	65.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps B Ø	58.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps A Ø	65.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Maintenance Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Unknown Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AF	175	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AL	175	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations This Read Vac	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Switching Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Present	33	°C
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.8424	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Max	51	°C
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	8087.04	kw
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	851	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	69482	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	69494	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps A Ø	84.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps B Ø	80.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations	13	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps C Ø	90.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps A Phase V	27.36	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps B Phase V	27.36	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations A Ø	6	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations B Ø	6	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations C Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Maintenance Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AF	220	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AL	220	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations This Read Vac	12	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Switching Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Unknown Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	1	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	209.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	212.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	341	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	341	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	190.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations	1	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps A Ø	32.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps B Ø	55.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps C Ø	33.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations C Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations Ground	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Maintenance Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AF	170	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations A Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations B Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AL	170	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations This Read Vac	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Switching Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Unknown Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	47.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	53.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	48.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	4	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	13.68	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	3	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	205	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	205	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	3	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AL	192	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AF	192	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Maintenance Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Unknown Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations This Read Vac	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Switching Operations	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations Ground	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps C Ø	113.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps B Ø	98.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps A Ø	107.0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations C Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations B Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations A Ø	0	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	2	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	2	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	117.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	89.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	9.12	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	4	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	267	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	267	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	102.0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	5	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.2	VDC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	26019	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	26028	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	657	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	11L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	3L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	6L	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.9	VDC
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1714.56	kw
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0716	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments	needs new fan controls	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	95.0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	19.17	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	19.17	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	19.17	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	25.0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	145.0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	158	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	158	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	5	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	5	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	5	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	.6570	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	41	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	55	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	4730.40	kw
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	xfmr fuses are deteriorated	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments	needs yard light	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 12:11	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	455	Seconds
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 15:16	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.4	VDC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BAT001666	Battery	467-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 13:32	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	683	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	3L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	7L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	23743	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	23741	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	4204.80	kw
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	49	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.5840	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	48364	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	48370	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	813	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.0	VDC
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	°F
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments	cascade wont allow AF and AL float voltage entry	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13901	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	LTCC000990	LTCControl	301-1	LTC Control Insp	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.7416	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	7119.36	kw
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	61	°C
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	14520	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15297	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	3	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	24.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	24.0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	51.0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	1	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	1	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments	1-AG, 1-BG	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	2	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	214	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	214	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6192	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5944.32	kw
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	277	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	277	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	57.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	52.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	91.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	1	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	3	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations VCB New	3	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	23.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	37.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	27.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	250	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	250	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	1-CG, 1-CA-T	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	2	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	9	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations VCB New	7	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	139.0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	148.0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	2	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	234	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	154.0	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	234	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	4	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	213	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	213	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	4	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	64.76	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	45.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	35.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	36.0	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	5	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	79737	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	79739	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	548	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	SPR not in use	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 12:05	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	4544.64	kw
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	48	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.4734	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 13:05	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	87	°F
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 12:03	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13591	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments	drag hands wont reset	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16837	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17799	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8322	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7989.12	kw
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	-1	psi
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	2	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	186	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	32.38	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	186	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	2	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	77.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	51.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	53.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations VCB New	3	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	5	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	5	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations VCB New	6	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	5	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	102.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	110.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	92.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	80.95	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	80.95	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	80.95	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	272	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	272	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	11	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	32.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	23.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	29.0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations VCB New	7	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	7	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	187	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	0	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	187	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments	cascade wont allow either float voltage to be entered	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 11:40	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	44	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0648	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	39	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	19.44	kw
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	39	°C
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 11:46	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.6	VDC
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BAT001656	Battery	481-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.3	VDC
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	BCH001573	Charger	481-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33087	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.1	VDC
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.3	VDC
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BAT001660	Battery	410-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33741	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45824	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40104	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10020	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32911	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0092	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	130	°C
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9688.32	kw
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.7	psi
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	16	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	16	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	2	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments	7-8-23 AB-N Inst	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	1	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	1	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	5.20	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	43.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	54.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	52.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations VCB New	7	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	9	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	328	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	328	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	131.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	150.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	124.0	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	2	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	339	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	339	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	30.0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	43.0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	42.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	3	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	4.56	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	33	°C
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3330	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1198.80	kw
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	485	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	485	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	247.0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	254.0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	204.0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	1	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	17381	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	17371	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	1287	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments	meter is off	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	37	°C
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	229	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	229	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments	2-ABCN Inst	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	2	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	2	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	2	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	9.88	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	9.88	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	9.88	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	25.0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	6	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	10.0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	10.0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	8	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.710	millivolts
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments	ok	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	Small waskout left rear corner.	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:58	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 12:04	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments	SPR has been disabled	
9/1/2023 10:53	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BAT001687	Battery	480-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments	cabinet door needs replaced	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	3966	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	4R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	697844	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	697839	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	919	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	377288	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	205992	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	3974.40	kw
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	32	°C
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.8280	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	2	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	65.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	65.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	37.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	204	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	204	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	159.17	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	0	°C
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	4	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations VCB New	4	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	194	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	194	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	71.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	63.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	59.0	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	chipped bush	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	175	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	3	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	4	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	175	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments	7-24 C-N Inst/ 6-26 ABC	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	2	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	1	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	30.13	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	81.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	62.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	62.0	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	15.07	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.8442	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	168.84	kw
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	137	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	194	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	39.0	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.0	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	171	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.5	VDC
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BAT001611	Battery	596-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments	center phase of HV switch wire tied	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments	fence at ditch area needs attn	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:23	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments	small washout	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:22	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76931	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	150981	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113234	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	156.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations VCB New	8	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	8	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	162.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	156.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	228	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	228	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	54.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	39.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	236	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	236	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	51.0	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations VCB New	8	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	8	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	32	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	60.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	60.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	60.0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	162	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	162	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	19791	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	19803	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	8R	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	887	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	1233	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	108494	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	108486	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5356.80	kw
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	62	°C
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.5580	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	3331.20	kw
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	48	°C
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.3470	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.940	millivolts
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top fence rails are rusty, fence fabric seperated from post on the left hand side of the station	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:21	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.013	millivolts
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.6	VDC
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1687.68	kw
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3516	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 10:06	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51815	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50007	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41905	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99960	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99960	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	80.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	80.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	55.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2270.88	kw
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9462	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	192	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	192	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	115.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	83.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	87.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	1	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	80.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	76.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	81.0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	205	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	205	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	1	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments	Breaker is open.	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	166	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	166	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments	ok	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments	Bus needs wildlife protection.	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments	Fence fabric on right side of station is held together by aluminum tie wire. Needs to be repaired.	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments	Small washout is developing in front of gate.	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 10:18	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:50	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.600	millivolts
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.5	VDC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	22529	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	1123	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	1L	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	10R	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	22522	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.5874	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	51	°C
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	5639.04	kw
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	194	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	194	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	1	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	105.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	115.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	100.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	2	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	155	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	155	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/1/2023 9:30	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	53.6	VDC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	°F
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	54.5	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	17267	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	17273	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	1005	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.9744	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	67	°C
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	7015.68	kw
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	32.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	5	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	26.86	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	1	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	2	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments	2-CG, 1-BCG	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	214	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	214	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	3	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	32.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	38.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	97598	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	51.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	4	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	40.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	30.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations VCB New	4	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	258	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	258	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	93309	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BAT001659	Battery	576-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	5	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	208	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	208	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments	1-BG-T, 1-BG, 2-AG-T, 1-AG	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	2	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	3	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	26.86	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	40.29	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	49.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	6	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	54.0	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	69.0	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18422	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.700	millivolts
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	88753	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	counter broken	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	brabed wire rusty and sagging, one bayonet broken, fence post very loose	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	15566	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	15560	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	873	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 9:34	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1201.68	kw
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0014	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	13L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	70294	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.5	psi
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	281	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.0	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	330	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	273	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	6952.32	kw
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	62	°C
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.7242	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 9:21	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	20.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	20.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	120.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	1	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	269	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	269	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	1	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	1910	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	191	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	5.0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	59	°C
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1146.24	kw
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3582	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments	Needs wildlife protection.	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	105.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	85.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	80.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	1	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	147	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	147	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	110.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	65.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	65.0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	2	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	0	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	123	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	123	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	1	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations VCB New	1	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	182	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	182	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	24.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	16.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	21.0	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments	All fuse barrels are starting to deteriorate.	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	287470	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	287480	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	586	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	There is a washout in front right corner of station.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:16	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments	C phase SandC insulator has broken skirt. broken skirt center phase of 303. Whole station could use wildlife protection upgrade.	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	1889.28	kw
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Max	49	°C
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Present	34	°C
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.1968	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:15	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments	ok	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 9:20	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
9/5/2023 7:41	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.4	VDC
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BAT001669	Battery	006-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	8L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	11L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.8	volts
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	31037	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	1L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	9L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.6	volts
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	36990	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	52.5	VDC
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	24594	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.6	volts
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	2L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	9L	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments	cascade wont accept AF and AL float voltages	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	96043	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	6L	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	213055	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2805.12	kw
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	47	°C
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1688	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	144	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	144	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations VCB New	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	20.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	5.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	60.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	2R	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	8R	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	1861	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	15.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	5.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	5.0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations VCB New	1	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	1	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	224	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	224	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	514.56	kw
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6432	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments	Xfmr fuse barrels are frayed and whole station needs wildlife protection.	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments	fans not hooked up	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	55	°C
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 8:41	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	205	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	205	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	5.51	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	5.51	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	5.51	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	24.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	22.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	14.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations VCB New	2	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	5	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	3	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	3	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	39.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments	5 unknown	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	220	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	3543	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	3538	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	448	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.9588	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	39	°C
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	48	°C
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	2301.12	kw
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	5.0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	5.0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	13	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	13	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	5.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations VCB New	3	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	3	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.7	VDC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	0.0	VDC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 8:35	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Swept?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2023 8:40	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	180.0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	200.0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	2	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations VCB New	2	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	210.0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	298	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	298	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	369	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	369	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	4	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations VCB New	4	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	30.0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	50.0	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	LTC Totalizer Reading	6526.08	kw
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Present	45	°C
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Max	60	°C
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Reading	.6798	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Present	40	°C
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	6	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	1.11	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	1.11	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	80.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	849	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	849	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	534	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	534	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2559	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2559	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	89.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	98.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	7.76	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	62.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	425	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	425	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Month Ops New	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	40.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	70.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	50.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	102.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	65.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	2.04	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	2.04	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	2.04	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	3.38	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	80.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	50.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	90.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	394	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	394	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	96.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	88.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	115.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	6.65	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	5.54	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1134	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1134	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	2	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Month Ops New	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	917	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	917	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	68.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Month Ops New	6	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.98	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.98	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.98	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	300.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	250.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	250.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1044	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1044	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	1.12	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	1.12	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	1.12	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	355	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	355	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	8.15	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	8.15	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	8.15	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	63.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	65.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Month Ops New	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	3.38	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	3.38	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	803	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	803	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Month Ops New	2	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	2	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	6.87	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	5.5	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	6.87	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	36.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	26.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	25.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	275	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	275	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	5.63	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Month Ops New	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Month Ops New	2	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	2	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11589	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11589	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	26.48	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	4.44	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	398	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	398	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4991	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4991	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	80.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	126.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	78.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	2.23	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	2.23	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	2.23	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	68.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	95.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	8.05	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	8.05	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	250.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	8.05	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Month Ops New	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	101.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	4.07	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	10.18	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	250.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	0.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	250.0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	1	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.02	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4517	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4517	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	930	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	930	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.02	%
8/30/2023 14:03	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.02	%
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Operations Since Last Insp	471	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Min Tap Position	5L	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Found Counter	3622	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Left Counter	3622	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	All Connections OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Operation Checked?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.5	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/31/2023 20:23	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	2	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	243	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	2430	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	2	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	4	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations VCB New	2	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	2	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations VCB New	2	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1592	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1592	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	3	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations VCB New	3	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	150.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	150.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	283	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	180.0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	283	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	0	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	11707	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	11707	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	3R	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	6R	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	230	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3726.72	kw
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.3882	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.8	VDC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/29/2023 14:39	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Unknown Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Switching Operations	2	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations A Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations This Read Vac	2	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AL	197	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps A Ø	80.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	9 Month Operations	3	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	9 Month Operations VCB New	1	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps B Ø	80.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AF	197	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Maintenance Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations Ground	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations C Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps C Ø	80.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations B Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	9 Month Operations VCB New	10	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	9 Month Operations	12	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps A Ø	65.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps B Ø	65.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Switching Operations	2	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations This Read Vac	2	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps C Ø	65.0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AL	183	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Unknown Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AF	183	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations A Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Maintenance Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations B Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations C Ø	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations Ground	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	1	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	341	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	9 Months Operations OCB New	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	341	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	1	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	1	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2023-02-22 00:00:00.000000	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	5656	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	5656	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	2R	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	5R	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	1R	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	118	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	2856.96	kw
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.2976	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	55	°C
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
8/29/2023 7:11	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	375.0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	385.0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	380.0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations VCB New	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	9 Month Operations GCB New	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	78	°F
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	127.0	VAC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	721	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	4R	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	2R	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	42696	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	42696	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	60	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	55	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	9900.92	kw
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.9745	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.0	VDC
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearnce?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
8/29/2023 6:59	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/28/2023 8:49	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	9 Month Operations GCB New	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Fault Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Num Operations Last 9 Months	1	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations Counter AF	147	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations Counter AL	147	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Operations This Read SF6	1	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Switching Operations	1	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Pressure	66	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	General Comments	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Ambient Temperature	80	°F
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	9 Month Operations	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	9 Month Operations VCB New	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Switching Operations	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations This Read Vac	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations Counter AL	116	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Readings	Operations Counter AF	116	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Switching Operations	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations This Read Vac	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations Counter AL	115	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Operations Counter AF	115	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	9 Month Operations VCB New	23	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Readings	9 Month Operations	25	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002209	BreakerVacuum	830-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002298	BreakerVacuum	830-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	9 Month Operations	38	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	9 Month Operations VCB New	36	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps A Ø	505.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps B Ø	475.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Amps C Ø	470.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Switching Operations	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations This Read Vac	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations Counter AL	136	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Readings	Operations Counter AF	136	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002297	BreakerVacuum	830-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations Counter AF	116	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations Counter AL	116	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Operations This Read Vac	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps C Ø	255.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps B Ø	250.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Amps A Ø	245.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Switching Operations	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	9 Month Operations VCB New	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Readings	9 Month Operations	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002208	BreakerVacuum	830-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	9 Month Operations	31	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	9 Month Operations VCB New	31	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps A Ø	160.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps B Ø	125.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Amps C Ø	160.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations Counter AL	106	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Operations Counter AF	106	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002301	BreakerVacuum	830-0411	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps C Ø	225.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps B Ø	250.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Amps A Ø	240.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	9 Month Operations VCB New	29	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	9 Month Operations	29	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations Counter AF	112	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations Counter AL	112	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002302	BreakerVacuum	830-0397	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations Counter AF	91	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations Counter AL	91	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	9 Month Operations	28	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	9 Month Operations VCB New	28	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002300	BreakerVacuum	830-0396	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	9 Month Operations	27	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	9 Month Operations VCB New	27	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations Counter AL	115	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Operations Counter AF	115	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002299	BreakerVacuum	830-0412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Switching Operations	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations This Read Vac	8	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations Counter AL	127	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Operations Counter AF	127	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps C Phase V	24.53	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps B Phase V	24.53	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Fault Adjusted Amps A Phase V	24.53	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps C Ø	75.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps B Ø	100.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Amps A Ø	70.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	9 Month Operations VCB New	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	Unknown Operations	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Readings	9 Month Operations	10	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002213	BreakerVacuum	830-0410	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps C Ø	180.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps B Ø	155.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Amps A Ø	190.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations Counter AF	114	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations Counter AL	114	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	9 Month Operations VCB New	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	9 Month Operations	4	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002212	BreakerVacuum	830-0400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations Counter AL	118	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Operations Counter AF	118	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	9 Month Operations VCB New	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	9 Month Operations	2	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002211	BreakerVacuum	830-0399	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	9 Month Operations VCB New	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	9 Month Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps C Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps B Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations Ground	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations B Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations C Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Operations A Ø	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Amps A Ø	0.0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Unknown Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Switching Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations This Read Vac	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations Counter AL	113	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Operations Counter AF	113	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Readings	Maintenance Operations	0	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK002210	BreakerVacuum	830-0398	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000232	Switchgear	830-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Operations Since Last Insp	1017	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Min Tap Position	3L	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Max Tap Position	10R	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC Current Tap Position	3R	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC As Left Counter	4182	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	LTC As Found Counter	4182	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	LTC Operation Checked?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000925	LTCControl	830-2	LTC Control Insp	All Connections OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Winding Temp Present	40	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Winding Temp Max	40	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Totalizer Meter Reading	.6297	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Oil Temp Present	40	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Oil Temp Max	40	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	LTC Totalizer Reading	15112.80	kw
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearnce?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	SWG000233	Switchgear	830-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC As Found Counter	1459	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC As Left Counter	1459	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Current Tap Position	2R	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Max Tap Position	8R	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Min Tap Position	3L	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	LTC Operations Since Last Insp	241	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	LTC Operation Checked?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCC000957	LTCControl	830-1	LTC Control Insp	All Connections OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	LTCM000124	LTCMechanism	830-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Oil Temp Max	43	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Oil Temp Present	43	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Totalizer Meter Reading	.6472	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X1 Winding Temp Max	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X1 Winding Temp Present	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X2 Winding Temp Max	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X2 Winding Temp Present	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X3 Winding Temp Max	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	X3 Winding Temp Present	44	°C
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	LTC Totalizer Reading	15532.80	kw
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	TX000288	WithLTC	830-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Ambient Temperature	80	°F
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	General Comments	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Pressure	66	psi
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2023 11:50	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	80	°F
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations This Read Vac	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	313	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	313	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations VCB New	3	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	135.0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	153.0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	153.0	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	3	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55067	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.4	volts
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51905	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	55251	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5130	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4924.80	kw
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	51.5	VDC
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BAT001632	Battery	634-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	86	°F
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	BCH001581	Charger	634-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments	no spill kit in station	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/25/2023 10:51	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	86	°F
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations VCB New	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps A Ø	163.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps B Ø	195.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps C Ø	168.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations A Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations This Read Vac	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AL	156	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AF	156	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations VCB New	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	152.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	133.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	113.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations This Read Vac	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	74	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	74	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	142.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	159.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	199.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations VCB New	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	226	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	226	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations This Read Vac	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AL	170	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AF	170	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations	4	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations C Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations A Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps C Ø	72.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps B Ø	72.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps A Ø	58.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations VCB New	4	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	4	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations VCB New	3	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	178.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	201.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	187.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	4.81	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	214	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	214	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations This Read Vac	1	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations VCB New	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	480.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	490.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	480.0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations A Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations B Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations C Ø	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations Ground	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99956	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99956	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations This Read Vac	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	96256	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	96256	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	4L	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	5R	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	8L	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	1252	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	LTC Operation Checked?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	LTC Output Voltage Level	122.6	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	All Connections OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000974	LTCControl	588-2	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments	needs desicant	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	14796.00	kw
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	60	°C
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	60	°C
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.8220	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	279340	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	279340	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	6L	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	8L	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	1136	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	7276.80	kw
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	60	°C
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	55	°C
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.7580	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Bat Volt 1Min After Chgr Trip	50.5	VDC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments	signs need updating	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/25/2023 9:33	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	55	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0234	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	52	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	52	°C
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	98.28	kw
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	7.0	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	7.0	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments	Bird in SS Txfmr	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	213	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments	ok	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	94	°F
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments		
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/24/2023 12:29	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Grounds in Place?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Unknown Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Switching Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations This Read Vac	1	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AL	201	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AF	201	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Maintenance Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations Ground	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations C Ø	1	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations B Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations A Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps C Ø	140.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps B Ø	150.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps A Ø	140.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations VCB New	1	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations	2	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations	2	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations VCB New	2	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps A Ø	130.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps B Ø	145.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps C Ø	135.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations A Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations B Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations C Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations Ground	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Maintenance Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Unknown Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AF	191	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AL	191	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations This Read Vac	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Switching Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Grounds in Place?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Unknown Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Switching Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations This Read Vac	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AL	174	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AF	174	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Maintenance Operations	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations Ground	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations C Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations B Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations A Ø	0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps C Ø	30.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps B Ø	25.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps A Ø	40.0	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations VCB New	2	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations	2	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	General Comments		
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8/24/2023 11:22	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup